MIL-P-21325A(Wep)
20 September 1963
Superseding
MIL-P-21325(NOrd)
21 April 1958

MILITARY SPECIFICATION

POWER SUPPLY FOR TEST SET MARK 281 MOD 0

This specification has been approved by the
Bureau of Naval Weapons, Department of the Navy.

1. SCOPE

1.1 Scope. This specification establishes the requirements for the procurement of a 115 volt, 400 cycle, 3 phase Power Supply, LD 298427, for tender and shore base use with Test Set Mark 281 Mod 0. This power supply is of one type and one class.

2. APPLICABLE DOCUMENTS

2.1 The following documents of the issue in effect on the date of invitation for bids or request for proposal form a part of this specification to the extent specified herein.

SPECIFICATIONS

FEDERAL

PPP-B-601	Boxes, Wood, Cleated-Plywood
PPP-B-621	Boxes, Wood, Nailed and Lock-Corner

MILITARY

MIL-P-116	Preservation, Methods of
MIL-T-945	Test Equipment, For Use with Electronic Equipment; General Specification
MIL-P-16298	Preservation, Packaging, Packing, and Marking of Electric Machines Having Rotating Parts and Associated Repair Parts

FSC 6130

Source: https://assist.dla.mil -- Downloaded: 202610-19T09:16Z
Check the source to verify that this is the current version before use.

STANDARDS

MILITARY

MIL-STD-105	Sampling Procedures and Tables for Inspection by Attributes
MIL-STD-129	Marking for Shipment and Storage

DRAWINGS

NAVY DEPARTMENT

BUWEPS LD 298427	400 Cycle Power Supply Assembly
BUWEPS Dwg 1473087	400 Cycle Power Supply Assembly
BUWEPS Dwg 1803355	Power Supply, 400 Cycles, Schematic Diagram
BUWEPS Dwg 1803393	Phase Sequence Indicator

PUBLICATIONS

BUREAU OF NAVAL WEAPONS

OS 6341	Miscellaneous General Ordnance Design Requirements

(Copies of specifications, standards, drawings, and publications required by contractors in connection with specific procurement functions should be obtained from the procuring activity or as directed by the contracting officer.)

2.2 Other publications. The following documents form a part of this specification to the extent specified herein. Unless otherwise indicated, the issue in effect on date of invitation for bids shall apply.

NATIONAL BUREAU OF STANDARDS PUBLICATIONS

Handbook H28	Screw-Thread Standards for Federal Services

(Application for copies should be addressed to the Superintendent of Documents, Government Printing Office, Washington 25, D. C.)

Source: https://assist.dla.mil -- Downloaded: 2026-10-19T09:16Z
Check the source to verify that this is the current version before use.

3. REQUIREMENTS

3.1 Description. The equipment shall provide 115 volts, 400 cycles per second (cps), 3 phase regulated power with a minimum rating of 350 volt amperes at 0.75 power factor. It shall consist of a motor generator set operating from 115 volt, 3 phase, 60 cps input, made up of the following sections:

3.1.1 A 60 cps alternating current motor.

3.1.2 A 400 cps alternating current generator.

3.1.3 A voltage and frequency regulating device.

3.1.4 Voltage and frequency adjustment potentiometers.

3.1.5 Output tip jacks to allow for the measuring of voltage, frequency, and phase rotation.

3.2 General requirements

3.2.1 Preproduction samples. Unless otherwise specified in the contract or order, preproduction samples of the power supply shall be manufactured using the methods and procedures proposed for the production lot. These samples will be tested as specified in section 4 herein and are for the purpose of determining that the production item meets the requirements of this specification and the design. Provision of samples shall be in accordance with 4.1.2.

3.2.2 Materials. Unless otherwise specified in the contract, requisition, or order, all materials and purchased parts entering into the final assembly of the power supply shall conform strictly to the detailed requirements indicated on the drawings and specifications listed in BUWEPS LD 298427.

3.2.3 Finishes, coatings, construction, and dimensions. Finishes, coatings, construction, and dimensions for the power supply shall be strictly in accordance with the applicable drawings, specifications, and publications listed in BUWEPS LD 298427.

3.2.4 Moisture, fungus, and corrosion. The power supply shall be rendered moisture, fungus, and corrosion resistant as required by OS 6341 and shall be in accordance with the detail requirements specified in the drawings and specifications listed.

3.2.5 Marking. Marking of assemblies, subassemblies, and parts shall be in accordance with the applicable drawings listed in BUWEPS LD 298427.

Source: https://assist.dla.mil -- Downloaded: 202610-19T09:16Z
Check the source to verify that this is the current version before use.

3.2.6 Interchangeability. Component parts of assembled units (unless otherwise specified on the applicable drawings) fabricated in strict agreement with their applicable drawings, shall be interchangeable and shall assemble with mating components of the unit without selection or fitting. If, during assembly of the fabricated parts of a unit, selection or fitting is required then changes in dimensions are necessary and revision and correction of the applicable drawings is required. See 3.2.9.

3.2.7 Gages. The contractor shall provide himself with whatever gages are necessary and adequate to insure that the material to which this specification applies will meet the dimensional requirements shown on the applicable drawings. If so stipulated in the contract, order, or requisition, the Government will furnish drawings of pertinent Navy Final Inspection Gages for guidance in the design of the contractor's inspection gages. However, such procedure shall not serve to relieve the contractor of his responsibility in the design and manufacture of such gages as may be required in the satisfactory fulfillment of the contract requirements, but is intended to facilitate acceptance of all components and assemblies by Navy Final Inspection Gages.

3.2.8 Threads. Unless otherwise specified, all threads shall be in accordance with the National Bureau of Standards Handbook H28. The class or fit for threads shall be as specified on the applicable drawings.

3.2.9 Conflicting requirements. Conflicting requirements arising from this specification and any specifications, publications, or drawings listed herein shall be referred in writing to the procuring agency or appointed agent for interpretation, clarification, and resolution (or correction).

3.3 Definitions. Definitions applicable to the environmental requirements of this specification are as follows:

3.3.1 Vibration. Vibration is a sinusoidal motion defined by amplitude and frequency. The amplitude may refer to displacement or acceleration. The displacement is given in inches peak to peak, or the corresponding maximum acceleration in gravity units (g). The frequency is given in cycles per second (cps).

3.3.2 Shock. Shock is an abrupt change in the motion of a body, resulting from the sudden application of a large external force of short duration. Shock, in general, can be described as a buildup of 90 percent of peak force in less than 0.010 second. Shock is described (a) as a pulse in units of gravitational acceleration (g's), (b) duration in milliseconds (ms), and (c) some description of the shock wave form.

Source: https://assist.dla.mil -- Downloaded: 202640-19T09:16Z
Check the source to verify that this is the current version before use.

3.3.3 Ready condition. The condition of the power supply when fully assembled and ready for operation.

3.4 Performance requirements and product characteristics. The power supply shall meet the following performance requirements and product characteristics:

3.4.1 Input power. The power supply shall operate with an input power of 115 volt plus or minus 10 percent, 3 phase, 60 cps plus or minus 10 percent alternating current. Phase rotation shall be A-B-C with C,D, and E of input receptacles (BUWEPS Dwg 1803355) connected to phases A, B, and C, respectively.

3.4.2 Output power. The output of the power supply shall be as follows:

3.4.2.1 Three phase 115 plus or minus 7 volts at 400 plus or minus 3 cps frequency. The voltage and frequency shall be adjustable to these values at any balanced load from a no load to a full load condition.

3.4.2.2 When adjusted to 115 plus or minus 7 volts and 400 plus or minus 3 cps at any balanced load, the power supply shall maintain this voltage and frequency over a 20 percent change in the balanced load.

3.4.2.3 Three hundred and fifty volt amperes at 0.75 power factor.

3.4.2.4 The phase rotation shall be A-B-C with C, D, and E of output receptacle, respectively. The phase rotation shall also be A-B-C at output jacks J1, J2, and J3, respectively.

3.4.3 Size. The overall dimensions of the power supply shall be within the limits specified on BUWEPS Dwg 1473087.

3.4.4 Weight. The weight of the power supply shall be no greater than 110 pounds.

3.4.5 Inclination. The power supply shall be capable of operating to the requirements of this specification when tilted at an angle of 50 degrees.

3.4.6 Operating life. The power supply shall have a minimum total operating life of 1000 hours without adjustment, maintenance, or repair.

3.5 Environmental requirements

3.5.1 Vibration. The power supply, mounted rigidly on a vibration device, shall be subjected to vibration requirements as follows:

Source: https://assist.dla.mil -- Downloaded: 20261O-19T09:16Z
Check the source to verify that this is the current version before use.

3.5.1.1 Vibration, transportation, storage and handling. The power supply, packaged and packed as specified in section 5, and mounted as specified in 4.6.1.1, shall withstand the vibration tests specified in 4.6.1.1 and thereafter shall show no damage and meet all the performance and product characteristic requirements of this specification.

3.5.1.2 Vibration, ready-non-operating, or ready condition. The power supply, less packing or packaging, shall be mounted as specified in 4.6.1.2 and shall withstand vibration testing as specified in 4.6.1.2, and thereafter shall show no damage and meet all performance requirements and product characteristics of this specification.

3.5.2 Shock. The power supply, mounted rigidly on a shock testing device, shall be subjected to shock requirements as follows:

3.5.2.1 Shock, transportation, storage and handling. The power supply, packaged and packed as specified in section 5, shall withstand the rough handling tests of 4.6.2.1 and thereafter shall show no damage and shall meet all the performance requirements and product characteristics of this specification.

3.5.2.2 Shock, ready-non-operating, or ready condition. The power supply, less packing or packaging, shall be mounted and shall withstand the shock requirements as specified in 4.6.2.2, and thereafter shall show no damage and shall meet all performance requirements and product characteristics of this specification.

3.5.3 Temperature and humidity.

3.5.3.1 Operating temperature. The power supply shall meet the performance requirements of this specification at any ambient temperature between plus 30 degrees Fahrenheit (F) and 130 degrees F.

3.5.3.2 Humidity. External humidity conditions of 100 percent up to and including 160 degrees F and including conditions wherein condensation takes place in the form of both water and frost shall cause no malfunction in the power supply during or after 5 hours of extended exposure.

3.5.4 Cleanup. Prior to and after final assembly all parts, components, and the assembly shall be thoroughly cleaned of loose, spattered, or excess solder, metal chips, and other foreign matter. Burrs and sharp edges as well as rosin flash shall be removed.

3.6 Workmanship. The equipment, including all parts and accessories, shall be constructed and finished in a manner to assure compliance with all requirements of this specification. Particular attention shall be paid to neatness and thoroughness of soldering, wiring, impregnation of coils, marking of parts and assemblies, plating, printing, riveting, machine screw assemblage, welding, brazing, and freedom of parts from burrs and sharp edges.

Source: https://assist.dla.mil -- Downloaded: 2026-10-19T09:16Z
Check the source to verify that this is the current version before use.

4. QUALITY ASSURANCE PROVISIONS

4.1 The supplier is responsible for the performance of all inspection requirements as specified herein. Except as otherwise specified, the supplier may utilize his own or any other inspection facilities and services acceptable to the Government. Inspection records of the examination and tests shall be kept complete and available to the Government as specified in the contract or order. The Government reserves the right to perform any of the inspections set forth in the specification where such inspections are deemed necessary to assure supplies and services conform to prescribed requirements.

4.1.1 Sampling. Sampling plans and procedures used by the Government inspector in the determination of the acceptability of products submitted by a supplier for Government inspection shall be in accordance with the provisions set forth in MIL-STD-105.

4.1.2 Preproduction sample. Unless otherwise specified for each contract or order, a representative sample of five power supplies shall be manufactured using the methods and procedures proposed for the production lot. These shall be submitted to the Government inspector for preproduction tests at an activity designated in the contract or by the Bureau of Naval Weapons, for purposes of determining compliance with the requirements of the contract, specifications, and drawings. Further production of the item by the contractor prior to approval of the contracting activity or the completion of tests on preproduction samples shall be at the contractor's risk. Preproduction samples accepted will be applied as part of the quantity specified by the contract or order.

4.1.3 Lot size. As applied to Government inspection of units of product, the term "lot" shall mean "inspection lot", i.e., a collection of units of product submitted by a supplier for Government inspection. Unless otherwise specified, the number of units of product in "inspection lots" shall be determined by the Government inspector and may differ from the quantity designated in the contract or order as a "lot" for production, shipment, or other purpose.

4.1.4 Periodic production samples. From each 300 power supplies successively produced, a random sample of 5 power supplies will be selected by the government inspector for submission to a Bureau of Naval Weapons assigned activity and tested in accordance with 4.5 and 4.6 to determine compliance with the requirements of the contract, specification, and drawings. For less than 300 power supplies successively produced, the sample size shall be in accordance with standard MIL-STD-105 appendix, Inspection Level L-5. The power supplies shall be considered satisfactory if they meet all specifications and pertinent drawing requirements and withstand the tests specified in 4.5 and 4.6.

Source: https://assist.dla.mil -- Downloaded: 20260410-19T09:16Z
Check the source to verify that this is the current version before use.

4.2 Contractor's inspection. Contractor's inspection shall be conducted in accordance with provisions of 4.1.

4.3 Classification of tests. The inspection and testing of the power supply shall be classified as follows:

4.3.1 Acceptance tests. These tests, defined in 4.5, shall be accomplished by the manufacturer on each power supply being submitted for acceptance under contract. Failure in any test shall be cause for rejecting the power supply.

4.3.2 Preproduction and periodic production tests. Preproduction and periodic production tests are those which are accomplished on samples selected as specified in 4.1.2 and 4.1.4 which are representative of the production of the power supplies after the award of the contract to determine that the lot and production meet the requirements of this specification. These are detailed in 4.6. Acceptance shall be based on no defects in a sample. Failure of a sample to comply with these requirements will result in the rejection of the lot or the cessation of production as determined by the procuring activity.

4.4 Test equipment. The following items of test equipment are required to perform the acceptance tests set forth in this specification:

4.4.1 Frequency meter capable of measuring 400 plus or minus 10 cps with an accuracy of 1 cps.

4.4.2 AC voltmeter with a voltage range of 0 to 150 volts and an accuracy of plus or minus 2 percent.

4.4.3 Three rheostats of 250 ohms value at 400 watts. Three capacitors to provide a 0.75 power factor load.

4.4.4 Sixty cps, 3 phase power source variable in frequency from 54 to 66 cps and in voltage from 103.5 to 126.5 volts. Regulation of the source must be flat over the frequency voltage range specified and from 0 to 3 amperes.

4.4.5 A means for applying 1000 volts root mean square (rms) value, 60 cps, through a current limiting source.

4.4.6 Phase sequence indicator capable of measuring phase rotation at 60 cps and 400 cps, BUWEPS Dwg 1803393 or equivalent.

4.4.7 Megohmmeter with a range of 0.5 to 10 megohms at 500 volts dc and a full scale accuracy of 5 percent.

Source: https://assist.dla.mil -- Downloaded: 2026-10-19T09:16Z
Check the source to verify that this is the current version before use.

4.5 Acceptance tests

4.5.1 The contractor shall conduct acceptance tests as specified in 4.3.1 to assure that the power supply is in compliance with the requirements of 3.2, 3.4, 3.5.4, and 3.6.

4.5.2 Test conditions. Unless otherwise specified the power supply shall be subjected to acceptance tests under the following conditions:

4.5.2.1 Temperature: Room ambient 65 degrees F to 95 degrees F (18.33 degrees centigrade (C) to 35 degrees C).

4.5.2.2 Altitude: Normal ground.

4.5.2.3 Vibration: None.

4.5.2.4 Humidity: Room ambient to 95 percent relative maximum.

4.5.3 Test and inspection equipment and facilities. The manufacturer shall furnish and maintain all necessary test equipment, facilities, and personnel for performing all acceptance tests. The test equipment shall be adequate in quantity, and when definite requirements are not specified, shall be of sufficient accuracy and quality to permit performance of the required acceptance tests.

4.5.4 Test procedure.

4.5.4.1 Visually inspect the unit for signs of damage, defective workmanship, or missing parts.

4.5.4.2 Connect the input power cable to the power source (4.4.4).

4.5.4.2.1 Turn on power. Operate the power supply for at least 15 minutes, checking for any signs of smoking or excessive heating.

4.5.4.2.2 Connect the frequency meter (4.4.1) to the output tip jacks, and adjust the frequency until the output is 400 plus or minus 3 cps.

4.5.4.2.3 Connect the voltmeter (4.4.2) to the output tip jacks and adjust the voltage until the output is 115 plus or minus 7 volts. Readjust the frequency as in 4.5.4.2.2 if necessary.

4.5.4.2.4 Using the phase sequence indicator of 4.4.6, verify that with the input phase rotation specified in 3.4.1, the output phase rotation meets the requirements of 3.4.2.4.

Source: https://assist.dla.mil -- Downloaded: 2026-10-19T09:16Z
Check the source to verify that this is the current version before use.

4.5.4.3 Connect the three rheostats (4.4.3) to the output of the power supply so they form a balanced load on the three phases. Adjust the frequency and voltage to the limits as given in 4.5.4.2.2 and 4.5.4.2.3.

4.5.4.3.1 Vary the input voltage and frequency over the ranges of 103.5 to 126.5 volts and 54 to 66 cps. The output shall remain 400 plus or minus 3 cps and 115 plus or minus 7 volts.

4.5.4.3.2 At 60 cps and 115 volts input, reduce the balanced load by 20 percent. The output shall remain 400 plus or minus 3 cps and 115 plus or minus 7 volts.

4.5.4.4 Change the balanced full load to a balanced one-half load and repeat 4.5.4.3 and 4.5.4.3.1. Change the load to a balanced full load at 0.75 power factor, using capacitor 4.4.3. After adjustment the output shall be 400 plus or minus 3 cps and 115 plus or minus 7 volts.

4.5.4.5 With all grounds removed apply 1000 volts rms, 60 cps to the insulation of the machine for 1 minute. Immediately afterward measure the insulation resistance with a 500 volt resistance indicator (4.4.7). The resistance shall be 3 megohms or greater.

4.6 Preproduction and periodic production tests

4.6.1 Vibration. The power supply, mounted on a vibration device to simulate as realistically as possible its service condition, shall be subjected to vibration testing as required by 3.5.1. At the conclusion of the test, the power supply shall meet the performance and other requirements of this specification.

4.6.1.1 Vibration-transportation. The power supply, packaged and packed as specified in section 5, shall be vibration tested as follows:

4.6.1.1.1 The vibration range given below shall be explored to determine resonant points. All resonant points shall be vibrated for 30 minutes each in the 3 mutually perpendicular axes at the G values indicated for the frequency of the resonant point in question. No deviation from the vibration ranges given below shall be allowed without prior approval in writing from the procuring activity. Special testing techniques approved by the procuring activity may be used to vibrate the packs. Packs shall be attached to the vibration test equipment in the manner most closely simulating the method of attachment to the shipping vehicle:

Source: https://assist.dla.mil -- Downloaded: 202610-19T09:16Z
Check the source to verify that this is the current version before use.

Acceleration (G's)	Frequency (cps)	Double Amplitude (inches)
1.3	From 2	6.0
1.3	To 26	0.036
5.0	From 52	0.036
5.0	To 300	0.0017

Reason: To test ability of packing to protect packaged items against transportation vibration.

4.6.1.2 Vibration, ready non-operating or ready condition. The test set, less packaging or packing, shall be mounted on a vibration table to simulate as realistically as possible its service condition and shall be vibrated for a total period of two hours as specified in the table below. The direction of vibration shall be in each of three mutually perpendicular axes. The frequency range shall be varied uniformly, starting at five cps to its high frequency limit and returning to five cps in the time specified:

Frequency (cps)	Total Excursion (inch)	Time (min)
5-15	0.060 ± 0.006	40

4.6.2 Shock. The power supply, mounted on a shock-testing device to simulate as realistically as possible its service condition, shall be shock tested as follows:

4.6.2.1 Shock-transportation, storage, and handling. The power supply, packaged and packed as specified in section 5, shall be subjected to the appropriate rough handling tests specified in Specification MIL-P-116.

Reason: To test the adequacy of cushioning and packing, as required.

4.6.2.2 Shock, ready non-operating, or ready condition. The power supply, less packing or packaging, mounted on a shock-testing device to simulate as realistically as possible its service condition, shall be subjected to shock testing as specified in shock test of Specification MIL-T-945. At the conclusion of the test, the power supply shall meet the performance and other requirements of this specification.

4.6.3 Temperature and humidity. The power supply shall be subjected to temperature and humidity testing as required in 3.5.3 and as specified in 4.4.2 and 4.4.4 of Specification MIL-T-945. At the conclusion of the test the power supply shall meet the performance requirements and product characteristics specified herein.

Source: https://assist.dla.mil -- Downloaded: 20260-19T09:16Z
Check the source to verify that this is the current version before use.

4.6.4 Operating life. Operate the power supply continuously for 750 hours, stopping only for routine maintenance, and perform the tests of 4.5.4 once every 24 hours.

4.6.5 Functional tests. At the conclusion of tests specified in 4.6.1.1 and 4.6.2.1 above, functional and other tests, as applicable, shall be conducted on the power supply to determine freedom from operational malfunction and compliance with all requirements of section 3.

4.6.6 Waiver of tests. Tests specified in 4.6.1.1 and 4.6.2.1 above may be waived by the procuring agency for level C packs only, provided the contractor guarantees safe delivery to the using activity.

4.7 Failure of the power supply to meet any of the requirements and tests of this specification shall be considered cause for rejection.

5. PREPARATION FOR DELIVERY

5.1 Preservation and packaging

5.1.1 Level A. In addition to the following, level A packaging shall be in accordance with MIL-P-16298.

5.1.1.1 Cleaning. Unless otherwise specified, the power supply shall be cleaned in accordance with Method C-1 of Specification MIL-P-116.

5.1.1.2 Drying. Unless otherwise specified, the power supply shall be dried in accordance with one or more of the procedures given in Specification MIL-P-116, provided the procedure is not injurious to the item.

5.1.1.3 Preservative application. None, unless otherwise specified.

5.1.1.4 Unit packaging. Unit packaging of the power supply shall be in accordance with Method IIa of Specification MIL-P-116. The unit package shall contain one power supply.

5.1.1.5 Intermediate package. None.

5.1.1.6 Cushioning. The unit package, intermediate package (when used), and pack shall incorporate sufficient cushioning material, bracing, or other adequate shock absorbing devices to ensure that the power supply will meet all the requirements of section 3 after being tested in accordance with section 4. At the time of packaging or packing, the moisture content of the cushioning material shall be no more than 5 percent.

5.1.2 Level B. Not applicable.

Source: https://assist.dla.mil -- Downloaded: 2026-10-19T09:16Z
Check the source to verify that this is the current version before use.

5.1.3 Level C

5.1.3.1 Cleaning, drying, and preservation. Cleaning, drying, and preservation shall be in accordance with 5.1.1.

5.1.3.2 Unit packaging. Unit packaging shall be in accordance with Method IA-16 of Specification MIL-P-116. The unit package shall contain one power supply.

5.1.3.3 Intermediate package. None.

5.1.3.4 Cushioning. The cushioning shall be in accordance with 5.1.1.6.

5.2 Packing

5.2.1 Level A. In addition to the following, level A packing shall be in accordance with MIL-P-16298.

5.2.1.1 Exterior containers. One power supply, packaged as described in 5.1.1.4, shall be packed in any overseas type container given in 5.2.4 that is constructed in accordance with its applicable specification, provided the gross weight and dimensions, as given for that container, are not exceeded.

5.2.2 Level B. Not applicable.

5.2.3 Level C. The power supply, packaged as specified in 5.1.3.2, shall be packed in any domestic type container given in 5.2.4 that is constructed in accordance with its applicable specification, provided the gross weight and dimensions, as given for that container, are not exceeded.

5.2.4 List of permissible containers:

Item Specification	Description	Overseas Max.Wt. (Lbs.)	(Lev.A) Max. Dim. (Inches)	Domestic Max.Wt. (Lbs.)	Lev.C Max. Dim. (Inches)
PPP-B-601	Boxes, Wood, Cleated-Plywood	200	Any	200	Any
PPP-B-621	Boxes,Wood, Nailed and Lock-Corner	200	Any	200	Any

Source: https://assist.dla.mil -- Downloaded: 202610-19T09:16Z
Check the source to verify that this is the current version before use.

5.2.5 Additional requirements. In addition to the above, all material used in the preservation, packaging, and packing of the power supply shall meet all the requirements of Specification MIL-P-116.

5.3 Marking

5.3.1 Special markings. None, unless otherwise specified.

5.3.2 Normal markings. In addition to the markings required by contract or order, unit packages, intermediate packages (when used), and shipping containers shall be marked in accordance with the requirements of MIL-STD-129.

6. NOTES

6.1 Intended use. The power supply is intended for use with Test Set Mark 281 Mod 0 for tender and shore base operation.

6.2 Ordering data. Procurement documents should specify the specific title, number, and date of this specification and exceptions to this specification, applicable drawings, and other documents.

6.2.1 The attention of the contracting officer is invited to the Quality Assurance Provisions and options in Specification MIL-P-116 and to paragraph 4.6.6 of this document.

6.3 Criteria for use of proper level of preservation, packaging, and packing shall be as follows:

6.3.1 Level A. This level shall be used for those items which are to be shipped to indeterminate destinations or stored under indeterminate conditions for redistribution anywhere.

6.3.2 Level C. This level shall be used only when it is definitely known that the packaged item is to be shipped to domestic installations for immediate use at the first receiving activity.

NOTICE:

When Government drawings, specifications, or other data are used for any purpose other than in connection with a definitely related Government procurement operation, the United States Government thereby incurs no responsibility nor any obligation whatsoever; and the fact that the Government may have formulated, furnished, or in any way supplied the said drawings, specifications, or other data is not to be regarded by implication or otherwise as in any manner licensing the holder or any other person or corporation, or conveying any rights or permission to manufacture, use, or sell any patented invention that may in any way be related thereto.

Source: https://assist.dla.mil -- Downloaded: 202610-19T09:16Z
Check the source to verify that this is the current version before use.

Fold

DEPARTMENT OF THE NAVY
BUREAU OF NAVAL WEAPONS
WASHINGTON 25, D.C.

OFFICIAL BUSINESS

POSTAGE AND FEES PAID
NAVY DEPARTMENT

Chief, Bureau of Naval Weapons (RREN-5)

Navy Department

Washington 25, D.C.

Fold

Source: https://assist.dla.mil -- Downloaded: 2026-10-19T09:16Z
Check the source to verify that this is the current version before use.

SPECIFICATION ANALYSIS SHEET
NAVWEPS FORM 4121/3 (8-62)

FORM APPROVED
BUDGET BUREAU NO. 48-R300

INSTRUCTIONS

This sheet is to be filled out by Government or contractor personnel involved in the use of this specification in procurement of products for ultimate use by the activity shown on the reverse of this sheet.

This sheet is provided for obtaining information which will aid the activity shown in insuring that through use of this specification suitable products can be procured with a minimum amount of delay and at the least cost.

Comments and the return of this sheet will be appreciated.

Fold on dotted lines on reverse side, staple in corner, and send to the activity shown.

SPECIFICATION *(No. and abbrev. title)*

ORGANIZATION	CITY	STATE

CONTRACT NUMBER	QUANTITY OF ITEMS PROCURED	DOLLAR AMOUNT

MATERIAL PROCURED UNDER A DIRECT GOVERNMENT CONTRACT ☐ OR A SUBCONTRACT ☐

1. HAS ANY PART OF THIS SPECIFICATION CREATED PROBLEMS OR REQUIRED INTERPRETATION IN PROCUREMENT USE?
(If so, give paragraph number and wording, and recommendations for correcting the deficiencies.)

2. COMMENTS ON ANY SPECIFICATION REQUIREMENT CONSIDERED TOO RIGID

3. IS THE SPECIFICATION RESTRICTIVE?
☐ YES ☐ NO IF YES, IN WHAT WAY?

4. REMARKS *(Attach any pertinent data which may be of use in improving this specification. If additional papers are attached, send this form and papers in an envelope. This form is addressed for use in window envelope when appropriate.)*

SUBMITTED BY *(Print name and title)*	DATE

Source: https://assist.dla.mil -- Downloaded: 20240-19109:16Z
Check the source to verify that this is the current version before use.