J-C-138b
AMENDMENT—2
April 14, 1964

SUPERSEDING
Int. Amendment—1
April 5, 1963

FEDERAL SPECIFICATION

# CABLE AND WIRE, POWER, ELECTRICAL; VARNISHED-CLOTH-INSULATED (0 TO 5000 - VOLT SERVICE)

*This amendment, which forms a part of Federal Specification J-C-138b, dated September 20, 1962, was approved by the Commissioner, Federal Supply Service, General Services Administration, for the use of all Federal agencies.*

Page 1, paragraph 1.2.1, line 7 through 18: Delete and substitute:

Class 2—Concentric-lay-stranded conductors of standard flexibility conforming to type C, class B of QQ-W-343.

Class 3—Concentric-lay-stranded conductors where greater flexibility is desired, conforming to type C, class C of QQ-W-343.

Class 4— Rope - lay - stranded conductors where extreme flexibility is desired, conforming to type RC, class G of QQ-W-343.

Page 2, paragraph 2.1, under "Federal Specifications", delete:

J-C-98—Cable and Wire, Insulated; Methods of Sampling and Testing.

Page 2, paragraph 2.1, under "Federal Specifications", add:

QQ-W-343—Wire, Electrical and None-electrical, Copper, (Uninsulated).

Page 2, paragraph 2.2, under "American Standards Association, Inc., Publications", delete in its entirety.

Page 3, paragraph 3.1, line 5, delete "and the applicable American Standards Association, Inc., Standard".

Page 3, paragraph 3.2.1, line 7: After "listing" add "with reexamination".

Page 3, paragraph 3.2.2, line 1: After "listing" add: "with reexamination".

Page 3, section 4.2: Delete in its entirety and substitute:

4.2 **Sampling, nonmilitary.** Unless otherwise specified in the invitation for bids, sampling shall be in accordance with UL-133.

Page 3, paragraph 4.3.1, line 2: Change "4.2.2" to "4.2".

Page 5, paragraph 4.6.1, line 2: Change "4.2.2" to "4.2".

Page 5, paragraph 4.6.2: Delete in its entirety.

Page 5, paragraph 4.6.2.1: Change paragraph number from "4.6.2.1" to "4.6.2".

Page 7, paragraph 6.4, delete in its entirety and substitute:

**6.4 Transportation description.** Transportation description and minimum weights applicable to this commodity are:



Source: https://assist.dla.mil -- Downloaded: 2026-10-26T11:07Z
Check the source to verify that this is the current version before use.

## *CABLE*

*Rail*:

Cable, electric, copper, not otherwise indexed by name.
Carload minimum weight 30,000 pounds.

*Motor*:

Cable, electric, copper, not otherwise indexed.
Truckload minimum weight 30,000 pounds, subject to Rule 115, National Motor Freight Classification.

## *WIRE*

*Rail*:

Wire, covered or insulated, copper.
Carload minimum weight 30,000 pounds.

*Motor*:

Wire, covered or insulated, copper.
Truckload minimum weight 30,000 pounds, subject to Rule 115, National Motor Freight Classification.



Source: https://assist.dla.mil -- Downloaded: 20260-26T11:07Z
Check the source to verify that this is the current version before use.