DATA ITEM DESCRIPTION

Form Approved
OMB No. 0704-0188

2. TITLE	1. IDENTIFICATION NUMBER
Unfired Pressure Vessel Inspection Report	DI-MISC-80381

3. DESCRIPTION/PURPOSE

3.1 The Unfired Pressure Vessel Inspection Report is used to document the inspector's observations and recommendations on the condition, operation, modification and repair of unfired pressure vessels inspected.

3.2 The report is used as a receiving document by the government showing that the inspection has been accomplished.

4 APPROVAL DATE (YYMMDD)	5 OFFICE OF PRIMARY RESPONSIBILITY (OPR)	6a. DTIC REQUIRED	6b. GIDEP REQUIRED
870708	F/AFLC-DEMU		

7 APPLICATION/INTERRELATIONSHIP

7.1 This Data Item Description (DID) contains the format and content preparation instructions for the data product generated by the specific and discrete task requirement as delineated in the contract.

7.2 This DID is applicable to all Air Force contracts for inspection of unfired pressure vessels.

8 APPROVAL LIMITATION	9a APPLICABLE FORMS	9b AMSC NUMBER
		F4146

10 PREPARATION INSTRUCTIONS

10.1 Format. An example of the format for this report is shown in Figure 1.

10.2 Content. The report shall contain the following:

10.2.1 Identification:

a. Air Force Base. The Air Force base where the pressure vessel is located.

b. Location of Receiver (Bldg.). The building number where the receiver or pressure vessel is located.

c. Manufacturer. The manufacturer of the pressure vessel.

d. Manufacturer's Serial number. The manufacturer's serial number on the pressure vessel.

e. National Board Number. The National Board number on the pressure vessel.

f. Year Built. The year the pressure vessel was built.

g. Capacity (cu. ft. and gal). The capacity of the pressure vessel in cubic feet or gallons.

h. Design Working Pressure (maximum allowable working pressure) (PSIG). Pressure in pounds per square inch gage.

10.2.2 Safety Valve Capacity.

a. CFM Air. The capacity of the valve in cubic feet per minute of air.

b. LB/HR Steam. The capacity of the valve in pounds per hour of steam.

10.2.3 Original metal thickness.

a. Shell (inches). The shell thickness measured in inches.

b. Heads (inches). The inspection head thickness in inches.

10.2.4 Efficiency of longitudinal seam (percent).

(Continued on Page 2)

11 DISTRIBUTION STATEMENT

DISTRIBUTION STATEMENT A. Approved for public release; distribution is unlimited.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T10:36Z
Check the source to verify that this is the current version before use.

10. PREPARATION INSTRUCTIONS (Continued)

10.2.5 Inspection Data.
a. Date This Inspection. The date of the inspection.
b. Due date next inspection.
c. Minimum metal thickness this inspection and location on receiver. The minimum measured metal thickness of the shell and the location of the measurement.
d. Maximum allowable working pressure this inspection on receiver.
e. Safety valve inspected (yes/no).
f. Hydrostatic Test, PSIG. The hydrostatic test pressure in pounds per square inch gage, if performed on this inspection.
10.2.7 Inspectors signature.
10.2.8 BCE Comments. Base Civil Engineer's comments.
10.2.9 BCE Signature. Base Civil Engineer's signature or signature of authorized representative.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T10:36Z
Check the source to verify that this is the current version before use.

10. PREPARATION INSTRUCTIONS (Continued)

UNFIRED PRESSURE VESSEL INSPECTION REPORT

1. AIR FORCE BASE			2. LOCATION OF RECEIVER *(Bldg)*		
3. MANUFACTURER			4. MANUFACTURER'S SERIAL NUMBER		
5. NATIONAL BOARD NUMBER			6. YEAR BUILT	7. CAPACITY A. CU FT	B. GAL
8. DESIGN WORKING PRESSURE *(Maximum allowable working pressure)(PSIG)*	9. SAFETY VALVE SETTING *(PSIG)*		10. SAFETY VALVE CAPACITY A. CFM AIR	B. LB/HR STEAM	
11. ORIGINAL METAL THICKNESS A. SHELL *(Inches)*	B. HEADS *(Inches)*		12. EFFICIENCY OF LONGITUDINAL SEAM *(Percent)*		

DATE THIS INSPECTION	DUE DATE NEXT INSPECTION	MINIMUM METAL THICKNESS THIS INSPECTION AND LOCATION ON RECEIVER	MAXIMUM ALLOWABLE WORKING PRESSURE THIS INSPECTION ON RECEIVER	SAFETY VALVE INSPECTED YES	SAFETY VALVE INSPECTED NO	HYDRO-STATIC TEST PSIG

INSPECTORS REMARKS AND RECOMMENDATIONS

INSPECTORS SIGNATURE

BCE COMMENTS

BCE SIGNATURE

FIGURE 1. Sample Unfired Pressure Vessel Inspection Report

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T10:36Z
Check the source to verify that this is the current version before use.