A-A-996A
August 6, 1985
SUPERSEDING
A-A-996
March 7, 1983

# COMMERCIAL ITEM DESCRIPTION

## PIPE, PLASTIC

The General Services Administration has authorized the use of this commercial item description in preference to Type I of Interim Federal Specification L-P-00315.

This description covers black polyethylene plastic pipe used to carry potable water, cold water only, conforming to the following classes and grades.

Type - Black Polyethylene Pipe, Cold Water Only

Class B - PE 2306

Grade 1 - SIDR 11.5
Grade 2 - SIDR 15

Class C - PE 3408

Grade 2 - SIDR 15
Grade 3 - SIDR 19

Standard themoplastic pipe dimension ratio (SIDR). Refers to the ratio of pipe diameter to wall thickness as defined in ASTM D 2239.

Salient characteristics.

Sizes. Pipe furnished under this description shall be of the following nominal pipe sizes as specified: 1/2, 3/4, 1, 1-1/4, 1-1/2, and 2 inches.

Lengths. Pipe shall be furnished in 100-, 300-, or 500-foot coils as specified.

FSC 4710

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T08:11Z
Check the source to verify that this is the current version before use.

Pressure rating.

Class B, Grade 1 - 100 psi
Class B, Grade 2 - 80 psi
Class C, Grade 2 - 100 psi
Class C, Grade 3 - 80 psi

Conformance. Pipe shall conform to the requirements of ASTM D 2239 and National Sanitation Foundation (NSF) Standard No. 14.

Workmanship. Pipe shall be free of cracks, holes, foreign inclusions and any defects which may impair durability, appearance, and serviceability.

Responsibility for inspection. Unless otherwise specified in the contract or purchase order, the contractor is responsible for the performance of all inspection requirements as specified herein. Except as otherwise specified in the contract or order, the contractor may use his own or any other facilities suitable for the performance of the inspection requirements specified herein, unless disapproved by the Government. The Government reserves the right to perform any of the inspections set forth in the specification where such inspections are deemed necessary to assure that supplies and services conform to prescribed requirements.

Sampling and inspection. Inspection levels and acceptable quality levels (AQL) shall be in accordance with MIL-STD-105.

Lot formation. For purposes of inspection sampling, a lot shall consist of all pipe of the same grade and class offered for acceptance at one time.

Dimensional and visual examination of end item. Pipe and tubing shall be examined for the characteristics listed in Table II. Examination shall be in accordance with level S-3, using an AQL of 2.5 percent defective for major defects and 6.5 defective for total defects. Dimensions of PE pipe shall be measured in accordance with ASTM D 2239.



Source: https://assist.dla.mil -- Downloaded: 2026-10-26T08:11Z
Check the source to verify that this is the current version before use.

TABLE II Classification of defects, end item

| Defects | Major | Minor |
|---|---|---|
| Type, class, grade, form, or size not as specified | X | |
| Cracks or holes | X | |
| Foreign inclusions | X | |
| Dimension not within tolerance | X | |
| Identification marking omitted, incorrect, illegible | | X |
| Damage or defects affecting function or serviceability | X | |
| Damage or defects not affecting function or servicability | | X |

Sampling for tests. A sufficient number of specimens shall be randomly selected from each inspection lot to perform each test specified. See test methods paragraph below to determine which tests are applicable.

Test methods.

1. Pipe shall be tested in accordance with ASTM D 2239.

2. Sustained pressure and environmental cracking tests shall be conducted in accordance with ASTM D 2239 only when NSF label or listing has been withheld from the pipe submitted for acceptance by the Government.

The issues of ASTM D 2239 and NSF 14 in effect on the date of the solicitation shall be used to determine compliance with these requirements.

Preservation, packaging, packing, labeling, and marking. The preservation, packaging, packing, labeling, and marking shall be as specified in the contract or order.

Examination of preparation for delivery requirements. An examination shall be made to determine that the packaging, packing, and marking comply with the requirements specified. Defects shall be scored in accordance with table III. For examination of interior packaging, the sample unit shall be one shipping container fully prepared for delivery, selected at random just prior to the closing operations. Defects of closure listed shall be examined on shipping containers fully prepared for delivery. The inspection level shall be S-2 with an AQL of 4.0 percent defective.



Source: https://assist.dla.mil -- Downloaded: 2026-10-26T08:11Z
Check the source to verify that this is the current version before use.

TABLE III Classification of preparation for delivery defects

| Examine | Defects |
|---|---|
| Marking (exterior and interior) | Omitted, incorrect, illegible, improper size, location, sequence, or method of application. |
| Materials | Any component missing or damaged. |
| Workmanship | Inadequate application of components such as incomplete closure of container flaps, loose strapping, inadequate stapling. Distortion of container. |

Regulatory requirements. In accordance with section 23.403 of the Federal Acquisition Regulations, the Government's policy is to acquire items composed of the highest percentage of recovered materials practicable, consistent with maintaining a satisfactory level of competition without adversely affecting performance requirements or exposing suppliers' employees to undue hazards from the recovered materials.

Notes: Purchasers should select the options allowed in this document and should specify type, class, grade, size, and length of pipe required in the contract or purchase ordering document. Class B pipe is commonly connected by means of insert fittings while class C pipe because it is made from higher density material is most satisfactorily connected by fusion joining in accordance with ASTM method D 2657.

Copies of Military Standard MIL-STD-105 required by suppliers in connection with specific acquisition functions should be obtained from the contracting activity or as directed by the contracting officer.

NSF Standard No. 14 is available from the National Sanitation Foundation, NSF Building, Ann Arbor, Michigan 48105.

ASTM D 2239 and ASTM D 2657 are available from the American Society for Testing and Materials, 1916 Race Street, Philadelphia, Pennsylvania 19103.



Source: https://assist.dla.mil -- Downloaded: 2026-10-26T08:11Z
Check the source to verify that this is the current version before use.

The commercial item description certification clause is not required when this commercial item description is used for procurement.

MILITARY INTERESTS:

Custodian

Air Force - 99

Review activity

Air Force - 82

PREPARING ACTIVITY

GSA - FSS



Source: https://assist.dla.mil -- Downloaded: 2026-10-26T08:11Z
Check the source to verify that this is the current version before use.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T08:11Z
Check the source to verify that this is the current version before use.