INTERIM AMENDMENT-1
TO
FEDERAL SPECIFICATION

BUSWAY SYSTEM, POWER, ELECTRICAL, 600 VOLTS

This Interim Amendment was developed by the General Services Administration, Federal Supply Service, Standardization Division, Washington 25, D.C., based upon currently available technical information. It is recommended that Federal agencies use it in procurement and forward recommendations for changes to the preparing activity at the address shown above.

The General Services Administration has authorized Federal agencies to use this Interim Amendment as a valid part of Federal Specification W-B-811b, dated June 13, 1962.

Page 1, paragraph 1.2.1, delete:

Styles:
Style A - With ventilated enclosures.
Style B - With unventilated enclosures.

Page 2, after paragraph 3.3.3, add:

3.4 Enclosure. The enclosure shall protect the busway from mechanical damage. Unless otherwise specified (see 6.1), enclosures may be ventilated or unventilated at the option of the manufacturer.

Page 3, paragraph 6.1, add at end of paragraph:

(f) Ventilated or unventilated enclosures, if either is specifically required for the application being made (see 3.4).

Page 4, paragraph 6.3, Transportation description:

Change paragraph number from "6.3" to "6.4".

FSC 5975

Source: https://assist.dla.mil -- Downloaded: 202640-26T11:33Z
Check the source to verify that this is the current version before use.

Page 4, after paragraph 6.2, add:

6.3 Building designers and engineers should give adequate consideration to the relative importance of the type of busway enclosure included in their plans, particularly where local building codes are involved. Where there is no definite need for specifying ventilated enclosures over unventilated enclosures, or vice versa, the contractor should be permitted to supply either.

MILITARY INTEREST:

Army = E

Navy - Y

Air Force- Rome Air Material Area

Source: https://assist.dla.mil -- Downloaded: 202640-26T11:33Z
Check the source to verify that this is the current version before use.