W-T-631c
AMENDMENT—2
October 7, 1966

SUPERSEDING
Int. Amendment—1
October 28, 1964

FEDERAL SPECIFICATION

TRANSFORMER, POWER, DISTRIBUTION

This amendment, which forms a part of Federal Specification W-T-631c, dated June 4, 1964, was approved by the Commissioner, Federal Supply Service, General Services Administration, for the use of all Federal agencies.

PAGE 2

Paragraph 3.1: Delete in its entirety and substitute:

3.1 **General.** Except as otherwise provided herein, transformers furnished under this specification shall conform to the applicable requirements of ASA C57.12.00 and C57.12.20.

Paragraph 3.2: Delete in its entirety and substitute:

3.2 **Continuous rating temperature rise.**

3.2.1 *Limits of observable temperature rise.* The temperature rise above the ambient temperature of overhead distribution transformers or parts thereof, when tested in accordance with their ratings, shall not exceed 65°C.

3.2.2 *Limits of hottest-spot temperature rise.* Overhead distribution transformers shall be so designed that the hottest-spot conductor temperature rise above the ambient temperature shall not exceed 80°C.

PAGE 3

Paragraph 3.6: Delete in its entirety and substitute:

3.6 Insulation materials.

3.6.1 *Solid.* If class A materials are utilized in the insulation system of the transformers, these materials shall be thermally stabilized, exhibiting, by experience or accepted tests, a comparable thermal life at 120°C. to that of unstabilized class A materials at 105°C.

3.6.2 *Liquid.* The transformers shall be delivered with the proper quantity of insulating liquid contained therein.

Paragraphs 3.6.1 and 3.6.2: Renumber to "3.6.2.1" and "3.6.2.2", respectively.

Paragraph 3.7.1, line 3: Change "in" to "and".

PAGE 4

After paragraph 4.3.3, add the following:

4.3.3.1 *Reference temperature for losses, impedance, and efficiencies.* The reference temperature to which losses, impedances, and efficiencies are corrected shall be 85°C.

4.3.3.2 *Determination of transformer regulation.* The regulation of a transformer shall be determined by calculation based on the measured values of impedance volts and impedance watts, corrected to a temperature of 85°C.

PAGE 5

Paragraph 6.1, line 19: Change "(3.6.1)" to "(3.6.2.1)."

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T11:33Z
Check the source to verify that this is the current version before use.

PAGE 6

Delete in its entirety and substitute:

MILITARY INTERESTS:

CUSTODIANS:
Army—MO (ERDL)
Navy—YD
Air Force—85

Review Interest:
Army—MO
Navy—YD
Air Force—85

User Interest:
Army—EL, MI, CE
Navy—MC
Air Force—11

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T11:33Z
Check the source to verify that this is the current version before use.