A-A-2297
April 9, 1985

COMMERCIAL ITEM DESCRIPTION

BALL VALVE
(DROP-OUT TYPE: LINE; INLINE; SUCTION; DISCHARGE)

This description covers full-flow, drop-out ball valves for fire fighting purposes and shall be furnished in the following types, classes, and sizes, as specified.

Type I - Brass, cast
Type II - Aluminum, hardcoated

Class A - Line valve. For use on pumpers as discharge valves or in hose lines for flow control.
Class B - Inline valve. For use in the piped lines of a pumper on either the suction or discharge side of the pump.
Class C - Suction valve. For use on the inlet side of the pump.
Class D - Discharge valve. For use on the discharge side of the pump.

Size	Inside Diameter (inches)
1	1
2	1-1/2
3	2
4	2-1/2

Salient characteristics.

Valves shall hold vacuum or pressure in either direction.
Quarter-turn handle shall be supplied pre-set so that the "Closed" position is perpendicular to the waterflow; the handle shall swing parallel to the waterflow for "Open" but shall be capable of being set for any operating position at time of installation.
Valve body and seat assembly shall be quickly and easily removed from the line without disturbing the rest of the system.
Drain holes shall be provided.
Class A valves shall be provided with a handle for manual operation. Classes B, C, and D shall be provided with handles for manual operation. (They are also available for remote operation, if specified).
Line valves (Class A) shall be furnished with a rigid male pipe thread (NPT) outlet adapter. Suction valves (Class C) shall be furnished with a rigid female pipe thread outlet adapter. Both classes shall be provided with a swivel female inlet adapter using the following thread series: NH or NPSH, as specified, for Size 1; NH for Sizes 2 and 4; and NPSH for Size 3.
Inline valves (Class B) shall be furnished with rigid female pipe thread (NPT) adapters on both the inlet and outlet sides.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T08:2+2
Check the source to verify that this is the current version before use.

Discharge valves (Class D) shall be furnished with a rigid female pipe thread (NPT) inlet adapter and rigid male thread outlet adapter with thread series NH or NPSH for Size 1, NH for Sizes 2 and 4, and NPSH for Size 3.

Conformance testing.

Dry torque test. The valve shall be dry and without hydrostatic pressure. A torque shall be installed in place of the valve handle, and the valve turned to its open and closed positions. The peak torque shall not exceed 150 pound-inches.

Hydrostatic pressure torque test. The valve shall be connected to a hydrostatic pressure source and 400 psig shall be applied. The valve discharge ends shall be open. The torque wrench shall be turned to its open and closed positions. The peak torque shall not exceed 200 pound-inches.

Working pressure test. After the hydrostatic pressure torque test the pressure shall be increased to 500 psig for one minute. The valve shall be examined. Leaks, distortion, mechanical damage, and failures are not permissable.

Workmanship. Cast parts shall be fine-grained, free from blowholes, porosity, hard spots, shrinkage, cracks and other defects. Exterior surfaces shall be smooth. Excessive material on edges shall not be allowed. Valve shall be free of any defects which may affect the durability. appearance, or serviceability.

Regulatory requirements. The offeror/contractor is encouraged to use recovered materials in accordance with Public Law 94-580 to the maximum extent practicable.

Preservation, packaging, packing, labeling, and marking. The preservation, packaging, packing, labeling, and marking, shall be as specified in the contract or order.

Note. Purchaser shall specify the following: Type; class; size; type of handle for classes B, C, and D if other than manual; thread series for classes A, C, and D, Size 1.

When this commercial item description is used for procurement, the commercial item certification clause must appear in the solicitation.

Review Activity

Army - ME

PREPARING ACTIVITY:

GSA - FSS

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T08:21Z
Check the source to verify that this is the current version before use.