A-A-591
November 14, 1979

COMMERCIAL ITEM DESCRIPTION

DETECTOR, SMOKE, ALARM, RESIDENTIAL, AC POWERED, PHOTOELECTRIC TYPE

The General Services Administration has authorized the use of this commercial item description.

Salient characteristics:

Application - Residential.

Mode of operation - Sounds 85 dBA alarm continuously when air particulate density exceeds critical levels.

Circuitry - Solid state throughout.

Environmental degradation tolerance - Automatically adjusts sensitivity to compensate for dust film, temperature, or age.

Power - 120 VAC.

Line frequency - 60 Hz.

Validation - Test capability for smoke sensing and alarm. Automatic reset and power-on indicating light.

Ceiling and wall mounting (hardware included).

Safety - Complies with UL Standard 217.

Smoke detector types

Model	Type	Power connection
A	Built in	Pigtails
B	Plug in	Line cord

Certification. The contractor shall certify that the product offered meets the salient characteristics of this description and that the product conforms to the producer's own drawings, specifications, standards, and quality assurance practices and is the same product offered for sale in the commercial marketplace. The Government reserves the right to require proof of such conformance prior to first delivery and thereafter as may be otherwise provided for under the provisions of the contract.

Recovered materials. The manufacturer shall utilize recovered materials to the maximum extent practicable.

Packaging, packing, and marking. The smoke detector/alarm shall be packaged in accordance with normal commercial practice and packed in fiberboard boxes that will assure acceptance by common carrier and provide product protection against loss and damage during multiple shipment, handling, and storage. The shipping containers shall be in compliance with the National Motor Freight Classification and Uniform Freight Classification. The marking shall be as specified in the contract or order.

UL Standard 217, Smoke Detector, Single and Multiple Station, may be obtained from Underwriters' Laboratories (UL), Inc., 1285 Walt Whitman Road, Melville, Long Island, NY 11747.

FSC 6350

GSA DC-01001725

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T08:09Z
Check the source to verify that this is the current version before use.