A-A-733
February 24, 1981

COMMERCIAL ITEM DESCRIPTION

GENERATOR SET, GASOLINE ENGINE (PORTABLE, 120/240 V, 60 HERTZ, SINGLE PHASE)

The General Services Administration has authorized the use this commercial item description.

This commercial item description covers gasoline or gas driven, portable, air cooled, electric generator sets with an electrical ratings of 120/240 volts, 60 Hertz.

Salient characteristics:

Four cycle engine with air cleaner.
Fuel tank.
Recoil starter.
Five percent speed regulation at rated load.
Manual start.
Manual choke.
Fuel pump.
Muffler.
Stop switch.
Outlet box with duplex receptacle outlets with a NEMA configuration of 5-15R.
Steel carrying frame.
Vibration isolaters between generator set and frame.
Temperature rise for alternator at rated load shall be in accordance with NEMA MG-1-22.40.
Insulation system shall be in accordance with class B of NEMA MG-1-1.65.
The electrical ratings shall be as follows:

Electrical ratings

Type	Watts	Amperes
A	2,500	20.8/10.4
B	4,000	34.0/17.0
C	5,000	42.0/21.0

The issue of NEMA MG-1 in effect on the date of the solicitation shall be used to determine compliance with stated requirements.

Certification. The contractor shall certify that the product offered meets the salient characteristics of this description, and at the product conforms to the producer's own drawings, specifications, standards and quality assurance practices and is the same product sold in the commercial marketplace. The Government reserves the right to require proof of such conformance prior to first delivery and thereafter as may be otherwise provided for under the provisions of the contract.

Regulatory Requirements. The manufacturer shall utilize recovered materials to the maximum extent practicable.

Packaging, Packing, and Marking. The items shall be packaged in accordance with normal commercial practice and packed to assure acceptance by common carrier and provide product protection against loss and damage during multiple shipments, handling, and storage. The shipping container shall be in compliance with National Motor Freight Classification and Uniform Freight Classification. Shipping containers shall be marked as specified in the contract or order.

Copies of NEMA MG-1 are available from the National Electrical Manufacturers Association, 2101 L. Street, NW, Washington, DC 20037.

FSC 6115

GSA DC-01102527

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T08:10Z
Check the source to verify that this is the current version before use.