A-A-735
March 5, 1980

COMMERCIAL ITEM DESCRIPTION

ADAPTER, FLUORESCENT, SCREW-IN, 20-WATT

The General Services Administration has authorized the use of this commercial item description.

This commercial item description covers 20-watt fluorescent screw-in adapters for direct replacement of 60-watt, 120-volt, 60-hertz incandescent lamps.

Salient characteristics:

Medium screw Edison lamp base.
Adapter shall be mounted base up or base down.
Ballasts shall meet the requirements of UL Standard No. 935, be CBM certified, high power factor, and class P rated.
Ballasts shall not contain polychlorinated biphenyl insulating fluid and shall be marked in a manner to indicate same.
One 6-1/2-inch, four-pin FC6T9/CW fluorescent lamp shall be furnished with the adapter.
The adapter shall allow quick and easy replacement of the fluorescent lamps without the use of tools.
Adapters shall have clip tube suspension or equal for the fluorescent lamp.
An attachment for a white lamp shield diffuser shall be provided.
The lamp shield, when specified, shall be shatterproof, nonyellowing acrylic plastic.
The diffuser shall shield bare fluorescent lamps from direct view from nadir to 90° above nadir, when the adapter is ceiling mounted.
The diffuser shall be removable without the use of tools.
All components shall be combined into an integral unit.
The adapter shall be in accordance with UL Standard No. 496, Section 10A.

Certification. The contractor shall certify that the product offered meets the salient characteristics of this description and that the product conforms to the producer's own drawings, specifications, standards, and quality assurance practices and is the same product offered for sale in the commercial marketplace. The Government reserves the right to require proof of such conformance prior to first delivery and thereafter as may be otherwise provided for under the provisions of the contract.

Recovered materials. The manufacturer shall utilize recovered materials to the maximum extent practicable.

Packaging, packing, and marking. The adapter shall be packaged in accordance with normal commercial practice and packed in fiberboard boxes that will assure acceptance by common carrier and provide product protection against loss and damage during multiple shipments, handling, and storage. The shipping container shall in compliance with the National Motor Freight Classification and Uniform Freight Classification. Marking shall be as specified in contract or order.

UL Standard Nos. 496 and 935 are available from the Underwriters' Laboratories, Inc., 1285 Walt Whitman Road, Melville, Long Island, NY 11747.

Procedural Guide for Certified Ballast Manufacturers (CBM) is available from Certified Ballast Manufacturers, 2120 Keith Building, Cleveland, OH 44115.

FSC 6250

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T08:10Z
Check the source to verify that this is the current version before use.