MIL-R-4582B
22 October 1964
Superseding
MIL-R-4582A(USAF)
12 October 1956

MILITARY SPECIFICATION

REFRIGERATOR, ELECTRIC, PORTABLE, RIVET STORAGE

This specification is mandatory for use by all Departments and Agencies of the Department of Defense.

1. SCOPE

1.1 This specification covers one type of portable, caster-mounted, electric refrigerator for storage of aluminum alloy rivets.

2. APPLICABLE DOCUMENTS

2.1 The following documents of the issue in effect on date of invitation for bids or request for a proposal, form a part of the specification to the extent specified herein.

SPECIFICATIONS

Federal

CC-M-636	Motors, Fractional Horsepower, (Alternating current)

Military

MIL-V-173	Varnish, Moisture and Fungus Resistant For the Treatment of Communications Electronic and Associated Equipment
MIL-C-5756	Cable and Wire, Power, Electric Portable
MIL-P-12323	Preparation of Refrigerators for Shipment And Storage
MIL-D-70327	Drawings, Engineering and Associated Lists

STANDARDS

Federal

FED-STD-595	Colors

Military

MIL-STD-105	Sampling Procedures and Tables for Inspection by Attributes
MIL-STD-129	Marking for Shipment and Storage

FSC 4110

Source: https://assist.dla.mil -- Downloaded: 202610-17T03:39Z
Check the source to verify that this is the current version before use.

MIL-STD-130	Identification of Marking of US Military Property
MIL-STD-143	Specifications and Standards, Order of Precedence for the Selection of
MIL-STD-808	Finishes, Protective and Codes for Finishing Schemes for Ground and Ground Support Equipment
MIL-STD-810	Environmental Test Methods for Aerospace And Ground Equipment
MIL-STD-831	Test Reports, Preparation of
MS24663	Connector, Plug, Electrical, with Spring Loaded Pivoted Grounding Blade, Polarized
MS33586	Metals, Definition of Dissimilar

(Copies of specifications, standards, drawings, and publications required by suppliers in connection with specific procurement functions should be obtained from the procuring activity or as directed by the contracting officer.)

2.2 Other publications. The following documents form a part of this specification to the extent specified herein. Unless otherwise indicated, the issue in effect on date of invitation for bids or request for proposal shall apply.

National Bureau of Standards Publications

Handbook H28	Screw-Thread Standards for Federal Services
Handbook H30	National Electrical Safety Code
CS131-46	Industrial Mineral Wool Products, All Types - Testing and Reporting

(Application for copies should be addressed to the Superintendent of Documents, Government Printing Office, Washington, D.C. 20325.)

National Machine Tool Builders Association

Electrical Standards

(Application for copies should be addressed to the National Machine Tool Builders Association, 2139 Wisconsin Ave., N.W., Washington, D.C. 20307.)

3. REQUIREMENTS

3.1 Preproduction testing. This specification makes provisions for preproduction testing.

3.1.1 Preproduction sample. When specified the supplier shall furnish a preproduction sample for inspection and tests to determine

Source: https://assist.dla.mil -- Downloaded: 2026-10-17T03:39Z
Check the source to verify that this is the current version before use.

conformance with this document (see 6.2). Approval of the preproduction sample, by the activity concerned, shall not relieve the supplier of his obligation to supply equipment conforming to this document. The preproduction sample shall be identical with the proposed production items and shall be made and assembled by the same methods that are to be used in production of the items to fulfill the terms of the contract. No change or deviation from the preproduction sample will be acceptable without prior written approval from the contracting officer.

3.2 Components. The rivet storage refrigerator shall consist of a cabinet, storage compartment, refrigeration system, and necessary accessories.

3.3 Selection of specifications and standards. Specifications and standards for necessary commodities and services not specified herein shall be selected in accordance with MIL-STD-143 except as provided in 3.3.1 and 3.3.2.

3.3.1 Standard parts. AN or MS standard parts shall be used where they are suitable for the purpose and shall be identified by their part numbers. Commercial utility parts such as screws, bolts, nuts, cotter pins, hose fittings, etc., may be used, provided they have suitable properties and are interchangeable with AN, MS, or MIL standard parts without alterations.

3.3.2 Commercial parts. Commercial parts may be used provided they conform to the requirements of this document in applications for which no suitable corresponding AN, MS or MIL type is in effect on date of Invitation for Bids.

3.4 Materials. Materials shall be as specified herein. Materials not specifically designated shall be of commercial quality.

3.4.1 Protective treatment. Construction materials subject to deterioration when exposed to climatic and environmental conditions likely to occur during service usage of the refrigerator shall be protected against such deterioration in a manner that will in no way prevent compliance with the performance requirements of this document. The use of any protective coating that will crack, chip or scale with age or extremes of climatic or environmental conditions shall be avoided.

3.4.2 Metals. Metals shall be of the corrosion resistant type or shall be protected to resist corrosion during normal service life.

3.4.3 Dissimilar metals. Contact between dissimilar metals shall be avoided wherever possible. Wherever such contacts are unavoidable, they shall be insulated in a manner approved by the procuring activity. Dissimilar metals are defined in MS33586.

Source: https://assist.dla.mil -- Downloaded: 2026-10-17T03:39Z
Check the source to verify that this is the current version before use.

3.5 Design and construction. The refrigerator shall be complete, so that when installed, it can be used for the operations specified herein. The refrigerator shall be designed and constructed so that no parts will work loose in service. It shall be built to withstand the strains, jars, vibrations, and other conditions incident to shipping, storage, installation, and service. (see 4.4)

3.5.1 Castings and forgings. All castings shall be free from blowholes, porosity, hardspots, shrinkage defects, cracks, or other defects. Forgings shall be free from scale, inclusions, cold shuts, mismatching and other defects that may affect the structural strength of the forgings involved. Strength and other essential physical and chemical properties of the castings and forgings shall meet the performance requirements specified herein.

3.5.2 Welding, brazing and soldering. Welding, brazing, and soldering shall be performed in accordance with commercial practice. In no event shall such processes, including peening or plugging, be used on castings or forgings for reclaiming any parts of the refrigerator without authorization of the procuring activity.

3.5.3 Fastening devices. All screws, pins, bolts, and similar parts shall be installed with means for preventing loss of tightness and adjustment. All such parts when subject to removal or adjustment shall not be swaged, peened, staked, or otherwise permanently deformed.

3.5.4 Electrical components. The rivet storage refrigerator shall be designed for operation on 115 volts, nominal, 60 cps, single phase, alternating current electrical system. Electrical components of the refrigerator; including starters, relays, switches, wiring and their enclosures; shall conform to and shall be located in accordance with the National Machine Tool Builders Association Electrical Standards except as specified herein. No component part shall be used in any application where requirements exceed the manufacturer's rating for the part.

3.5.4.1 Motors. Motors, other than hermetically sealed compressor motors, shall conform to CC-M-636 and shall start and operate without exceeding a maximum temperature rise of 55° Centigrade. All motors and other electrical equipment shall conform to the standards of the National Bureau of Standards Handbook H30.

3.5.4.2 Electrical connections. Electrical connections shall be mechanically secured and soldered or brazed, except connections on screw type terminals which shall be mechanically secured. Resin base fluxes shall be used in all soldering operations.

Source: https://assist.dla.mil -- Downloaded: 202610-17T03:39Z
Check the source to verify that this is the current version before use.

3.5.5 Fungus treatment. Unless otherwise specified, (see 6.2) circuit elements such as cable and wire, (except plastic, rubber, and bitumen coated) shall be coated with a fungicidal varnish conforming to Specification MIL-V-173. Fungus treatment of the motor windings shall be in accordance with Federal Specification CC-M-636. Switches, fuses and contacts shall not be fungus treated.

3.5.6 Threads. All threaded parts shall comply with National Bureau of Standards Handbook H28.

3.5.7 Instruments and controls. All instruments and gages supplied on the refrigerator shall correspond in appearance. All instruments, switches, controls, and outlets shall be plainly identified by permanent plates.

3.5.8 Lubrication. All bearings (except sealed-for-life type) and other working parts shall be plainly identified by permanent plates.

3.5.9 Maintenance and servicing. The design and construction of the refrigerator shall be such that adjustment, repair and overhaul are held to a minimum and when required, may be easily accomplished with a minimum of special tools.

3.6 Details of Components.

3.6.1 Cabinet. The cabinet shall contain the storage compartment, refrigeration system and necessary accessories.

3.6.1.1 Exterior construction. The exterior construction of the cabinet shall be of non-ferrous sheet metal of not less than .0625 inch. Wood or wood fiber materials shall not be used in the construction of the cabinet or its reinforcement members.

3.6.1.2 Casters. The cabinet shall be provided with four anti-friction bearing, swivel type casters rated at not less than 125 pounds per caster.

3.6.1.3 Handles. A bar type handle, the full width of the refrigerator, shall be provided on each end of the refrigerator for pushing between locations. The handles shall be constructed of corrosion resistant material or treated to prevent corrosion.

3.6.1.4 Foot treadle. A foot treadle shall be provided for raising the lid.

3.6.2 Storage compartment. The storage compartment of the refrigerator shall consist of an insulated tank with a hinged

Source: https://assist.dla.mil -- Downloaded: 202610-17T03:39Z
Check the source to verify that this is the current version before use.

insulated lid and shall be capable of holding canister rack or racks with 50 canisters.

3.6.2.1 Tank. The tank shall be constructed of non-ferrous sheet metal not less than .0625 inch. All seams, corners and joints shall be welded and ground to a smooth finish. The tank shall be vapor tight and shall be adequately reinforced. No rivets shall be used in the tank construction or reinforcement. The tank shall be plated or otherwise treated to prevent corrosion. Wood or wood fiber materials shall not be used in the construction of the tank or its reinforcement members.

3.6.2.2 Insulated lid. An insulated lid shall be provided to close the top of the tank. The exterior construction shall conform to the material requirements of 3.6.1.1. The interior shall be constructed with the same material required in 3.6.2.1. A breaker strip of insulating material shall be provided at the lid opening. A means to hold the lid in the open position shall be provided.

3.6.2.3 Hinges. Two hinges or a single piano type hinge shall be provided for hinging the insulated lid at the rear of the cabinet. The hinge(s) shall be corrosion resistant material or treated to prevent corrosion.

3.6.2.4 Insulation. The outside of the tank and the insulated lid shall be insulated with material in accordance with section 1(a) of the National Bureau of Standards Commercial Standard CS 131-46. The thermal conductivity shall not be greater than 0.25 BTU per hour per square foot per inch thickness per degree Fahrenheit temperature difference.

3.6.3 Refrigeration System. The refrigeration system shall consist of a compressor, condenser, receiver, expansion coil, and controls, all mounted on a common base. The refrigeration system shall be capable of reducing the temperature of 50 pounds of aluminum rivets from 100 degrees Fahrenheit to minus 40 degrees Fahrenheit in not more than three hours while the refrigerator is operating in an ambient temperature of 110 degrees Fahrenheit plus or minus 2 degrees F. (see 4.4.3.1). The refrigeration system shall maintain the storage compartment at a temperature of a minus 40 degrees Fahrenheit for a period of 24 hours with a maximum running time of 16 hours while operating in an ambient temperature of 110 degrees Fahrenheit (see 4.4.3.2).

3.6.3.1 Compressor. The compressor and motor shall be self-contained, hermetic, thermally or mechanically sealed, service type of standard commercial design with a minimum rating of 600 BTU per hour at minus 40 degrees Fahrenheit (in an ambient temperature of plus 110 degrees F.) The compressor shall be air cooled.

Source: https://assist.dla.mil -- Downloaded: 2026-10-17T03:39Z
Check the source to verify that this is the current version before use.

All moving parts shall be automatically lubricated and means provided for returning the lubricant from the suction lines to the crankcase.

3.6.3.2 Condenser. The condenser shall be air cooled and shall be of adequate size to condense the full output of the compressor when the ambient air temperature is 110°F. Means shall be provided to circulate an adequate supply of air through the condenser.

3.6.3.3 Receiver. A receiver shall be provided and shall hold the complete refrigerant charge of the system in 80 percent of its volumetric capacity.

3.6.3.4 Expansion coil. The expansion coil shall be firmly supported outside the tank and shall remove heat to meet the requirements specified in 3.6.3. Embossed steel plate coils may be welded to the liner in such a way that the liner becomes one surface of the refrigerant passage.

3.6.3.5 Expansion valve. A thermostatic type of expansion valve, float valve, or other equally suitable means to properly serve the expansion coil, shall be provided.

3.6.3.6 Temperature control. The automatic operation of the compressor shall be controlled by a thermostat in the storage compartment or by a suction pressure controller in the suction line.

3.6.3.7 Refrigerant. The refrigerant shall be monochlorodifluoromethane. (Freon 22)

3.6.4 Accessories

3.6.4.1 Canisters. Each rivet storage refrigerator shall be supplied with 50 canisters. The canisters shall be fabricated of not less than .025 inch aluminum. The capacity of each canister shall be not less than 19 cubic inches. The canisters shall be formed so that individual canisters may be removed. The bottom of each canister shall have perforations for moisture drainage. Means shall be provided for tabulating information concerning the rivets in the canisters.

3.6.4.2 Canister rack. A rack(s) shall be provided to support the 50 canisters in their proper locations. The rack shall be removable and designed to prevent the canisters from freezing tight in the rack.

Source: https://assist.dla.mil -- Downloaded: 2026-10-17T03:39Z
Check the source to verify that this is the current version before use.

3.6.4.3 Thermometer. A thermometer shall be provided and installed on the front of the refrigerator. The thermometer shall indicate the temperature inside the storage compartment.

3.6.5 Power cable and plug connector. A three conductor power cable with a heavy duty attachment plug shall be provided. The cable shall conform to MIL-C-5756 and shall be not less than 15 feet long. One conductor shall be grounded to the metal frame of the unit. The free end of the cable shall be provided with a plug connector conforming to MS24663.

3.6.6 Safety devices. Safety devices necessary to provide safe and automatic operation shall be provided.

3.7 Interchangeability. All parts having the same manufacturer's part number shall be functionally and dimensionally interchangeable. The item identification and part number requirements of MIL-D-70327 shall govern the manufacturer's part numbers and changes thereto.

3.8 Dimensions. The overall height of the refrigerator shall not exceed 38 inches including casters. The width shall not exceed 36 inches. The depth (front to back) shall not exceed 24 inches.

3.9 Finish. The refrigerator shall be finished and painted in accordance with MIL-STD-808.

3.9.1 Color. Unless otherwise specified (see 6.2), the color shall be aircraft gray, color 16473 in accordance with FED-STD-595.

3.10 Identification of product. Equipment, assemblies and parts shall be marked for identification in accordance with MIL-STD-130.

3.11 Workmanship. Workmanship shall be in accordance with high grade manufacturing practice covering this type of equipment.

4. QUALITY ASSURANCE PROVISIONS

4.1 Responsibility for inspection. Unless otherwise specified (see 6.2) in the contract or purchase order, the supplier is responsible for the performance of all inspection requirements as specified herein. Except as otherwise specified, the supplier may utilize his own facilities or any commercial laboratory acceptable to the Government. The Government reserves the right to perform any of the inspections set forth in the specification where such inspections are deemed necessary to assure supplies and services conform to prescribed requirements.

4.2 Classification of tests. The inspection and testing of the refrigerator shall be classified as follows:

Source: https://assist.dla.mil -- Downloaded: 202610-17T03:39Z
Check the source to verify that this is the current version before use.

a. Preproduction testing (see 4.4.)
b. Acceptance tests (see 4.5)

4.3 Test conditions

4.3.1 Atmospheric conditions. Unless otherwise specified herein, all tests required by this specification shall be made at an atmospheric pressure of 28 to 32 inches of mercury and at a temperature of 25 degrees (plus or minus 5 degrees) C. and a relative humidity of 80% or less. Where tests are made with atmospheric pressure or temperature substantially different from the above values, proper allowance shall be made for the change in instrument reading.

4.3.2 Test power. Unless otherwise specified herein, the refrigerators shall be tested with 115 volt, 20 cycle, single phase alternating current. The voltage and frequency tolerance shall be plus or minus 5 percent.

4.4 Preproduction testing. The preproduction testing shall consist of the tests prescribed under sections 4.4.3 and 4.5. Failure of the preproduction sample to meet the requirements or pass the tests or inspections, as specified herein, shall be cause for rejection.

4.4.1 Sample. The preproduction sample shall consist of refrigerator(s) representative of the production equipment.

4.4.2 Test report. Three copies of a test report in accordance with MIL-STD-831 shall be submitted to the procuring activity.

4.4.2.1 Code and standards compliance. The supplier shall furnish the Government with proof of compliance with the requirements of all standards, codes and specifications specified herein.

4.4.3 Preproduction tests

4.4.3.1 Pull-down test. The complete refrigerator, with the storage compartment at a temperature of 100 degrees Fahrenheit, shall be placed in ambient of 110 degrees Fahrenheit. The refrigerator shall then be put into operation to determine compliance with 3.6.3. Fifty pounds of aluminum rivets, at a temperature of 100 degrees Fahrenheit, shall be loaded into the storage compartment at any time after the refrigerator has been put in operation and before the temperature of the storage compartment has dropped to minus 20 degrees Fahrenheit.

4.4.3.2 Running time test. At the completion of the test specified in 4.4.3.1 and with the rivets remaining in the refrigerator, the refrigerator shall be kept in operation for a

Source: https://assist.dla.mil -- Downloaded: 202610-17T03:39Z
Check the source to verify that this is the currentversion before use.

period of 24 hours to determine compliance with 3.6.3. Immediately upon completion of this 24 hour test the canisters shall be removed from the rack to determine compliance with 3.6.4.2.

4.4.3.3 Caster load test. A compressed load of 500 pounds shall be applied to each of four casters through the top plate by means of weights or a press for a period of one minute to determine compliance with 3.6.1.2. The casters so tested shall be inspected for damage or permanent set as a result of the load applied. Casters which display damage or permanent set shall be cause for rejection.

4.4.3.4 Transportation and handling test. The refrigerator shall be subjected to test method 516 procedure II or III of MIL-STD-810. Failure to meet the requirements of this test shall be cause for rejection.

4.5 Acceptance tests. Acceptance tests shall consist of:

a. Individual tests
b. Sample tests.

4.5.1 Individual tests. Each refrigerator shall be subjected to the following tests.

4.5.1.1 In-process inspection. The intermediate product or assemblies which cannot be checked or measured after final assembly shall be examined at various stages of manufacture for compliance with this specification. The examination will be made at an appropriate intermediate station for defects in construction; workmanship, dimensions, material, and compliance with paragraphs 3.4.1, 3.5.2, 3.5.3, and 3.5.4. Any deviation from specified requirements shall be classified as a defect. The inspection level (Sample Size) shall be level II and the acceptable quality level (AQL) shall be 4.0 defects per hundred units.

4.5.1.2 End product inspection. The inspection lot shall consist of all completely fabricated refrigerators offered for acceptance at one time. The sample unit shall be one completely fabricated refrigerator.

4.5.1.3 Visual examination. Examination of the refrigerators shall be in accordance with the classification of defects set forth below:

Source: https://assist.dla.mil -- Downloaded: 2026-10-17T03:39Z
Check the source to verify that this is the current version before use.

EXAMINE	DEFECT	MAJOR	MINOR
Finish	Type of finish not as specified or blistered peeled, chipped, or area of no film or thin film	x	
	Not finished where required	x	
Materials	Component not fabricated of material specified	x	
Construction & Workmanship	Part missing or not specified type or size	x	
General (Applicable to all components & assemblies)	Fractured, split, punctured, dented, deteriorated, bowed, malformed, or otherwise impaired	x	
	Defective or otherwise damaged.		x
	Sharp burr, sliver or splinter that may be injurious to personnel.		x
	Misplaced, loose or not in proper alignment	x	
	Operation omitted or not properly performed	x	
	functioning component that requires abnormal force to operate		x
	Not connected or jointed as specified, or poorly accomplished.	x	
	Any adjustable assembly that cannot be adjusted	x	
	Any adjustable assembly not fully adjusted to perform the function for which intended		x

Source: https://assist.dla.mil -- Downloaded: 2026-10-17T03:39Z
Check the source to verify that this is the current version before use.

EXAMINE	DEFECT	MAJOR	MINOR
	Any component not readily accessible for servicing where required		x
Welding and Brazing (Where required)	Not type specified, missing, incomplete, burn holes, cracked, fractured or otherwise not fused	x	
	Slag inclusion, slight undercut, not smooth and uniform, scale or flux deposits not removed		x
Soldering (where applicable)	Missing, not adherent or incomplete	x	
	Not clean (flux or flux residue not removed), not smooth (surface not finished neatly or pin holes in solder)		x
Bolts, nuts, screws studs and other	Missing, not type specified, broken, stripped, fractured or loose.		x
Electrical assembly	Wiring cut, abraded, not properly joined, loose at terminal or not enclosed in specified conduit where required.	x	
	Adequate slack not provided for wiring to relieve strain or excessive insulation stripped from wiring		x
Lubrication (Where applicable)	Not lubricated where required	x	
	Insufficiently lubricated		x
	Lubrication fitting not readily accessible for servicing	x	

Source: https://assist.dla.mil -- Downloaded: 202610-17T03:39Z
Check the source to verify that this is the current version before use.

EXAMINE	DEFECT	MAJOR	MINOR
Assembly	Component not properly assembled or secured		x
	Unit perceptibly out of square or alignment	x	
Marking, Identification	Missing, incomplete, not legible, not as specified		x

4.5.1.4 Dimensional examination. Inspection shall be made of the refrigerators to determine compliance with the dimensions specified. Any deviation from specified requirements shall be classified as a defect.

4.5.2 Sample tests.

4.5.2.1 Sampling. Sampling for inspection and acceptance shall be performed in accordance with the provisions set forth in Standard MIL-STD-105, except where otherwise indicated.

4.5.2.2 End product testing. When a preproduction sample is not required, one production unit from the initial lot shall be tested as specified in 4.4.3.1 and 4.4.3.2.

4.5.2.3 Sample testing. All samples shall be tested as specified in 4.4.3.1 and 4.5.1.

4.5.2.4 Inspection levels and AQL's. The acceptable quality levels (AQL's), expressed in defects per hundred units, and inspection levels (for sample size), shall be as follows in accordance with MIL-STD-105.

	AQL's Insp Lev	Major	Total
For examination in 4.5.1.3	II	4.0	10.
For examination in 4.5.1.4 (one class)			10.

4.5.3 Examination of preparation for delivery. An examination shall be made to determine that preservation and packaging, packing, and marking conform to MIL-P-12323.

5. PREPARATION FOR DELIVERY

5.1 Preservation and packaging. Refrigerators shall be preserved packaged, and packed in accordance with the applicable requirements of MIL-P-12323. Preservation and packaging shall be level A, B, or C as specified (see 6.2).

Source: https://assist.dla.mil -- Downloaded: 202610-17T03:39Z
Check the source to verify that this is the current version before use.

5.2 Marking. In addition to any special marking required by the contract or order, interior and exterior containers shall be marked in accordance with MIL-STD-129.

6. NOTES

6.1 Intended use. The refrigerator covered by this specification is intended for use in storing aluminum alloy rivets and maintaining them at temperature low enough to retard age-hardening of the rivets before they are headed.

6.2 Ordering data. Procurement documents should specify the following:

a. Title, number, and date of this specification.
b. Preproduction testing required and number of samples (see 3.1.1).
c. Fungus treatment, if required (see 3.5.5).
d. Color, if different (see 3.9.1).
e. Responsibility for inspection (see 4.1).
f. Level of packaging and packing (see 5.1).

Custodians:

Army-GL
Navy-YD
Air Force-82

Preparing Activity:

Air Force-82

Reviewer:

Army-GL
Navy-YD
Air Force-82

"Review/user information is current as of the date of this document. For future coordination of changes to this document, draft circulation should be based on the information in the current DODISS."

Source: https://assist.dla.mil -- Downloaded: 202610-17T03:39Z
Check the source to verify that this is the current version before use.

STANDARDIZATION DOCUMENT IMPROVEMENT PROPOSAL

(See Instructions – Reverse Side)

1. DOCUMENT NUMBER	2. DOCUMENT TITLE

3a. NAME OF SUBMITTING ORGANIZATION	4. TYPE OF ORGANIZATION *(Mark one)*
	☐ VENDOR
b. ADDRESS *(Street, City, State, ZIP Code)*	☐ USER
	☐ MANUFACTURER
	☐ OTHER *(Specify)*: _____

5. PROBLEM AREAS

a. Paragraph Number and Wording:

b. Recommended Wording:

c. Reason/Rationale for Recommendation:

6. REMARKS

7a. NAME OF SUBMITTER *(Last, First, MI)* – Optional	b. WORK TELEPHONE NUMBER *(Include Area Code)* – Optional
c. MAILING ADDRESS *(Street, City, State, ZIP Code)* – Optional	8. DATE OF SUBMISSION *(YYMMDD)*

DD FORM 82 MAR 1426 PREVIOUS EDITION IS OBSOLETE.

(TO DETACH THIS FORM, CUT ALONG THIS LINE.)

Source: https://assist.dla.mil -- Downloaded: 202610-17T03:39Z
Check the source to verify that this is the current version before use.