Fed. Std. No. 128a
AMENDMENT—2
February 17, 1965

SUPERSEDING
Interim Amendment—1
September 10, 1964

FEDERAL STANDARD

JUNCTION BOX; EXTENSION, JUNCTION BOX; COVER, JUNCTION BOX, (STEEL, CADMIUM OR ZINC COATED) (FOR USE WITH METALLIC CONDUIT SYSTEMS)

This amendment, which forms a part of Federal Standard No. 128a, dated October 18, 1961, was approved by the Commissioner, Federal Supply Service, General Services Administration, for the use of all Federal agencies.

Page 1, title: Delete "(FOR USE WITH METALLIC CONDUIT SYSTEMS)".

Page 1, paragraph S1: Delete in its entirety and substitute:

S1. Purpose and scope. The purpose of this standard is the establishment of a standard list of junction boxes, junction box extensions, and junction box covers for use with rigid metallic conduit, electrical metallic tubing, flexible metallic conduit, armored cable and, when installed in accordance with the National Electrical Code, nonmetallic-sheathed cable and nonmetallic tubing, for ordinary maintenance and extension of circuit purposes as required by Government maintenance activities. This standard will keep the varieties of such boxes, extensions and covers which are procured and stocked to a minimum consistent with such requirements. It does not cover nonmetallic junction boxes, cast-metal boxes, conduit outlets or hinged covered boxes.

Page 1, paragraph S3: Under Type I, Size B, Style No. 5, line 2: Delete "armored" and substitute "integral".

Page 2, paragraph S3:

Under Type II, Size D, Style No. 12, line 1: Delete "ten" and substitute "twelve".

Under Type IV, Size K, Style No. 30, line 2: After 21/32", Add: w/integral cable clamp.

Under Type IV, Size L, Style No. 32, line 2: Delete 23/32" and substitute 21/32", delete "armored" and substitute "integral".

Under Type IV, Size L, Style No. 33, line 2: Delete 23/32" and substitute 21/32", delete "armored" and substitute "integral".

Under Type IV, Size M, Style No. 35, line 2: Delete 23/32" and substitute 21/32".

Under Type VIII, Size W, Styles Nos. 69 through 73: Delete in their entirety.

Page 3, bottom, Add:

Note: Type VIII, Size W, Style Nos. 69 through 73 are covered by Federal Specification W-P-455, Plate, Wall, Electrical.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T12:54:
Check the source to verify that this is the current version before use.