MIL-C-12433B(MO)
26 April 1965

SUPERSEDING
MIL-C-12433A(CE)
15 January 1959

MILITARY SPECIFICATION

CIRCUIT-BREAKER BOX, SURFACE-MOUNTED, WITH TWO BREAKERS MANUALLY RESET

1. SCOPE

1.1 Scope. This specification covers one size circuit-breaker box containing two circuit breakers of like capacity.

1.2 Classification. Circuit-breaker boxes shall be of the following classes, as specified (see 6.2):

Class 1 - With 15-ampere circuit breakers.
Class 2 - With 20-ampere circuit breakers.
Class 3 - With 30-ampere circuit breakers.
Class 4 - With 40-ampere circuit breakers.
Class 5 - With 50-ampere circuit breakers.

2. APPLICABLE DOCUMENTS

2.1 The following documents of the issue in effect on date of invitation for bids or request for proposal form a part of this specification to the extent specified herein:

SPECIFICATIONS

Federal

W-C-375	- Circuit Breaker, Molded Case; Branch Circuit and Service.
QQ-S-636	- Steel; Carbon (Low-Carbon), Sheets and Strips.

Military

MIL-V-173	- Varnish, Moisture- and -Fungus Resistant, for the Treatment of Communications, Electronic, and Associated Electrical Equipment.

FSC 5925

Source: https://assist.dla.mil -- Downloaded: 2026-10-17T22:48Z
Check the source to verify that this is the current version before use.

MIL-T-704 - Treatment and Painting of Materiel.
MIL-E-17555 - Electronic and Electrical Equipment and Associated Repair Parts, Preparation for Delivery of.

STANDARDS

Military

MIL-STD-105 - Sampling Procedures and Tables for Inspection by Attributes.
MIL-STD-130 - Identification Marking of U. S. Military Property.

DRAWINGS

MO(ERDL)

D 4008-1 - Circuit Breaker Box, Surface-Mounted with Two Breakers Manually Reset.

(Copies of specifications, standards, and drawings required by suppliers in connection with specific procurement functions should be obtained from the procuring activity or as directed by the contracting officer.)

2.2 Other publications. The following documents form a part of this specification to the extent specified herein. Unless otherwise indicated, the issue in effect on date of invitation for bids or request for proposal shall apply.

OFFICIAL CLASSIFICATION COMMITTEE

Uniform Freight Classification Rules.

(Application for copies should be addressed to the Official Classification Committee, 1 Park Avenue at 33rd Street, New York, N. Y. 10016.)

AMERICAN TRUCKING ASSOCIATION

National Motor Freight Classification Rules.

(Application for copies should be addressed to the American Trucking Association, 1616 P Street, NW, Washington, D. C. 20036.)

Source: https://assist.dla.mil -- Downloaded: 2026-10-17T22:48Z
Check the source to verify that this is the current version before use.

3. REQUIREMENTS

3.1 Description. The circuit-breaker box shall be in accordance with Drawing D 4008-1. The box shall be fitted with two circuit breakers (see 3.3) of the capacity specified (see 1.2 and 6.2).

3.1.1 Drawing. The drawing which forms a part of this specification is an engineering design drawing. The supplier is responsible for preparing his own shop drawings. Where tolerances prescribed could cumulatively result in improper fits, the supplier shall provide tolerances within those prescribed on the drawing to insure proper fit, assembly, and operation of the circuit breaker box. No deviation from the prescribed dimensions or tolerances is permissible without prior approval of the contracting officer.

3.2 Material. Material shall be as specified herein and on Drawing D 4008-1.

3.2.1 Steel. Steel shall conform to QQ-S-636, hot-rolled, as-rolled condition, and finish.

3.3 Circuit-breaker units. The circuit-breaker units shall conform to W-C-375, class 1a, single-pole for use with 120-volt, alternating current. The circuit breakers within each box shall be of like capacity. The handles of the two circuit-breaker units shall be interconnected.

3.4 Treatment and painting. The circuit-breaker box shall be treated and painted in accordance with MIL-T-704.

3.4.1 Fungus control of electrical components. Circuit elements such as cable and wire and circuit breakers shall be treated with a fungicidal varnish conforming to MIL-V-173.

3.5 Identification marking. The circuit-breaker boxes shall be identified in accordance with MIL-STD-130.

3.6 Workmanship. The circuit-breaker boxes shall be free from defects such as sharp edges, burrs, rust, or other defects that may adversely affect their intended function.

4. QUALITY ASSURANCE PROVISIONS

4.1 Responsibility for inspection. Unless otherwise specified in the contract or purchase order, the supplier is responsible for the performance of all inspection requirements as specified herein. Except as otherwise specified, the supplier may utilize his own facilities

Source: https://assist.dla.mil -- Downloaded: 2026-10-17T22:48Z
Check the source to verify that this is the current version before use.

or any commercial laboratory acceptable to the Government. The Government reserves the right to perform any of the inspections set forth in this specification where such inspections are deemed necessary to assure supplies and services conform to prescribed requirements.

4.2 Classification of inspection. Inspection shall be classified as follows:

(a) Quality conformance inspection (see 4.3)
(b) Inspection of preparation for delivery (see 4.4)

4.3 Quality conformance inspection.

4.3.1 Sampling. Sampling for examination shall be in accordance with MIL-STD-105, inspection level S-2. AQL shall be 2.5 percent defective.

4.3.2 Examination. Samples selected in accordance with 4.2.1 shall be examined for the following defects:

101. Dimension not in accordance with the applicable drawing.
102. Assembly not complete.
103. Components damaged or inoperable.
104. Fungus treatment not as specified.
105. Identification not as specified.
106. Cleaning, treating, or painting not as specified.

4.4 Inspection of preparation for delivery. Preservation, packaging, packing, and marking shall be examined and tested in accordance with MIL-E-17555.

5. PREPARATION FOR DELIVERY

5.1 Preservation, packaging, packing, and marking. Circuit-breaker boxes shall be unit protected and packaged, packed, and marked in accordance with MIL-E-17555, packaging level A or C as specified (see 6.2), and packing level A, B, or C as specified (see 6.2).

6. NOTES

6.1 Intended use. The circuit-breaker boxes are used on 120-volt a-c lighting and power circuits where total current does not exceed 50 amperes.

6.2 Ordering data. Procurement documents should specify the following:

(a) Title, number, and date of this specification.
(b) Class of circuit-breaker box required (see 1.2).
(c) Level of packaging and packing required (see 5.1).

Custodians:

Army - MO(ERDL)

Preparing Activity:

Army - MO(ERDL)

Project No. 5925-A018

Source: https://assist.dla.mil -- Downloaded: 2026-10-17T22:48Z
Check the source to verify that this is the current version before use.

FOLD

DEPARTMENT OF THE ARMY
U. S. ARMY MOBILITY EQUIPMENT CENTER
RESEARCH, DEVELOPMENT AND ENGINEERING DIRECTORATE
ATTN: SMOFB-RDE-KX
FORT BELVOIR, VIRGINIA 22060

OFFICIAL BUSINESS

POSTAGE AND FEES PAID
DEPARTMENT OF THE ARMY

DEPARTMENT OF THE ARMY
U. S. ARMY MOBILITY EQUIPMENT CENTER
RESEARCH, DEVELOPMENT AND ENGINEERING DIRECTORATE
ATTN: SMOFB-RDE-KX
FORT BELVOIR, VIRGINIA 22060

FOLD

Source: https://assist.dla.mil -- Downloaded: 2026-10-17T22:48Z
Check the source to verify that this is the current version before use.

SPECIFICATION ANALYSIS SHEET

Form Approved
Budget Bureau No. 119-R004

INSTRUCTIONS

This sheet is to be filled out by personnel either Government or contractor, involved in the use of the specification in procurement of products for ultimate use by the Department of Defense. This sheet is provided for obtaining information on the use of this specification which will insure that suitable products can be procured with a minimum amount of delay and at the least cost. Comments and the return of this form will be appreciated. Fold on lines on reverse side, staple in corner, and send to preparing activity *(as indicated on reverse hereof)*.

SPECIFICATION

MIL-C-12433B(MO) - Circuit-Breaker Box, Surface-Mounted, With Two Breakers Manually Reset

ORGANIZATION *(Of submitter)*	CITY AND STATE

CONTRACT NO.	QUANTITY OF ITEMS PROCURED	DOLLAR AMOUNT
		$

MATERIAL PROCURED UNDER A

☐ DIRECT GOVERNMENT CONTRACT ☐ SUBCONTRACT

1. HAS ANY PART OF THE SPECIFICATION CREATED PROBLEMS OR REQUIRED INTERPRETATION IN PROCUREMENT USE?

A. GIVE PARAGRAPH NUMBER AND WORDING.

B. RECOMMENDATIONS FOR CORRECTING THE DEFICIENCIES.

2. COMMENTS ON ANY SPECIFICATION REQUIREMENT CONSIDERED TOO RIGID

3. IS THE SPECIFICATION RESTRICTIVE?

☐ YES ☐ NO IF "YES", IN WHAT WAY?

4. REMARKS *(Attach any pertinent data which may be of use in improving this specification. If there are additional papers, attach to form and place both in an envelope addressed to preparing activity)*

SUBMITTED BY *(Printed or typed name and activity)*	DATE

DD FORM 1 APR 63 1426

D — 63,913 ARMY — FORT BELVOIR, VA.

Source: https://assist.dla.mil -- Downloaded: 2026-10-17T22:48Z
Check the source to verify that this is the current version before use.