INCH-POUND

MIL-P-17739D(YD)
7 July 1988
SUPERSEDING
MIL-P-17739C(YD)
27 October 1980

MILITARY SPECIFICATION

PUMP UNIT, ROTARY, POWER-DRIVEN, FUEL OIL, SKID BASE MOUNTED

This specification is approved for use by the Naval Facilities Engineering Command, Department of the Navy, and is available for use by all Departments and Agencies of the Department of Defense.

1. SCOPE

1.1 Scope. This specification covers two sizes of positive displacement, skid-mounted, diesel- and gasoline-engine-driven rotary pumps complete with engine suitable for handling Navy special fuel oil at temperatures ranging from 200 degrees Fahrenheit (°F) to 60°F.

1.2 Classification. Pump unit shall be of the following sizes, as specified (see 6.2):

Size 6 - Single speed - 360 gallons per minute (gpm).
Size 8 - Two speed - 300 gpm at low speed; 600 gpm at high speed.

2. APPLICABLE DOCUMENTS

2.1 Government documents.

2.1.1 Specifications, standards, and handbooks. The following specifications, standards, and handbooks form a part of this specification to the extent specified herein. Unless otherwise specified, the issues of these documents shall be those listed in the issue of the Department of Defense Index of Specifications and Standards (DODISS) and supplement thereto, cited in the solicitation.

Beneficial comments (recommendations, additions, deletions) and any pertinent data which may be of use in improving this document should be addressed to: Commanding Officer, Naval Construction Battalion Center (Code 156), Port Hueneme, CA 93043-5000, by using the self-addressed Standardization Document Improvement Proposal (DD Form 1426) appearing at the end of this document or by letter.

AMSC N/A FSC 4320

DISTRIBUTION STATEMENT A. Approved for public release; distribution is unlimited.

Source: https://assist.dla.mil -- Downloaded: 2026-10-18T10:31Z
Check the source to verify that this is the current version before use.

SPECIFICATIONS

MILITARY

MIL-V-173 - Varnish, Moisture- and Fungus-Resistant (for the Treatment of Communications, Electronic, and Associated Electrical Equipment).
MIL-P-16789 - Packaging of Pumps, Including Prime Movers and Associated Repair Parts.

STANDARDS

MILITARY

MIL-STD-461 - Electromagnetic Interference Characteristics Requirements for Equipment.
MIL-STD-462 - Electromagnetic Interference Characteristics, Measurement of.

(Copies of specifications, standards, handbooks, drawings, publications, and other Government documents required by contractors in connection with specific acquisition functions should be obtained from the contracting activity or as directed by the contracting activity.)

2.2 Other publications. The following document(s) form a part of this specification to the extent specified herein. Unless otherwise specified, the issues of the documents which are DOD adopted shall be those listed in the issue of the DODISS specified in the solicitation. Unless otherwise specified, the issues of the documents not listed in the DODISS shall be the issue of the non-Government documents which is current on the date of the solicitation.

AMERICAN NATIONAL STANDARDS INSTITUTE, INC. (ANSI)

B16.1 - Cast Iron Pipe Flanges and Flanged Fittings Class 25, 125, 250, and 800 pounds.
B16.5 - Pipe Flanges and Flanged and Fittings.

(Application for copies should be addresssed to the American National Standards Institute, Inc., 1430 Broadway, New York, NY 10018.)

AMERICAN SOCIETY FOR TESTING AND MATERIALS (ASTM)

A27 - Specification for Mild to Medium Strength Carbon Steel Castings for General Application.
A278 - Specification for Gray Iron Castings for Pressure-Containing Parts for Temperatures up to 650°F.
A395 - Specification for Ferric Ductile Iron for Pressure Retaining Castings for Use at Elevated Temperatures.

Source: https://assist.dla.mil -- Downloaded: 2026-10-18T10:31Z
Check the source to verify that this is the current version before use.

(Application for copies should be addressed to the American Society for Testing and Materials, 1916 Race Street, Philadelphia, PA 19103.)

HYDRAULIC INSTITUTE (HI)

Standards of Hydraulic Institute.

(Application for copies should be addressed to the Hydraulic Institute, 712 Lakewood Center North, 14600 Detroit Ave., Cleveland, OH 44107.)

SOCIETY OF AUTOMOTIVE ENGINEERS, INC. (SAE)

SAE Handbook.

(Application for copies should be addressed to the Society of Automotive Engineers, Inc., 400 Commonwealth Drive, Warrendale, PA 15096.)

(Non-Government standards and other publications are normally available from the organizations which prepare or which distribute the documents. These documents also may be available in or through libraries or other informational services.)

* 2.3 Order of precedence. In the event of a conflict between the text of this specification and the references cited herein (except for associated detail specifications, specification sheets or MS standards), the text of this specification shall take precedence. Nothing in this specification, however, shall supersede applicable laws and regulations unless a specific exemption has been obtained.

3. REQUIREMENTS

3.1 Description. The pump unit shall consist essentially of a positive displacement, rotary pump, and a gasoline- or diesel-engine driver, all mounted on a common skid base. The rotary pump shall consist of a fixed casing containing gears, cams, screws, vanes, plungers, or similar pumping elements actuated by rotation of the drive shaft.

3.2 First production vehicle. When specified (see 6.2), the contractor shall furnish a pump of the size as required for first article inspection and approval (see 4.2.1 and 6.5).

3.3 Standard commercial product. The pump unit shall, as a minimum, be in accordance with the requirements of this specification and shall be the manufacturer's standard commercial product. Additional or better features which are not specifically prohibited by this specification but which are a part of the manufacturer's standard commercial product, shall be included in the pump unit being furnished. A standard commercial product is a product which has been sold or is being currently offered for sale on the commercial market through advertisements or manufacturer's catalogs, or brochures, and represents the latest production model.

Source: https://assist.dla.mil -- Downloaded: 2026-10-18T10:31Z
Check the source to verify that this is the current version before use.

3.4 Interchangeability. All units of the same classification furnished with similar options under a specific contract shall be identical to the extent necessary to insure interchangeability of component parts, assemblies, accessories, and spare parts.

3.5 Materials. Materials used shall be free from defects which would adversely affect the performance or maintainability of individual components or of the overall assembly. Materials not specified herein shall be of the same quality used for the intended purpose in commercial practice. Unless otherwise specified herein, all equipment, material, and articles incorporated in the work covered by this specification are to be new and fabricated using materials produced from recovered materials to the maximum extent possible without jeopardizing the intended use. The term "recovered materials" means materials which have been collected or recovered from solid waste and reprocessed to become a source of raw materials, as opposed to virgin raw materials. None of the above shall be interpreted to mean that the use of used or rebuilt products are allowed under this specification unless otherwise specified.

3.6 Pump design. The pump shall be a heavy-duty, positive displacement, rotary pump designed for a maximum output working pressure of at least 150 pound-force per square inch gage (psig). When specified (see 6.2), the pump casing or stuffing box or both shall be jacketed to permit transfer of heat from hot oil or steam to the oil being pumped. Unless otherwise specified (see 6.2), the jacket shall be designed for steam at 100 psig and 325°F. The pumps shall be gear, chain, or V-belt driven by a gasoline or diesel engine (see 3.11). A pressure relief valve designed to protect the pump from discharge overpressures exceeding an allowable safe pressure rise shall be furnished with each pump. The valve shall be incorporated in or attachable to the pump casing or shall be furnished for mounting external to the pump casing in accordance with the manufacturer's standard practice. The valve shall attain full relieving capacity at a pressure not exceeding 125 percent of the maximum rated outlet working pressure. The design of the pumping assembly shall permit accessibility for maintenance and service in the field.

3.6.1 Pump casing. The pump casing shall have properties at least equal to that of class 25 of ASTM A278, cast iron; ASTM A395, nodular iron; or ASTM A27 Grade 65-35, cast steel, and shall be capable of withstanding a hydrostatic pressure of 1.5 times the output working pressure. Suction and discharge flanges shall be faced, drilled, and blind tapped in accordance with ANSI B16.1. Suction flanges shall conform to ANSI B16.1, class 125; discharge flanges shall conform to ANSI B16.1, class 250. Unless otherwise specified (see 6.2), suction and discharge flanges shall be integral with the casing. When specified (see 6.2), pumps shall have inlet and outlet on opposite sides of the casing to achieve horizontal straight-line flow. The size 6, single-speed pump shall have 6-ingh pipe size suction and discharge, and the size 8, two-speed pump shall have 8-inch pipe size suction and discharge. Pumps not of these sizes but otherwise meeting the requirements herein may be adapted by

Source: https://assist.dla.mil -- Downloaded: 2026-10-18T10:31Z
Check the source to verify that this is the current version before use.

means of suitable steel flanged reducers conforming to ANSI B16.5 to meet the specified connection sizes. When specified (see 6.2), cast iron companion flanges or adaptors shall be bolted to the casing flanges or reducers and be suitably gasketed. Casing shall be furnished with renewable liners. The casing shall have tapped and plugged connections for draining and venting. A bronze valve shall be furnished for the vent.

3.6.2 Rotating elements. Rotating elements shall be gears, cams, screws, eccentrics, vanes, plungers, or similar elements actuated by rotation of the drive shaft. Rotating elements shall be of close-grained, cast-iron, bronzed, hardened carbon steel or alloy steel, synthetic material, or combinations thereof, suitable for fuel oil service. The rotating element shall operate in axial hydraulic balance and, if not symmetrical, shall be dynamically balanced critical speed in the range extending from a speed 25 percent below the lowest operating speed to a speed 25 percent above the highest operating speed (see 4.4.2). The pump, isolated from engine vibration, or tested separately from the unit shall give a double amplitude vibrometer reading in any plane of not greater than 0.005 inch when pumping the test medium (see 4.4.2) at any speed in the operating range.

3.6.3 Pump shaft. The pump shaft shall be the manufacturer's standard item.

3.6.4 Shaft seal. The shaft seal may be either a positive drive mechanical packless-type or conventional fiber ring-type packing designed for the required service. If lubrication is required, suitable fittings shall be furnished.

3.6.5 Bearings. The pump shaft shall be supported by two bearings of either the sleeve-type or the antifriction-type. Antifriction-type shall be sealed from pumped fluid and lubricated separately. Overhung pumps having both bearings on one side shall be equipped with a large diameter shaft and extra-heavy duty bearings an ample distance apart.

3.7 Performance. The size 6, single-speed pump unit shall be capable of delivering continuously 350 gpm of fuel oil at 15,000 Saybolt Seconds Universal (SSU) viscosity. The size 8, two-speed pump unit shall be capable of delivering continuously 600 gpm of fuel oil at 750 SSU viscosity in the high-speed range and 300 gpm of fuel oil at 60,000 SSU viscosity in the low-speed range. For both pump units these capacities shall be delivered at sea level against a total dynamic head of 390 feet, including a 15-foot suction lift, measured in feet of fuel oil at a pump efficiency of at least 60 percent. Both the size 6 and the size 8 pump units shall be capable of handling 80,000 SSU oil when operated at a lower capacity.

3.8 Flexible couplings. Except for V-belt drives for which couplings shall be furnished in accordance with the manufacturer's standard practice, a flexible coupling of approved design suitable for its intended purpose shall

Source: https://assist.dla.mil -- Downloaded: 2026-10-18T10:31Z
Check the source to verify that this is the current version before use.

connect the pump to the speed reducer and speed reducer to prime mover. Safety guards of light gage solid or expanded metal shall be installed around the flexible coupling.

3.9 Reduction gears. When reduction gears are furnished they shall be machine-cut and shall run in oil in a sealed, weatherproof case. The gear unit shall have a minimum efficiency of 96 percent.

3.10 Pressure and vacuum gages. A compound gage reading from 30 inches of vacuum to 150 psig shall be furnished for the pump suction. A 0-200 psig gage shall be furnished for the pump discharge. Both gages shall be furnished with restricting orifices and gage cocks, shall be self-draining, shall have a minimum diameter of 2-1/2 inches.

3.11 Engine. Size 6 pump unit shall be driven by a 4-cycle, air-cooled, gasoline engine or an industrial, 2- or 4-cycle diesel engine, as specified (see 6.2). Size 8 pump unit shall be driven through a two-speed reducer by an industrial, 2- or 4-cycle diesel engine. The engines shall have a continuous horsepower (hp) rating sufficient to operate the pump unit to meet the performance requirements of 3.7. All engine accessories, including instruments and gages, supplied commercially as standard equipment shall be furnished. Unless otherwise specified (see 6.2), the engine shall be equipped with 12-volt starting system. Batteries shall be shipped charged and dry. Fuel tanks shall be sized for a minimum of 8 hours continuous operation at full rated load. The diesel engine shall start in any temperature above -20°F. Starting aids may be either electric glow plug or ether primer. When an ether priming system is required, it shall be of the measured shot type, with storage capacity of not less than 12 fluid ounces.

3.12 Chain and belt drive. When belt-driven pump units are furnished, a multiple V-belt drive capable of transmitting not less than 125 percent of the rated hp of the engine shall be furnished. The belts shall be standard industrial belts. The pitch diameter, and center-to-center distance of the sheaves shall be as recommended by the belt manufacturer for the intended application. The drive shall be enclosed by a safety guard attached to the bedplate. The guard shall consits of a sheet-metal top not less than 0.1046-inch thick and an expanded metal side-panel. The commercial style designation of the expanded metal shall be not less than the belt drive. When chain-driven pump units are furnished, a multiple roller or silent chain drive capable of transmitting not less than 125 percent of the rated hp of the engine shall be furnished in accordance with the manufacturer's standard practice. Roller chains and sprockets shall have a guard as above. Silent chains shall run in oil in a sealed, weatherproof case.

3.13 Skid-base. The pump unit shall be mounted on a common, structural steel skid-base of welded construction. Each runner of the skid-base shall have both ends upturned and shall have lifting shackles, rings, or holes at least 3 inches in diameter at each end to permit handling by slings or chains. Each lifting attachment shall be capable of supporting 1-1/2 times

Source: https://assist.dla.mil -- Downloaded: 2026-10-18T10:31Z
Check the source to verify that this is the current version before use.

the weight of the pump unit. The base shall be sufficiently strong to keep the equipment in proper alinement and to avoid distortion when the unit is skidded along the ground or when the unit is raised or lowered through the air.

3.14 Lubrication. Unless otherwise specified (see 6.2), means for lubrication shall be in accordance with the manufacturer's standard practice. The lubricating points shall be easily visible and accessible. Hydraulic lubrication fittings shall be in accordance with SAE J534. Where use of high pressure lubricating equipment, 1,000 psi or higher, will damage grease seals or other parts, a suitable warning shall be affixed to the equipment in a conspicuous location. The unit shall be lubricated as specified in section 5.

3.15 Instruction plates. The pump unit shall be equipped with instruction plates suitably located, describing any special or important procedures to be followed in operating and servicing the equipment. Plates shall be of a material which will last and remain legible for the life of the equipment. Plates shall be securely affixed to the equipment with nonferrous screws or bolts of not less than 1/8-inch diameter.

3.16 Identification plate. An identification plate will be furnished by the contracting officer for each pump unit. The contractor shall stamp all necessary data in the blank spaces of the plate provided for that purpose, and securely affix a plate to each pump unit in a conspicuous place with nonferrous screws, rivets, or bolts not less than 1/8-inch in diameter. The applicable nomenclature contained in the contract item description shall be placed in the top blank.

3.17 Pump performance plate. The pump unit shall be equipped with a pump performance plate, suitably located, indicating the capacity range of the pump in gpm at corresponding viscosities. Plate shall be of a material which will last and remain legible for the life of the equipment, and shall be securely affixed thereto with nonferrous screws or bolts of not less than 1/8-inch diameter.

3.18 Electromagnetic interference suppression. When specified (see 6.2), the unit shall conform to the electromagnetic interference suppression requirements of MIL-STD-461, class C3 or the requirements of SAE J551, as specified (see 6.2).

3.19 Cleaning, treatment, and painting. Surfaces normally painted in good commercial practice shall be cleaned, treated, and painted as specified herein. The color of the finish coat shall be as specified (see 6.2). Surfaces to be painted shall be cleaned and dried to insure that they are free from contaminants such as oil, grease, welding slag and spatter, loose mill scale, water, dirt, corrosion product, or any other contaminating substances. As soon as practicable after cleaning, and before any corrosion product or other contamination can result, the surfaces shall be prepared or treated to insure the adhesion of the coating system. The painting shall consist of at least one coat of primer and one finish coat. The primer shall be applied to a clean, dry surface as soon as practicable after cleaning and treating.

Source: https://assist.dla.mil -- Downloaded: 2026-10-18T10:31Z
Check the source to verify that this is the current version before use.

Painting shall be with manufacturer's current materials according to manufacturer's current processes and the total dry film thickness shall be not less than 2.5 mils over the entire surface. The paint shall be free from runs, sags, orange peel, or other defects.

3.20 Fungus resistance. When specified (see 6.2), electrical components and circuit elements, including terminal and circuit connections, shall be coated with varnish conforming to MIL-V-173, except that:

a. Components and elements inherently inert to fungi or in hermetically sealed enclosures need not be coated.
b. Current-carrying contact surfaces, such as relay contact points, shall not be coated.

3.21 Workmanship.

3.21.1 Steel fabrication. The steel used in fabrication shall be free from kinks, sharp bends, and other conditions which would be deleterious to the finished product. Manufacturing processes shall not reduce the strength of the steel to a value less than intended by the design. Manufacturing processes shall be done neatly and accurately. All bends shall be made by controlled means to insure uniformity of size and shape.

3.21.2 Bolted connections. Boltholes shall be accurately punched or drilled and shall have the burrs removed. Washers or lockwashers shall be provided in accordance with good commercial practice, and all bolts, nuts, and screws shall be tight.

3.21.3 Riveted connections. Rivet holes shall be accurately punched or drilled and shall have the burrs removed. Rivets shall be driven with pressure tools and shall completely fill the holes. Rivet heads, when not countersunk or flattened, shall be of approved shape and of uniform size for the same diameter of rivet. Rivet heads shall be full, neatly made, concentric with the rivet holes, and in full contact with the surface of the member.

3.21.4 Welding. Welding procedures shall be in accordance with a nationally recognized welding code. The surface of parts to be welded shall be free from rust, scale, paint, grease, or other foreign matter. Welds shall be of sufficient size and shape to develop the full strength of the parts connected by the welds. Welds shall transmit stress without permanent deformation or failure when the parts connected by the weld are subjected to proof and service loadings.

3.21.5 Castings. All castings shall be sound and free from patching, misplaced coring, warping, or any other defect which reduces the castings ability to perform its intended function.

Source: https://assist.dla.mil -- Downloaded: 2026-10-18T10:31Z
Check the source to verify that this is the current version before use.

4. QUALITY ASSURANCE PROVISIONS

4.1 Responsibility for inspection. Unless otherwise specified in the contract or purchase order, the contractor is responsible for the performance of all inspection requirements as specified herein. Except as otherwise specified in the contract or purchase order, the contractor may use his own or any other facilities suitable for the performance of the inspection requirements specified herein, unless disapproved by the Government. The Government reserves the right to perform any of the inspections set forth in the specification where such inspections are deemed necessary to assure supplies and services conform to prescribed requirements.

* 4.1.1 Responsibility for compliance. All items must meet all requirements of sections 3 and 5. The inspection set forth in this specification shall become a part of the contractor's overall inspection system or quality program. The absence of any inspection requirements in the specification shall not relieve the contractor of the responsibility of assuring that all products or supplies submitted to the Government for acceptance comply with all requirements of the contract. Sampling in quality conformance does not authorize submission of known defective material, either indicated or actual, nor does it commit the Government to acceptance of defective material.

4.1.2 Material inspection. The contractor is responsible for insuring that supplies and materials are inspected for compliance with all the requirements specified herein and in applicable referenced documents.

4.1.3 Component and material inspection. Components and materials shall be inspected in accordance with all the requirements specified herein and in applicable referenced documents.

4.2 Classification of inspections. The inspection requirements specified herein are classified as follows:

a. First article inspection (see 4.2.1).
b. Quality conformance inspection (see 4.2.2).

4.2.1 First article inspection. The first article inspection shall be performed on one complete pump unit when a first article is required (see 3.2 and 6.2). This inspection shall include the examination of 4.3 and the tests of 4.4. The first article may be either a first production item or a standard production item from the supplier's current inventory provided the item meets the requirements of the specification and is representative of the design, construction, and manufacturing technique applicable to the remaining items to be furnished under the contract.

4.2.2 Quality conformance inspection. The quality conformance inspection shall be performed on each pump unit as specified herein. This inspection shall include the examination of 4.3, the tests of 4.4.3, and when specified (see 6.2), the tests of 4.4.1, 4.4.2, and 4.4.4.

Source: https://assist.dla.mil -- Downloaded: 2026-10-18T10:31Z
Check the source to verify that this is the current version before use.

4.3 Examination. Each pump unit shall be examined for compliance with the requirements specified in section 3 of this specification. Any redesign or modification of the contractor's standard product to comply with specified requirements, or any necessary redesign or modification following failure to meet specified requirements shall receive particular attention for adequacy and suitability. This element of inspection shall encompass all visual examinations and dimensional measurements. Noncompliance with any specified requirements or presence of one or more defects preventing or lessening maximum efficiency shall constitute cause for rejection.

4.4 Tests.

4.4.1 Hydrostatic test. The pump unit casing shall be hydrostatically tested at a pressure equal to one and one-half times the allowable output working pressure specified in 3.6. Hydrostatic tests shall be made using oil at room temperature, or water, at the option of the contractor.

4.4.2 Performance test. The pump unit shall be tested to determine compliance withthe requirements of 3.6.2 and 3.7. Tests shall be conducted and reported in accordance with the Rotary Pump Section of the Hydraulic Institute Standards. The test medium shall be a clean petroleum oil of approximately 250 SSU viscosity at a pumping temperature between 60°F and 130°F. The completely assembled pump unit shall be run continuously for 30 minutes through the range of speeds specified in 3.6.2. No critical speeds shall be permitted at any point of the range. Vibrations specified in 3.6.2 shall not be exceeded. Test results shall be corrected as required to reflect the difference in slippage between the test medium and fuel oil having the viscosity specified in 3.7.

4.4.3 Functional test. Each pump unit delivered shall be shop tested for not less than 15 minutes. Capacity, smoothness of operation (no critical revolutions per minute), and head effectiveness of the stuffing box or mechanical seals shall be checked during these tests. Test curves may be plotted, as necessary, to verify performance.

4.4.4 Electromagnetic interference suppresion tests. When electromagnetic interference suppresion is specified, the first article sample shall be tested in accordance with MIL-STD-462 or SAE J551, as applicable, to verify compliance with the pertinent provisions of MIL-STD-461 or SAE J551.

4.5 Packaging inspection. The preservation, packaging, and marking of the item shall be inspected to verify conformance to the requirements of section 5.

5. PACKAGING

5.1 Preservation, packaging, packing, and marking. The pump unit shall be preserved, packaged, packed, and marked in accordance with MIL-P-16789. The level of preservation, packaging, and level of packing shall be as specified (see 6.2).

Source: https://assist.dla.mil -- Downloaded: 2026-10-18T10:31Z
Check the source to verify that this is the current version before use.

6. NOTES

6.1 Intended use. Pump units covered by this specification are intended primarily for use in tank farms to transfer Navy special fuel oil.

6.2 Ordering data.

a. Title, number, and date of this specification.
b. Size required (see 1.2).
c. When first article is required for first article inspection and approval (see 3.2, 4.2.1, and 6.4).
d. When it is required for the pump casing or stuffing box or both to be jacketed (see 3.6).
e. When the jacket shall be designed for steam other than at 100 psig and 325°F (see 3.6).
f. Whe the suction and discharge flanges shall be other than integral with the casing (see 3.6.1).
g. When pump connections shall be arranged for horizontal, in-line flow (see 3.6.1).
h. When companion flanges shall be bolted to casing flanges or reducers and gasketed (see 3.6.1).
i. Type of engine required for size 6 pump (see 3.11).
j. When the engine shall be equipped with other than a 12-volt starting system (see 3.11).
k. When lubrication shall be other than manufacturer's standard practice (see 3.14).
l. When electromagnetic interference suppression control is required and whether class C3 of MIL-STD-461 or SAE J551 applies (see 3.18).
m. The color of the finish coat (see 3.19).
n. When fungus resistance is required (see 3.20).
o. When tests of 4.4.1, 4.4.2, and 4.4.4 are required for quality conformance inspection (see 4.2.2).
p. Level of preservation, packaging, and level of packing required (see 5.1).

6.3 Definitive specification part number. The specification part number is a definitive part number which corresponds to the sizes of pump units covered by this specification and defines the requirements of the options presented under this specification. The specification number, and the size code number are combined to form the definitive specification part number.

6.3.1 Cataloging data. For cataloging purposes, part numbers for the pump units are assigned as follows:

M17739 - X

Specification part number
Size code number (see 6.3.2)

Source: https://assist.dla.mil -- Downloaded: 2026-10-18T10:31Z
Check the source to verify that this is the current version before use.

6.3.2 Size code number. The size of the pump unit (see 3.6.1 and 3.7) are identified by a single digit number, as follows:

Size 6 - 6
Size 8 - 8

6.4 Data requirements. When this specification is used in an acquisition and data are required to be delivered, the data requirements shall be developed as specified by an approved Data Item Description (DD Form 1664) and delivered in accordance with the approved Contract Data Requirements List (CDRL), incorporated into the contract. When the provisions of DOD FAR Supplement, Part 27, Sub-Part 27.410-6 (DD Form 1423) are invoked and the DD Form 1423 is not used, the data shall be delivered by the contractor in accordance with the contract or purchase order requirements.

6.5 First article. When a first article inspection is required, the item will be tested and should be a first production item or it may be a standard production item from the contractor's current inventory as specified in 4.2.1. The first article should consist of one complete pump unit(s). The contracting officer should include specific instructions in acquisition documents regarding arrangements for examination, test, and approval of the first article.

6.6 Subject term (key word) listing.

Fuel oil transfer
Pump unit
Rotary pump

6.7 Changes from previous issue. The margins of this specification are marked with an asterisk to indicate where changes (additions, modifications, corrections, deletions) from the previous issue were made. This was done as a convenience only and the Government assumes no liability whatsoever for any inaccuracies in these notations. Bidders and contractors are cautioned to evaluate the requirements of this document based on the entire content irrespective of the marginal notations and relationship to the last previous issue.

Preparing Activity:
Navy - YD

(Project 4320-N257)

Source: https://assist.dla.mil -- Downloaded: 2026-10-18T10:31Z
Check the source to verify that this is the current version before use.

INSTRUCTIONS: In a continuing effort to make our standardization documents better, the DoD provides this form for use in submitting comments and suggestions for improvements. All users of military standardization documents are invited to provide suggestions. This form may be detached, folded along the lines indicated, taped along the loose edge *(DO NOT STAPLE)*, and mailed. In block 5, be as specific as possible about particular problem areas such as wording which required interpretation, was too rigid, restrictive, loose, ambiguous, or was incompatible, and give proposed wording changes which would alleviate the problems. Enter in block 6 any remarks not related to a specific paragraph of the document. If block 7 is filled out, an acknowledgement will be mailed to you within 30 days to let you know that your comments were received and are being considered.

NOTE: This form may not be used to request copies of documents, nor to request waivers, deviations, or clarification of specification requirements on current contracts. Comments submitted on this form do not constitute or imply authorization to waive any portion of the referenced document*(s)* or to amend contractual requirements.

(Fold along this line)

(Fold along this line)

DEPARTMENT OF THE NAVY

NO POSTAGE NECESSARY IF MAILED IN THE UNITED STATES

OFFICIAL BUSINESS
PENALTY FOR PRIVATE USE $300

BUSINESS REPLY MAIL
FIRST CLASS PERMIT NO. 12503 WASHINGTON D. C.

POSTAGE WILL BE PAID BY THE DEPARTMENT OF THE NAVY

Commander
Naval Facilities Engineering Command (FAC 04M2C)
200 Stovall Street
Alexandria, VA 22332

12

Source: https://assist.dla.mil -- Downloaded: 2026-10-18T10:31Z
Check the source to verify that this is the current version before use.

Carol Type

STANDARDIZATION DOCUMENT IMPROVEMENT PROPOSAL

(See Instructions – Reverse Side)

1. DOCUMENT NUMBER	2. DOCUMENT TITLE
Mil-P-17739A(YD)	MILITARY SPECIFICATION PUMP UNIT, ROTARY, POWER-DRIVEN, FUEL OIL, SKID BASE MONUTED

3a. NAME OF SUBMITTING ORGANIZATION	4. TYPE OF ORGANIZATION *(Mark one)*
	☐ VENDOR
b. ADDRESS *(Street, City, State, ZIP Code)*	☐ USER
	☐ MANUFACTURER
	☐ OTHER *(Specify)*: _____

5. PROBLEM AREAS

a. Paragraph Number and Wording:

b. Recommended Wording:

c. Reason/Rationale for Recommendation:

6. REMARKS

7a. NAME OF SUBMITTER *(Last, First, MI)* – Optional	b. WORK TELEPHONE NUMBER *(Include Area Code)* – Optional
c. MAILING ADDRESS *(Street, City, State, ZIP Code)* – Optional	8. DATE OF SUBMISSION *(YYMMDD)*

(TO DETACH THIS FORM, CUT ALONG THIS LINE.)

DD FORM 82 MAR 1426 PREVIOUS EDITION IS OBSOLETE.

Source: https://assist.dla.mil -- Downloaded: 2026-10-18T10:31Z
Check the source to verify that this is the current version before use.