MIL-P-18140(SHIPS)
AMENDMENT-4
19 October 1978
SUPERSEDING
AMENDMENT-3
11 March 1964

MILITARY SPECIFICATION

PUMPS, ROTARY, FUEL OIL TRANSFER, POWER DRIVEN

This amendment forms a part of Military Specification MIL-P-18140(SHIPS), dated 29 November 1954 and is approved for use by the Naval Sea Systems Command and is available for use by all Departments and Agencies of the Department of Defense.

PAGE 1

1.2, add: "Type V - Vane (sliding)."

2.1, under "SPECIFICATIONS, FEDERAL": Delete reference to "GGG-P-15".

PAGE 2

2.1, under "SPECIFICATIONS, MILITARY": Add:

"MIL-P-24377 - Packing Material, Asbestos, Braided, Impregnated With TFF (Polytetrafluoroethylene), Surface Lubricated."

2.1, under "SPECIFICATIONS, NAVY DEPARTMENT": Delete "General Specifications for Inspection of Material."

2.1, under "DRAWINGS, BUREAU OF SHIPS": Delete reference to *13-153".

2.1, add:

"PUBLICATIONS

MILITARY
NAVSEA 0900-LP-001-7000 - Inspection and Test of Silver-Brazed Piping Systems."

PAGE 9

Add as paragraph 3.3.14.3:

"3.3.14.3 Horizontal flexibly coupled units with bedplates shall have coupling guards provided. Guards shall be designed to permit ready access to the coupling for lubrication and Inspection."

3.3.15 through 3.3.15.6: Delete and substitute:

"3.3.15 Mechanical shaft seals.

'3. 3.15.1 Pumps shall be equipped with mechanical shaft seals. Magnetic type seals shall not be used.

"3.3.15.2 In addition to the requirement for mechanical shaft seals, pump shall have a backup stuffing box to accommodate two or more *rings* of conventional or "soft" packing for emergency use in the event of mechanical shaft seal failure. Packing shall be teflon impregnated asbestos in accordance with MIL-P-24377.

"3.3.15.3 Packing rings shall be inserted without removing the mechanical shaft seal.

"3.3.15.4 Mechanical shaft seals shall be positioned on the shaft by means of stub or step sleeves. Mechanical shaft seals shall not be positioned by use of set screws.

'3.3.15.5 Positive liquid pressure shall be supplied to the seal faces under all conditions of operation and there shall be adequate circulation of the liquid at the seal faces to minimize the deposit of foreign matter on the seal parts. Pump certification data shall contain certification by the seal manufacturer that there will be adequate circulation of liquid and adequate lubrication at the seal faces when the seal is installed as shown on the drawing.

FSC 4320

Source: https://assist.dla.mil -- Downloaded: 202610-18T10:59Z
Check the source to verify that this is the current version before use.

"3. 3.15.6 The design shall be such as to insure that if seal leakage occurs, fluid cannot reach bearings or drive units. A fluid leakage collection reservoir with means for adequate drainage to a safe point shall be provided to control any leakage that might occur."

Add as paragraph 3.3.18.1.

"3.3.18.1 Silver brazed joints shall be in accordance with NAVSEA 0900-LP-001-7000. For joints 1/2 inch and above, only preinserted ring fittings shall be used."

PAGE 10

Table II- Delete and substitute:

"TABLE II. Pump characteristics.

Discharge pressure	Rated capacity	Suction lift at rated capacity 1/	Viscosity range of liquid for test purposes	Range of liquid temperatures under operating conditions 2/	Preferred type of drive
P.s.i.g.	G.p.m.	Inches of mercury	SSU		
50 - 150	100 - 1250	5 - 10	35 - 100	60 - 120	Motor or geared turbine

1/ Referred to centerline pump rotors.
2/ Temperatives do not necessarily correspond with the viscosity range, but indicate temperative pumps may be expected to encounter in service.

PAGE 12

3.8.1, Delete "type C of".

PAGE 14

4.2, delete and substitute:

"4.2 Qualification inspection. Qualification inspection shall be conducted at a laboratory satisfactory to the Naval Ship Engineering Center (NAVSEC). Qualification inspection shall consist of the tests specified in 4.2.7 through 4.2.7.2."

PAGE 15

4.2.3, item (c), line 4: Delete "Government laboratory designated by the Bureau of Ships" and substitute "laboratory satisfactory to NAVSEC."

PAGE 19

4.5, delete and substitute:

"4.5 Inspection and test of silver brazed joints in systems designated as hazardous in NAVSEA 0900-LP-001-7000 shall be in accordance with the requirements of that publication."

Add as paragraph 4.6:

"4.6 Responsibility for inspection. Unless otherwise specified in the contract, the contractor is responsible for the performance of all inspection requirements as specified herein. Except as otherwise specified in the contract, the contractor may use his own or any other facilities suitable for the performance of the inspection requirements specified herein, unless disapproved by the Government. The Government reserves the right to perform any of the inspections set forth in the specification where such inspections arc deemed necessary to assure supplies and services conform to prescribed requirements. "

Source: https://assist.dla.mil -- Downloaded: 2026-10-18T10:59Z
Check the source to verify that this is the current version before use.

NOTE: The margins of this amendment are marked "#" to indicate where changes (additions, modifications, corrections, deletions) from the previous amendment were made. This was done as a convenience only and the Government assumes no liability whatsoever for any inaccuracies in these notations. Bidders and contractors are cautioned to evaluate the requiremets of this document based on the entire content irrespective of the marginal notations Canal relationship, to the last previous amendment .

Preparing activity:
Navy - SH
(Pro ject 4320-N179)

Source: https://assist.dla.mil -- Downloaded: 2026-10-18T10:59Z
Check the source to verify that this is the current version before use.