|INCH-POUND|

MIL-R-18115D
28 October 1988
SUPERSEDING
MIL-R-18115C
17 June 1981

MILITARY SPECIFICATION

REGULATORS, BOILER-FEED WATER, AUTOMATIC

This specification is approved for use by all Departments and Agencies of the Department of Defense.

1. SCOPE

1.1 Scope. This specification covers regulators, consisting of some combination of one or more sensing devices, a flow method or device, and the necessary ancillary components to complete the system, that provide for automatic and independent control of the flow of feed water to boilers operating at steam pressures up to 1,500 pounds per square inch gage (psig) inclusive.

1.2 Classification. Boiler-feed water regulators, covered by this specification, are of the following types, classes, and styles, as specified (see 6.2):

Type I - Feed water flow control valve regulation.

Class 1 - Single element, direct-operated.

Style 1 - Thermo-mechanical or thermo-hydraulic, inclined tube drum level sensing element.
Style 2 - Float-type drum level sensing element.

Class 2 - Single element, relay-or pilot-operated.

Style 1 - Pneumatic differential pressure drum level indicating transmitter, with proportional pneumatic output signal.
Style 2 - Thermo-mechanical, inclined tube proportional level sensing element, with variable gain pneumatic output signal.
Style 3 - Electronic cell differential pressure drum level indicating transmitter, with transducer proportional pneumatic output signal.
Style 4 - Electric, float-actuated drum level sensing element, with electrical output signal.

|Beneficial comments (recommendations, additions, deletions) and any pertinent data which may be of use in improving this document should be addressed to: Commanding Officer (Code 156), Naval Construction Battalion Center, Port Hueneme, CA 93043-5000, by using the self-addressed Standardization Document Improvement Proposal (DD Form 1426) appearing at the end of this document or by letter.|

Source: https://assist.dla.mil -- Downloaded: 2026-10-18T10:59Z
Check the source to verify that this is the current version before use.

Class 3 - Two element, relay- or pilot-operated.

Style 1 - Pneumatic differential pressure inclined tube drum level and flow indicating transmitters, with proportional pneumatic output signals.
Style 2 - Electronic cell differential pressure drum level and flow transmitters, with transducer proportional pneumatic output signals.
Style 3 - Thermo-mechanical, inclined tube drum level and flow indicating transmitter proportional pneumatic output signals.

Class 4 - Three element, relay- or pilot-operated.

Style 1 - Pneumatic differential pressure inclined tube drum level and flow indicating transmitters, with proportional pneumatic output signals.
Style 2 - Electronic cell differential pressure drum level and flow transmitters, with transducer proportional pneumatic output signals.
Style 3 - Thermo-mechanical, inclined tube drum level and flow indicating transmitter proportional pneumatic output signals.

Type II - Feed-pump motor start-stop regulation, single-element, direct-operated, with float-type drum level sensing element.

Type III - Feed-pump motor start-stop regulation, single-element, relay- or pilot-operated, with electrical probe drum level sensing element.

2. APPLICABLE DOCUMENTS

2.1 Government documents.

2.1.1 Specifications and standards. The following specifications and standards form a part of this document to the extent specified herein. Unless otherwise specified, the issues of these documents are those listed in the issue of the Department of Defense Index of Specifications and Standards (DODISS) and supplement thereto, cited in the solicitation (see 6.2).

SPECIFICATIONS

MILITARY

MIL-V-173 - Varnish, Moisture and Fungus Resistant (for Treatment of Communications, Electronic, and Associated Equipment).
MIL-B-3180 - Boiler and Related Equipment, Packaging of.

Source: https://assist.dla.mil -- Downloaded: 202610-18T10:59Z
Check the source to verify that this is the current version before use.

STANDARD

MILITARY

MIL-STD-105 - Sampling Procedures and Tables for Inspection by Attributes.

(Unless otherwise indicated, copies of federal and military specifications are available from the Naval Publications and Forms Center, (ATTN: NPODS), 5801 Tabor Avenue, Philadelphia, PA 19120-5099.)

2.2 Non-Government publications. The following documents form a part of this document to the extent specified herein. Unless otherwise specified, the issues of the documents which are DoD adopted are those listed in the issue of the DODISS cited in the solicitation. Unless otherwise specified, the issues of documents not listed in the DODISS are the issue of the documents cited in the solicitation (see 6.2).

AMERICAN NATIONAL STANDARDS INSTITUTE, INC. (ANSI)

ANSI B16.1 - Cast Iron Pipe Flanges and Flanged Fittings, Class 25, 125, 250, and 800.
ANSI B16.5 - Pipe Flanges and Flanged Fittings.
ANSI B16.24 - Bronze Pipe Flanges and Flanged Fittings Class 150 and 300.
ANSI B36.10M - Welded and Seamless Wrought Steel Pipe.

(Application for copies should be addressed to the American National Standards Institute 1430 Broadway, New York, NY 10018.)

AMERICAN SOCIETY FOR TESTING AND MATERIALS (ASTM)

ASTM A 126 - Gray Iron Castings for Valves, Flanges, and Pipe Fittings.
ASTM B 61 -Steam or Valve Bronze Castings.
ASTM B 62 -Composition Bronze or Ounce Metal Castings.

(Application for copies should be addressed to the American Society for Testing and Materials, 1916 Race Street, Philadelphia, PA 19103.)

AMERICAN SOCIETY OF MECHANICAL ENGINEERS (ASME)

Boiler and Pressure Vessel Code.
Section II-A - Material Specifications, Part A - Ferrous.

(Application for copies should be addressed to the American Society of Mechanical Engineers, 345 East 47th Street, New York, NY 10017.)

Source: https://assist.dla.mil -- Downloaded: 2026-10-18T10:59Z
Check the source to verify that this is the current version before use.

FACTORY MUTUAL ENGINEERING AND RESEARCH CORPORATION (FM)

Approval Guide.

(Application for copies should be addressed to the Factory Mutual Engineering and Research Corporation, 1151 Boston-Providence Turnpike, P. O. Box 9102, Norwood, MA 02062.)

FLUID CONTROLS INSTITUTE, INC. (FCI)

70-2 - Standard for Control Valve Seat Leakage.

(Application for copies should be addressed to the Fluid Controls Institute, Inc., 31 South Street, Suite 303, P. O. Box 9036, Morristown, NJ 07960.)

MANUFACTURERS STANDARDIZATION SOCIETY OF THE VALVE AND FITTINGS INDUSTRY, INC. (MSS)

SP 25 - Standard Marking System for Valves, Fittings, Flanges, and Unions. (DoD adopted)

(Application for copies should be addressed to the Manufacturers Standardization Society of the Valve and Fittings Industry, Inc., 127 Park St, N.E., Vienna, VA 22180.)

NATIONAL FIRE PROTECTION ASSOCIATION (NFPA)

70 - National Electrical Code.

(Application for copies should be addressed to the National Fire Protection Association, Batterymarch Park, Quincy, MA 02269.)

UNDERWRITERS LABORATORIES INC. (UL)

UL 353 - Limit Controls.
Gas and Oil Equipment Directory.

(Application for copies should be addressed to the Underwriters Laboratories Inc., 333 Pfingsten Road, Northbrook, IL 60062.)

(Non-Government standards and other publications are normally available from the organizations that prepare or distribute the documents. These documents also may be available in or through libraries or other informational services.)

2.3 Order of precedence. In the event of a conflict between the text of this specification and the references cited herein (except for associated detail specifications, specification sheets or MS standards), the text of this specification takes precedence. Nothing in this specification, however, supersedes applicable laws and regulations unless a specific exemption has been obtained.

Source: https://assist.dla.mil -- Downloaded: 2026-10-18T10:59Z
Check the source to verify that this is the current version before use.

3. REQUIREMENTS

3.1 Description. Feed water regulators shall include all of the required sensing, actuating, regulating, controlling elements, and components necessary to establish an automatic system to maintain the proper water level in boilers operating under the conditions as specified herein. Unless otherwise specified (see 6.2), the regulators shall accomplish this function independent of the volume and pressure of the forced draft and fuel oil being supplied to the boiler, for expected use in conjunction with, and as part of, a complete boiler automatic combustion control system. The regulators shall be provided complete with all accessory fittings, piping, tubing, mechanical linkages, wiring, or other materials or parts required to connect the operating components in such a manner as to permit the regulators to perform their designed function. The basic requirements for compliance with the classifications established in 1.2 are as follows.

3.1.1 Regulating valve. Regulating valve regulators shall control the feed water input by automatically positioning a feed water control regulating valve. The regulator shall be provided with a bypass around the regulating valve. The regulating valve shall be equipped with a handwheel or knob for manual control and operation, and shall incorporate the manufacturer's standard position indicator.

3.1.2 Feed-pump motor start-stop. Feed-pump motor start-stop regulators shall control the feed water by making and breaking electrical contacts to start and stop the feed-pump motor.

3.1.3 Single-element. Single-element regulators shall position a regulating valve in response to changes of water level in the boiler steam drum.

3.1.4 Two-element. Two-element regulators shall position a regulating valve in response to changes of water level in the steam drum, as well as changes in the rate of steam flow from the boiler.

3.1.5 Three-element. Three-element regulators shall position a regulating valve in response to changes of water level in the steam drum, changes in the rate of steam flow and changes in the rate of feed water flow to the boiler. Three-element regulators should consist of two independent controllers; one to control water flow and changing drum level, and the other to control rapid changes in steam and water flow.

3.1.6 Direct-operated. Direct-operated regulators shall have self-contained power transmission systems, which will position the regulating valve or control the feed-pump motor using power developed in the actuating element(s).

Source: https://assist.dla.mil -- Downloaded: 2026-10-18T10:59Z
Check the source to verify that this is the current version before use.

3.1.7 Relay- or pilot-operated. Relay- or pilot-operated regulators shall have power transmission systems employing a relay or pilot mechanism which utilizes a source of auxiliary hydraulic, pneumatic, or electric power, as specified (see 6.2), to position the regulating valve or control the feed-pump motor. For type I, class 2, 3, or 4 regulators, the auxiliary power shall be in accordance with the style specified in 1.2.

3.1.8 Thermostatic elements. Thermostatic elements for drum water level control shall consist essentially of a thermostat having a concentrically inclined element complete with an inner chamber and an outer chamber. The inner chamber shall be designed for connection above and below the drum water level. The outer chamber shall be designed for connection on type I, class 1 regulators by hydraulic or mechaincal linkage directly to the regulating valve, and on type I, class 2, 3, and 4 regulators, through a relay furnished integrally with the thermostat. The heat emitted from the inner chamber in response to changes in the drum water level shall provide a proportional, mechanical, or hydraulic force in the outer chamber.

3.1.9 Float-elements. Direct-operated, float-actuated regulators shall include a float chamber with an integrally furnished control valve connected directly by mechanical linkage to the float. Relay-operated float controls shall include an electric proportioning control having a slide-wire-type potentiometer connected by mechanical linkage to the float. The proportioning control shall send a signal in response to changes in the drum water level to modulate the feed water flow control regulating valve or to make and break the feed-pump motor electrical contacts.

3.1.10 Pressure elements. Pressure elements shall be designed for connection above and below the drum water level and shall transmit an ouput pneumatic signal directly proportional to the drum level. The signal from the level transmitter shall be received by a level control relay and sent through a manual-automatic station, if specified (see 3.14.2), to the feed water flow control regulating valve.

3.2 Standard commercial product. The regulator shall, as a minimum, be in accordance with the requirements of this specification and shall be the manufacturer's standard commercial product. Additional or better features which are not specifically prohibited by this specification but which are a part of the manufacturer's standard commercial product, shall be included in the regulator being furnished. A standard commercial product is a product which has been sold or is being currently offered for sale on the commercial market through advertisements or manufacturer's catalogs, or brochures, and represents the latest production model.

3.3 First article. When specified (see 6.2), a sample shall be subjected to first article inspection (see 6.5) in accordance with 4.2.1.

Source: https://assist.dla.mil -- Downloaded: 2026-10-18T10:59Z
Check the source to verify that this is the current version before use.

3.4 Materials. Materials used shall be free from defects which would adversely affect the performance or maintainability of individual components or of the overall assembly. Materials not specified herein shall be of the same quality used for the intended purpose in commercial practice. Unless otherwise specified herein, all equipment, material, and articles incorporated in the work covered by this specification are to be new and fabricated using materials produced from recovered materials to the maximum extent possible without jeopardizing the intended use. The term "recovered materials" means materials which have been collected or recovered from solid waste and reprocessed to become a source of raw materials, as opposed to virgin raw materials. None of the above shall be interpreted to mean that the use of used or rebuilt products are allowed under this specification unless otherwise specified.

3.4.1 Cast-iron. Cast-iron shall have mechanical properties equal to or better than class B of ASTM A 126.

3.4.2 Steel. Carbon steel, alloy steel, and corrosion-resistant steel for control valve bodies and other pressure-containing parts shall be of a type and grade specified in ANSI B16.5 for the applicable pressures and temperatures.

3.4.3 Copper alloys. Brass or bronze castings shall conform to ASTM B 61 or B 62.

3.5 Interchangeability. All units of the same classification furnished with similar options under a specific contract shall be identical to the extent necessary to ensure interchangeability of component parts, assemblies, accessories, and spare parts.

3.6 Design. The regulators shall be designed for installation as integral components on new packaged or field-erected boilers being furnished under separate specifications or as replacement regulators on existing boilers. In either case, the regulators shall be of the classification specified (see 1.2), and shall be designed to satisfy the performance requirements of 3.8 and to function under the following operating conditions, as specified in the contract (see 6.2):

a. Type, make, and model of boiler, if known.
b. Steam drum pressure (psig).
c. Maximum peak rating of boiler in pounds per hour.
d. Type of load (steady, moderately fluctuating, rapidly fluctuating).
e. Final steam temperature and superheater pressure drop at maximum flow.
f. Maximum and minimum pressure at inlet to feed water regulating valve.
g. Feed water temperature.

Source: https://assist.dla.mil -- Downloaded: 2026-10-18T10:59Z
Check the source to verify that this is the current version before use.

3.7 Safety. The regulator shall comply with the applicable requirements of UL 353 or shall be listed in the FM Approval Guide.

3.8 Performance. Unless otherwise specified (see 6.2), type I, class 1, style 2, and class 2, style 4, type II and type III single-element regulators, selected in accordance with 3.6 and 6.1, shall maintain the boiler water level under all conditions, within ±1 inch of the boiler manufacturer's established boiler water level. Type I, class 1, style 1, and class 2, style 1, 2, and 3 single-element regulators shall maintain the boiler water level under all conditions, within ±2 inches of the boiler manufacturer's established boiler steaming water level. Type I, class 3 and class 4, two- and three-element regulators shall maintain the boiler water level under all conditions, within ±2 inches of the high water level and within ±2 inches of the low water level set points prescribed by the boiler manufacturer.

3.9 End connections. The end connections of valves and fittings to be connected to the feed pipe, boiler components, or boiler fittings shall be as follows:

3.9.1 Size. The nominal sizes for end connections shall be 1/2, 3/4, 1, 1-1/4, 1-1/2, 2, 3, 4, 5, 6, 8, 10, and 12 inches pipe size and 14 and 16 inches outside diameter. The nominal sizes provided for both the feed pipe and the boiler connections shall be as recommended by the manufacturer for the proper installation and operation of his product under the conditions specified herein.

3.9.2 Type. The type of end connections provided shall be as specified (see 6.2), in accordance with the following limitations:

3.9.2.1 Size and pressure limits. Connecting ends shall be of the following types:

a. For pressures not exceeding 600 psig, end connections shall be welded end type or flanged end type, except that size 2 inches nominal size and under may be threaded end (female).
b. For pressures exceeding 600 psig, end connections shall be welded end type.

3.9.3 Flange and bolt dimensions. For flanged valves or fittings, the flange dimensions, dimensions for bolt holes, and the number and size of the bolts shall conform to ANSI B16.5. The face-to-face dimensions shall be the manufacturer's standard dimensions.

3.10 Regulating valve assembly. The regulating valve assembly shall be of the size recommended by the contractor for the boiler operating conditions specified in accordance with 3.6 and the contract. The valve flange dimensions shall conform to the requirements of ANSI B16.1, B16.5, or B16.24, as applicable, with respect to maximum pressure and temperature ratings based on the materials for pressure-enclosing parts in 3.11.1.

Source: https://assist.dla.mil -- Downloaded: 202610-18T10:59Z
Check the source to verify that this is the currentversion before use.

3.10.1 Body. The valve body shall be cast-iron, semi-steel, cast steel, or bronze conforming to the material requirememts of 3.5. The valve body shall withstand the hydrostatic test pressure specified in the ANSI standard listed in 3.10 applicable to the material used.

3.10.2 Valve seats, cages, and valves. Valve seats, cages, and valves shall be fabricated of corrosion-resistant steel, nickel-copper alloy, aluminum bronze or silicon-copper alloy, or any combination thereof. Corrosion-resistant steel for components not requiring heat treatment shall conform to any of the 300 series steels having a nominal chromium and nickel content of not less than 18 and 8 percent, respectively. Corrosion-resistant steel for components requiring hardenability treatment shall be an appropriate steel in the 400 series. In lieu thereof, commercial precipitation-hardened corrosion-resistant steel containing 17 percent chromium, 4 percent nickel, and 4 percent copper may be used. Alternate materials having properties equally suitable for the intended application may be used, subject to the approval of the contracting officer. Metal combinations shall display high resistance to seizure, galling, abrasion, and galvanic action. Seats and cages shall be so assembled with the valve body so that they cannot come loose under operating conditions. Leakage between the seat or cage and the valve body shall not exceed maximum seat leakage specified in FCI 70-2, class II. Valves shall be of the double-seated or fully- balanced piston type. Double-seated valves shall have disks and seats ground to a fit which will ensure minimum leakage at the operating temperature in accordance with FCI 70-2, class II. Piston-type valves shall fit their bore with the minimum clearance compatible with nonbinding sliding. The motion of double-seated and piston-type valves shall be constrained in such a manner that lateral thrust sufficient to cause appreciable increase in sliding resistance shall not develop.

3.10.3 Valve stems. Valve stems may be integral with or separable from the valve disk. Stems shall be fabricated of one of the materials specified in 3.10.2.

3.10.4 Seals. Valve stems and shafts which pass from one pressure zone to another shall be sealed against visible leakage. Packing materials shall not stick to or score stems or shafts. Grease used for sealing and packing materials shall not react chemically with the materials of the stuffing box, stem, or shaft. Unless otherwise specified (see 6.2), the manufacturer's standard seal material shall be used.

3.10.5 Valve actuators. When the valve assembly provided contains a valve actuator, the actuating device shall move the valve to its correct position without hunting, chattering, or sticking. The valve actuator shall be one of the following types, depending on the style or control medium specified in 3.1.7:

a. A hydraulic motor of the diaphragm, bellows, or piston type,
b. A pneumatic motor of the diaphragm, bellows, or piston type,
c. An electic motorized valve assembly, or
d. An electric switching device.

Source: https://assist.dla.mil -- Downloaded: 202610-18T10:59Z
Check the source to verify that this is the currentversion before use.

3.10.5.1 Diaphragms. Diaphragm plates and other parts against which the diaphragm flexes shall be smooth and well-rounded. The design shall be such that the diaphragm will not be subject to injurious twisting, wrinkling, or cutting, and will be such as to ensure ease of replacement by field maintenance personnel.

3.10.5.2 Metal bellows. Metal bellows shall be of nickel-copper alloy, phosphor-bronze, or corrosion-resistant steel.

3.10.5.3 Piston and cylinder. The piston shall be of the double-cup, piston ring, or plain cylinder type, or a flat disk on which a rim of synthetic rubber is bonded. The piston shall be mounted and held rigidly in place on a shouldered rod. Cups shall be of molded leather, synthetic rubber, or other material suitable for the intended use. Piston rings shall be carefully fitted so that clearances will have the smallest value compatible with nonbinding sliding. Cylinders shall be of bronze, cast iron, or steel.

3.11 Level-sensing element. Unless otherwise specified (see 6.2), the level-sensing element shall consist of a hollow float-type assembly, a thermo-mechanical expansion device, an electrical probe assembly, a pneumatic inclined tube, or electronic cell differential pressure indicating transmitter, or a thermo-hydraulic pressure generator that utilizes the expansive force of steam or a volatile liquid in accordance with the type, class, and style in 1.2. The element shall be mounted on or to the boiler in a location as determined by the manufacturer to ensure proper operation of the regulators and provide for ease of maintenance, or any necessary adjustments by operating personnel, with minimized required downtime against boiler service use.

3.11.1 Pressure-enclosing parts. Pressure-enclosing parts such as float chambers and pressure generators, shall be made of materials conforming to the ASME Boiler and Pressure Vessel Code, Section II-A. The materials and parts shall be selected as follows:

a. Steel parts shall be required for pressures exceeding 250 psig.
b. Materials for which the allowable stress values (as listed in, or determined by the method used in the ASME Boiler and Pressure Vessel Code, Section II-A) decrease 25 percent or more, between 100 degrees Fahrenheit, and the maximum operating temperature specified herein, shall not be used.
c. In no case shall a material or part be used for pressures or temperatures in excess of those permitted by the applicable material or part specification or standard.

3.11.1.1 Wall thickness. The wall thickness of float cages and other cast parts shall not be less than that required by the applicable ANSI standard as specified in 3.10. The wall thickness of tubular components for use with pressure exceeding 250 psig shall not be less than that required by schedule 80 of ANSI B36.10.

Source: https://assist.dla.mil -- Downloaded: 2026-10-18T10:59Z
Check the source to verify that this is the current version before use.

3.11.1.2 Hydrostatic test pressures. All pressure-enclosing parts shall withstand hydrostatic tests at test pressures of not less than twice the boiler design pressure. When the hydrostatic test pressure required by the applicable ANSI standard or by component specifications exceeds twice the designed operating pressure of the boiler, the higher test pressure shall be used. Complete assemblies of pressure enclosed systems shall withstand hydrostatic test pressures of at least 150 percent of boiler design pressure at boiler design temperature.

3.11.2 Floats. Copper floats may be used in float type regulators for use on boilers where the maximum steam drum pressure does not exceed 250 psig. Corrosion-resistant steel or nickel-copper floats shall be provided for steam from pressures exceeding 250 psig. All floats shall be capable of withstanding an external pressure of twice the maximum steam drum pressure.

3.11.3 Rods and stems. Float rods shall be of corrosion-resistant metal. Stems shall be of corrosion-resistant steel. Rotating stems for float-actuated regulators shall be supported by antifriction bearings capable of supporting both radial and thrust loads.

3.11.4 Stem-seals. Stem-seals shall conform to 3.10.4. When specified (see 6.2), stuffing boxes shall be provided with radiating bonnets.

3.11.5 Electrodes, electrode-holders, and insulating plugs. Electrodes shall be brass rod or corrosion-resistant steel rod, as specified (see 6.2). Electrodes shall be suitably insulated and equipped so that short-circuiting cannot occur by direct contact of electrodes with each other or through an intermediate metal, such as boiler metal or electrode-holders or due to excessive corrosion and scale build up across the electrode insulator to the boiler shell. Insulation on plugs shall be of mica or other insulation suitable for use with steam at the specified operating temperature and pressure. Insulating plugs shall be protected from mechanical injury and dust by a suitable enclosure, provided with a removable access plate to allow inspection of the insulating plugs and electrical connections thereto.

3.11.6 Electric switches. When used in level-sensing elements, electric switches shall be of a design which will permit adjustment of the cut-in and cut-out points, and their action shall be suitable for the particular application. The electrical capacity characteristics of the switches shall be suitable for the available power supply specified (see 6.2). The voltage shall not exceed 120 volts (V). Type I, class 2, style 4 level-sensing elements and types II and III feed-pump motor starters shall conform to UL 353. The listing or approval for listing under limit controls, group H of the UL Gas and Oil Equipment Directory, will be acceptable as evidence of compliance with UL 353.

3.12 Steam-flow sensing elements. Type I, class 3 and 4 steam-flow sensing elements shall be operated by the differences in pressure between two points in the flow from the boiler. The output movement or pressure from the element shall act on a relay- or pilot-mechanism used for controlling the application of auxiliary power in such a way that the specified performance

Source: https://assist.dla.mil -- Downloaded: 2026-10-18T10:59Z
Check the source to verify that this is the current version before use.

shall be met. Wearing parts shall be designed for long-life, low-friction operation and shall be of corrosion-resistant materials. Springs shall be of phosphor bronze, carbon steel, or corrosion-resistant steel. Carbon steel springs shall be rendered corrosion resistant. The ends of helical springs shall be closed and ground. Fluid passages shall be smooth and free of any tendency to become clogged.

3.13 Water-flow sensing elements. Type I, class 4 water-flow sensing elements shall modify the positioning of the feed water regulating valve to compensate for changes in water-supply flow. The effect of the water-flow element shall be applied to the pilot-mechanism used for controlling the application of auxiliary power in such a way that the specified performance shall be met. Wearing parts, springs, and fluid passages shall be as specified in 3.12.

3.14 Relay- or pilot-mechanism. The relay- or pilot-mechanism, when specified (see 1.2, 3.1.7, and 6.2), shall coordinate the effects of the level-sensing element, the steam-flow sensing element, and the water-flow sensing element of three-element regulators or the effects of the water-level sensing element and the steam-flow sensing element of two-element regulators into a single effect, or shall use the effect of the water-level sensing element alone for single-element regulators. The single effect, so obtained, shall control the application of auxiliary pneumatic, hydraulic, or electric power, as specified herein, in such a way that the performance specified shall be met. The relay- or pilot-mechanism shall operate to meet the performance requirements of 3.8 and shall not cause hunting, cycling, or fluttering of the regulating valve. Operating parts shall be suitably enclosed for protection from mechanical injury and contamination caused by ingestion of undesirable foreign materials, and shall be designed for long-life and reliable performance under the anticipated environmental operating conditions.

3.14.1 Lock-in devices. When specified (see 6.2), relay- or pilot-operated regulators used in conjunction with a regulating valve type shall be equipped with a lock-in device which will automatically lock the valve in the then-exsisting position in case of auxiliary power failure. The lock-in device shall be equipped with an automatic or manual release, as specified (see 6.2), which will unlock the valve when power is restored.

3.14.2 Manual-automatic selector panel. When specified (see 6.2), relay- or pilot-operated regulators used in conjunction with a regulating valve shall be provided with a manual-automatic selector panel. A device for transferring the regulator instantly from automatic to manual control and vice-versa, a control mechanism for adjusting the control pressure, and at least two flush-mounted gages to show pressures of the operating medium shall be mounted on the panel. The position of the transfer device shall be clearly indicated by suitable markings on the panel. The direction in which the control mechanism should be operated to raise or lower the water level shall be clearly indicated. The transfer device and operating mechanism shall be free of sharp projections easily caught by clothing, and shall be adequately designed or guarded such as to require a definitive action on the part of the operator and

Source: https://assist.dla.mil -- Downloaded: 202610-18T10:59Z
Check the source to verify that this is the current version before use.

to minimize the dangers of inadvertent or accidental activation. When specified (see 6.2), the panel shall be supplied with an integral, battery-operated auxiliary lighting circuit, to enable the operator to adequately see all controls and gages in the event of a power outage resulting in a loss of normal operating space lighting and which shall automatically activate under such conditions.

3.15 Connecting tubing, linkages, and wiring. Unless otherwise specified (see 6.1 and 6.2), as to specific installation distances, the tubing, linkages, wiring, or other connecting elements used to connect the operating components shall be of suitable length for the boiler type and make.

3.15.1 Instrument and control piping. The materials used for instrument and control piping shall be in accordance with 3.11.1. Hydrostatic requirements shall be in accordance with 3.11.1.2, except that the operating pressure for the particular system shall be used, in lieu of the boiler design pressure, as the basis for requirements.

3.15.2 Mechanical linkages. Mechanical linkages shall operate easily and without lost motion, buckling, or other distortion. Bearing surfaces of joints shall be designed for low-friction operation.

3.15.3 Electrical wiring. Electrical wiring shall be in accordance with UL 353. The size of the conductors used shall be in accordance with NFPA 70 for the current characteristics specified. The types of conductors used shall be chosen in accordance with the temperature rises permitted by UL 353 and the expected heat of the insulation. Circuits shall not exceed either a two-wire nominal 120V system with equipment ground conductor or a two-wire nominal 120V system obtained by using an insulation transformer with one side grounded.

3.16 Operating liquids. Operating liquids, such as hydraulic oil or mercury, shall not react chemically with the materials with which they come into contact in normal operation and shall have physical and chemical stability over the range of temperature and pressure conditions normally encountered in service.

3.17 Electrical components. Electrical components, when used, shall be in accordance with UL 353.

3.18 Fungus resistance. When specified (see 6.2), electrical components and circuit elements, including terminal and circuit connections, shall be coated with varnish conforming to MIL-V-173, except that:

a. Components and elements inherently inert to fungi or in hermetically sealed enclosures need not be coated.
b. Current-carrying contact surfaces, such as relay contact points, shall not be coated.

Source: https://assist.dla.mil -- Downloaded: 2026-10-18T10:59Z
Check the source to verify that this is the current version before use.

3.19 Lubrication. Means for lubricating shall be provided in accordance with the manufacturer's standard practice. Parts requiring lubrication shall be so located as to make the lubricating points easily visible and accessible. All parts requiring lubrication shall be properly lubricated before delivery.

3.20 Marking. The regulating valve body shall be marked in accordance with MSS SP 25. The regulator shall be marked in accordance with UL 353 or FM requirements.

3.21 Workmanship.

3.21.1 Steel fabrication. The steel used in fabrication shall be free from kinks, sharp bends, and other conditions which would be deleterious to the finished product. Manufacturing processes shall not reduce the strength of the steel to a value less than intended by the design. Manufacturing processes shall be done neatly and accurately. All bends shall be made by controlled means to ensure uniformity of size and shape.

3.21.2 Bolted connections. Boltholes shall be accurately punched or drilled and shall have the burrs removed. Washers or lockwashers shall be provided in accordance with good commercial practice, and all bolts, nuts, and screws shall be tight.

3.21.3 Riveted connections. Rivet holes shall be accurately punched or drilled and shall have the burrs removed. Rivets shall be driven with pressure tools and shall completely fill the holes. Rivet heads, when not countersunk or flattened, shall be of approved shape and of uniform size for the same diameter of rivet. Rivet heads shall be full, neatly made, concentric with the rivet holes, and in full contact with the surface of the member.

3.21.4 Welding. Welding procedures shall be in accordance with a nationally recognized welding code. The surface of parts to be welded shall be free from rust, scale, paint, grease, or other foreign matter. Welds shall be of sufficient size and shape to develop the full strength of the parts connected by the welds. Welds shall transmit stress without permanent deformation or failure when the parts connected by the weld are subjected to proof and service loadings.

3.21.5 Castings. All castings shall be sound and free from patching, misplaced coring, warping, or any other defect which reduces the castings ability to perform its intended function.

4. QUALITY ASSURANCE PROVISIONS

4.1 Responsibility for inspection. Unless otherwise specified in the contract or purchase order, the contractor is responsible for the performance of all inspection requirements (examinations and tests) as specified herein. Except as otherwise specified in the contract or purchase order, the contractor may use his own or any other facilities suitable for the

Source: https://assist.dla.mil -- Downloaded: 202610-18T10:59Z
Check the source to verify that this is the current version before use.

performance of the inspection requirements specified herein, unless disapproved by the Government. The Government reserves the right to perform any of the inspections set forth in the specification where such inspections are deemed necessary to ensure supplies and services conform to prescribed requirements.

4.1.1 Responsibility for compliance. All items shall meet all requirements of sections 3 and 5. The inspection set forth in this specification shall become a part of the contractor's overall inspection system or quality program. The absence of any inspection requirements in the specification shall not relieve the contractor of the responsibility of ensuring that all products or supplies submitted to the Government for acceptance comply with all requirements of the contract. Sampling inspection, as part of manufacturing operations, is an acceptable practice to ascertain conformance to requirements, however, this does not authorize submission of known defective material, either indicated or actual, nor does it commit the Government to accept defective material.

4.1.2 Material inspection. The contractor is responsible for ensuring that supplies and materials are inspected for compliance with all the requirements specified herein and in applicable referenced documents.

4.1.3 Component and material inspection. Components and materials shall be inspected in accordance with all the requirements specified herein and in applicable referenced documents.

4.2 Classification of inspections. The inspection requirements specified herein are classified as follows:

a. First article inspection (see 4.2.1).
b. Quality conformance inspection (see 4.2.2).

4.2.1 First article inspection. The first article inspection shall be performed on one complete regulator when a first article is required (see 3.3 and 6.2). This inspection shall include the examination of 4.4 and the tests of 4.5. The first article may be either a first production item or a standard production item from the supplier's current inventory provided the item meets the requirements of the specification and is representative of the design, construction, and manufacturing technique applicable to the remaining items to be furnished under the contract.

4.2.2 Quality conformance inspection. The quality conformance inspection shall include the examination of 4.4, the tests of 4.5.2, and the packaging inspection of 4.5.3. This inspection shall be performed on the samples selected in accordance with 4.3.

4.3 Sampling. Sampling and inspection procedures shall be in accordance with MIL-STD-105. The unit of product shall be one complete regulator. All regulators offered for delivery at one time shall be considered a lot for the purpose of inspection. If an inspection lot is rejected, the contractor may

Source: https://assist.dla.mil -- Downloaded: 2026-10-18T10:59Z
Check the source to verify that this is the current version before use.

rework it to correct the defects, or screen out the defective units, and resubmit for a complete reinspection. Resubmitted lots shall be reinspected using tightened inspection. If the rejected lot was screened, reinspection shall be limited to the defect causing rejection. If the lot was reprocessed, reinspection shall be performed for all defects. Rejected lots shall be separate from new lots, and shall be clearly identified as reinspected lots.

4.3.1 Sampling for examination. Examination shall be based on inspection level S-3 and an Acceptable Quality Level (AQL) of 2.5 percent for major defects and 4.0 for minor defects.

4.3.2 Sampling for tests. Tests shall be based on inspection level S-4 and an AQL of 4.0 percent defective.

4.4 Examination. Each regulator shall be examined for compliance with the requirements specified in section 3 of this specification. Any redesign or modification of the contractor's standard product to comply with specified requirements, or any necessary redesign or modification following failure to meet specified requirements shall receive particular attention for adequacy and suitability. This element of inspection shall encompass all visual examinations and dimensional measurements. Noncompliance with any specified requirements or presence of one or more defects preventing or lessening maximum efficiency shall constitute cause for rejection.

4.5 Tests.

4.5.1 Performance tests. The first article, when furnished, shall be completely assembled on a test boiler or other test set-up which can be used to properly simulate the specified boiler operating conditions and feed water pressure. The sample regulator shall then be tested for proper operation in strict compliance with the provisions of 3.8 for the operating conditions specified. Failure to hold the specified water levels under the load and operating conditions specified, and other evidence of noncompliance or unsuitability shall be cause for rejection.

4.5.2 Hydrostatic tests. The first article, when furnished, and regulating valves, pressure-enclosing components, hydraulic and pneumatic control piping, fittings, and valves selected in accordance with 4.3.2 shall be subjected to hydrostatic tests in accordance with 3.10.1, 3.11.1.2, and 3.15.1, as applicable. Floats shall be subjected to an external pressure test in accordance with 3.11.2. The hydrostatic tests may be conducted on individual components or on assemblies. The test pressure shall be maintained for a sufficient length of time to permit a thorough inspection of all parts, joints, and connections. Any evidence of leakage or deformation shall be cause for rejection.

4.5.3 Component operating tests. The first article, when furnished, and all operating components such as regulating valves, actuating elements, pilot valves, switches, and other electrical components selected in accordance with 4.3.2, shall be shop tested either as individual components or as systems, as

Source: https://assist.dla.mil -- Downloaded: 2026-10-18T10:59Z
Check the source to verify that this is the current version before use.

necessary and practicable, to determine their operating ability and condition. Average or normal operating pressures shall be used and the ease and speed of operating shall be checked. Sluggishness of operating and failure to operate shall be cause for rejection.

4.6 Packaging inspection. The inspection of the preservation, packing, and marking shall be in accordance with the requirements of section 4 of MIL-B-3180. The inspection shall consist of the quality conformance inspection; and, when specified (see 6.2), a preproduction pack shall be furnished, within the time frame required, for examination and tests.

5. PACKAGING

5.1 Preservation, packing, and marking. The regulators shall be preserved, packed, and marked in accordance with MIL-B-3180. The level of preservation, and level of packing shall be as specified (see 6.2).

6. NOTES

(This section contains information of a general or explanatory nature that may be helpful, but is not mandatory.)

6.1 Intended use. The regulators specified herein are intended for use on stationary boilers in power plant or heating installations. The boiler type, model, and make should be specified if known, so that the manufacturer can provide connection elements of the exact length required. Exact desired installation distances and locations should not be specified (see 3.15), unless connection to existing boiler fittings is considered mandatory. Such location requirements may limit bidding because optimum manufacturer's instructions, which may or may not permit connection to existing fittings when changing from one type or manufacture of regulator to another. The type and class of regulator should be selected in accordance with the following:

a. Generally, type I level sensing elements should not be specified when the boiler pressue exceeds 250 psig for relay- or pilot-operated, single- or two-element installations, or when the regulating valve is larger than 3 inches pipe size, or when the pressure differential at the regulating valve (feed water pressure less boiler pressure) normally exceeds the following:

Nominal pipe size, inches	1/2	3/4	1	1-1/4	1-1/2	2	3
Normal pressure differential, psi	50	50	40	30	20	15	10

b. Types II and III level sensing elements should not be specified when the boiler pressure exceeds 250 psig.
c. Direct-operated regulators should not be used when any of the following conditions exist:

Source: https://assist.dla.mil -- Downloaded: 2026-10-18T10:59Z
Check the source to verify that this is the current version before use.

(1) Water supply pressure exceeds 900 psig.
(2) Water supply pressure exceeds 600 psig and regulator valve size is greater than 2-1/2 inches.
(3) The pressure drop across the regulator-valve normally exceeds 100 psi and the regulator valve size is larger than 4 inches pipe size.
(4) The regulator-valve size is larger than 5 inches pipe size.
(5) The pressure differential at the regulator valve normally exceeds 150 psig.

d. Single-element regulators should not be specified when either of the following conditions exist:

(1) The weight of water in the boiler drum is less than 30 percent of the total weight of water in the boiler.
(2) The boiler normally operates with frequent rapid load-swings greater than 10 percent per minute of normal rating.

6.2 Acquisition requirements. Acquisition documents must specify the following:

a. Title, number, and date of this specification.
b. Type, class, and style required (see 1.2).
c. Issue of DODISS to be cited in the solicitation, and if required, the specific issue of individual documents referenced (see 2.1.1 and 2.2).
c. When intended use is to be as part of a complete boiler automatic combustion control system (see 3.1).
e. Whether relay- or pilot-operated regulators shall be hydraulic, pneumatic, or electric (see 3.1.7 and 3.14).
ff When a first article inspection is required (see 3.3, 4.2.1, and 6.5).
g. Type, make, and model of boiler on which regulator will be installed (if known) and operating conditions (see 3.6).
h. Limits for boiler water level control, if different (see 3.8).
i. Type of connection ends required (see 3.9.2).
j. Type of material for seal, if different (see 3.10.4).
k. Type of level-sensing element, if different (see 3.11).
l. When radiating bonnets are required on stuffing boxes for level measuring devices (see 3.11.4).
m. Whether brass rod or corrosion-resistant steel is required for electrodes on type III regulators (see 3.11.5).
n. Electrical supply characteristics available for electric level sensing elements (see 3.11.6).
o. When lock-in device is required for relay- or pilot-operated regulators and whether the release shall be automatic or manual (see 3.14.1).
p. When manual-automatic selector panel is required for relay- or pilot-operated regulators and whether the panel shall incorporate auxiliary lighting circuitry (see 3.14.2).

Source: https://assist.dla.mil -- Downloaded: 202610-18T10:59Z
Check the source to verify that this is the currentversion before use.

q. When installation distances for tubing, wiring, linkages, and other connecting elements are established (see 3.15).
r. When treatment for fungus is required (see 3.18).
s. When a preproduction pack is required and the time frame required for submission (see 4.6).
t. Level of preservation and level of packing required (see 5.1).

6.3 Data requirements. When this specification is used in an acquisition and data are required to be delivered, the data requirements shall be developed as specified by an approved Data Item Description (DD Form 1664) and delivered in accordance with the approved Contract Data Requirements List (CDRL), incorporated into the contract. When the provisions of DOD FAR Supplement, Part 27, Sub-Part 27.475-1 (DD Form 1423) are invoked and the DD Form 1423 is not used, the data should be delivered by the contractor in accordance with the contract or purchase order requirements.

6.4 Part or Identifying Number (PIN). The PIN to be used for regulators acquired to this specification are created as follows:

	M	18115-	X	XX
Prefix to indicate military specification				
Specification number				
Type letter (see 6.4.1)				
Class and style number (see 6.4.2)				

6.4.1 Type letter. The type of the regulator is identified by a single-digit letter (see table I).

TABLE I. Code letter to type.

Type I	A
Type II	B
Type III	C

6.4.2 Class and style number. The class and style of the regulator are identified by a two-digit number (see table II).

TABLE II. Code number to class and style.

	Style 1	Style 2	Style 3	Style 4
Class 1	01	02	-	-
Class 2	03	04	05	06
Class 3	07	08	09	-
Class 4	10	11	12	-

Source: https://assist.dla.mil -- Downloaded: 2026-10-18T10:59Z
Check the source to verify that this is the current version before use.

6.5 First article. When first article inspection is required, the contracting officer should provide specific guidance to offerors whether the item(s) should be a preproduction sample, a first article sample, a first production item, a sample selected from the first production items, a standard production item from the contractor's current inventory (see 3.2), and the number of items to be tested as specified in 4.2. The contracting officer should also include specific instructions in acquisition documents regarding arrangements for examinations, approval of first article test results, and disposition of first articles. Invitations for bids should provide that the Government reserves the right to waive the requirement for samples for first article inspection to those bidders offering a product which has been previously acquired or tested by the Government, and that bidders offering such products, who wish to rely on such production or test, must furnish evidence with the bid that prior Government approval is presently appropriate for the pending contract. Bidders should not submit alternate bids unless specifically requested to do so in the solicitation.

6.6 Subject term (key word) listing.

Liquid level
Feed water flow control
Feed pump motor regulation

6.7 Changes from previous issue. Marginal notations are not used in this revision to identify changes with respect to the previous issue due to the extensiveness of the changes.

Custodians:
Navy - YD
Air Force - 99

Review activity:
Air Force - 84

User activities:
Army - CE
Navy - CG

Preparing activity:
Navy - YD

(Project 4410-0065)

Source: https://assist.dla.mil -- Downloaded: 202640-18T10:59Z
Check the source to verify that this is the current version before use.

INSTRUCTIONS: In a continuing effort to make our standardization documents better, the DoD provides this form for use in submitting comments and suggestions for improvements. All users of military standardization documents are invited to provide suggestions. This form may be detached, folded along the lines indicated, taped along the loose edge *(DO NOT STAPLE)*, and mailed. In block 5, be as specific as possible about particular problem areas such as wording which required interpretation, was too rigid, restrictive, loose, ambiguous, or was incompatible, and give proposed wording changes which would alleviate the problems. Enter in block 6 any remarks not related to a specific paragraph of the document. If block 7 is filled out, an acknowledgement will be mailed to you within 30 days to let you know that your comments were received and are being considered.

NOTE: This form may not be used to request copies of documents, nor to request waivers, deviations, or clarification of specification requirements on current contracts. Comments submitted on this form do not constitute or imply authorization to waive any portion of the referenced document*(s)* or to amend contractual requirements.

(Fold along this line)

(Fold along this line)

DEPARTMENT OF THE NAVY

Commanding Officer (Code 156)
Naval Construction Battalion Center
Port Hueneme, CA 93043-5000

NO POSTAGE NECESSARY IF MAILED IN THE UNITED STATES

OFFICIAL BUSINESS
PENALTY FOR PRIVATE USE $300

BUSINESS REPLY MAIL
FIRST CLASS PERMIT NO. 12503 WASHINGTON D. C.

POSTAGE WILL BE PAID BY THE DEPARTMENT OF THE NAVY

Commanding Officer
Code 156
Naval Construction Battalion Center
Port Hueneme, CA 93043-5000

Source: https://assist.dla.mil -- Downloaded: 2026-10-18T10:59Z
Check the source to verify that this is the current version before use.

STANDARDIZATION DOCUMENT IMPROVEMENT PROPOSAL

(See Instructions – Reverse Side)

1. DOCUMENT NUMBER	2. DOCUMENT TITLE
MIL-R-18115D	REGULATORS, BOILER-FEED WATER, AUTOMATIC

3a. NAME OF SUBMITTING ORGANIZATION

b. ADDRESS *(Street, City, State, ZIP Code)*

4. TYPE OF ORGANIZATION *(Mark one)*

- ☐ VENDOR
- ☐ USER
- ☐ MANUFACTURER
- ☐ OTHER *(Specify)*: _____

5. PROBLEM AREAS

a. Paragraph Number and Wording:

b. Recommended Wording:

c. Reason/Rationale for Recommendation:

6. REMARKS

7a. NAME OF SUBMITTER *(Last, First, MI)* – Optional	b. WORK TELEPHONE NUMBER *(Include Area Code)* – Optional
c. MAILING ADDRESS *(Street, City, State, ZIP Code)* – Optional	8. DATE OF SUBMISSION *(YYMMDD)*

DD FORM 82 MAR 1426 PREVIOUS EDITION IS OBSOLETE.

(TO DETACH THIS FORM, CUT ALONG THIS LINE.)

KEPRODUCED AT GOVERNMENT EXPENSE

Source: https://assist.dla.mil -- Downloaded: 20261-18110:592
Check the source to verify that this is the current version before use.