MIL-W-406C(YD)
25 October 1982
SUPERSEDING
MIL-W-406B(YD)
30 April 1971

MILITARY SPECIFICATION

WELL POINTS, DRIVE TYPE

This specification is approved for use by the Naval Facilities Engineering Command, Department of the Navy, and is available for use by all Departments and Agencies of the Department of Defense.

1. SCOPE

1.1 Scope. This specification covers drive type well points for driven wells.

1.2 Classification. Well points shall be one of the following types, as specified (see 6.2):

Type I - Heavy-duty steel pipe outer casing over screen, with a polyvinyl chloride (pvc) plastic lining, and 2-inch National taper pipe (thread) (NPT) connection.
Type II - Continuous slot, wire wound over steel body construction, with 1.25- or 2-inch NPT connection.

2. APPLICABLE DOCUMENTS

2.1 Government documents.

2.1.1 Specifications and standards. Unless otherwise specified (see 6.2), the following specifications and standards of the issue listed in that issue of the Department of Defense Index of Specifications and Standards (DODISS) specified in the solicitation form a part of this specification to the extent specified herein.

SPECIFICATION

FEDERAL

PPP-B-636 - Boxes, Shipping, Fiberboard.

Beneficial comments (recommendations, additions, deletions) and any pertinent data which may be of use in improving this document should be addressed to: Commanding Officer (Code 156), Naval Construction Battalion Center, Port Hueneme, CA 93043, by using the self-addressed Standardization Document Improvement Proposal (DD Form 1426) appearing at the end of this document or by letter.

FSC 3820

Source: https://assist.dla.mil -- Downloaded: 202640-16T07:22Z
Check the source to verify that this is the current version before use.

STANDARDS

MILITARY

MIL-STD-105 - Sampling Procedures and Tables for Inspection by Attributes.
MIL-STD-129 - Marking for Shipment and Storage.
MIL-STD-147 - Palletized Unit Loads.
MIL-STD-794 - Parts and Equipment, Procedures for Packaging and Packing of.
MIL-STD-1188 - Commercial Packaging of Supplies and Equipment.

(Copies of specifications and standards required by manufacturers in connection with specific acquisition functions should be obtained from the contracting activity or as directed by the contracting officer.)

2.2 Order of precedence. In the event of a conflict between the text of this specification and the references cited herein, the text of this specification shall take precedence.

3. REQUIREMENTS

3.1 First article. When specified (see 6.2), the contractor shall furnish one complete well point for first article inspection and approval (see 4.2.1 and 6.4).

3.2 Standard commercial product. The well points shall, as a minimum, be in accordance with the requirements of this specification and shall be the manufacturer's standard commercial product. Additional or better features which are not specifically prohibited by this specification but which are a part of the manufacturer's standard commercial product shall be included in the well points being furnished. A standard commercial product is a product which has been sold or is being currently offered for sale on the commercial market through advertisements, manufacturer's catalogs, or brochures, and represents the latest production model.

3.3 Materials. Materials used shall be free from defects which would adversely affect the performance or maintainability of individual components or of the overall assembly. Materials not specified herein shall be of the same quality used for the intended purpose in commercial practice. Unless otherwise specified herein, all equipment, material, and articles incorporated in the work covered by this specification are to be new and fabricated using materials produced from recovered materials to the maximum extent possible without jeopardizing the intended use. The term "recovered materials" means materials which have been collected or recovered from solid waste and reprocessed to become a source of raw materials, as opposed to virgin raw materials. None of the above shall be interpreted to mean that the use of used or rebuilt products are allowed under this specification unless otherwise specified.

3.4 Design and construction. The well point shall consist of a screen section with external standard pipe threads on one end and a drive point on the other end. It shall be designed and constructed so that the well point will withstand driving without splitting or separation of the component parts.

Source: https://assist.dla.mil -- Downloaded: 2026-10-16T07:22Z
Check the source to verify that this is the current version before use.

3.4.1 Type I. The nominal length of the well point shall be 48 inches. The type I well point shall consist of an outer casing of heavy-duty steel pipe with a hardened steel pointed tip, a screen, and a pvc plastic lining. The screen shall be housed between the outer casing and the pvc lining in a manner that will prevent the screen from slipping or tearing. The screen shall be constructed of phosphorous bronze, stainless steel, or fiberglass, as specified (see 6.2). The threaded end shall be 2-inch NPT. The screen mesh and perforated area of the outer casing and lining shall envelop 42 inches of the pipe's length. The openings on the outer casing shall be designed and spaced in a manner that will make them self-cleaning and allow a maximum inlet area. The size of the screen openings shall be 60-gauze (0.010 inch) with a tolerance of ± 0.002 inch.

3.4.2 Type II. The nominal length of the type II well point shall be 54 inches. The screen section shall be constructed of a single continuous helical winding of steel wire around the outside of longitudinal rods secured to the end sections. The wire shall be welded to the rods at each intersection. The cross section of the wire shall be shaped so that the outside width of the slot, formed by winding the wire on the rods, shall be less than the inside width of the slot. The threaded end shall be 1.25- or 2-inch NPT, as specified (see 6.2). A heavy point shall be welded to the bottom of the screen body. The length of the screen portion shall be approximately 48 inches. The narrow part of the slot opening between adjacent turns of the wire wrapping shall be 60-gauze (0.010 inch), with a tolerance of ± 0.002 inch. The type II well points shall be constructed of galvanized steel or all stainless steel, as specified (see 6.2).

3.5 Identification marking. Identification shall be permanently and legibly marked directly on the well point or on a corrosion-resisting metal plate securely attached to the well point by the manufacturer. Identification shall include the manufacturer's model, serial number, name, and trademark to be readily identifiable to the manufacturer.

3.6 Workmanship. All well points being furnished shall be made and finished with a degree of uniformity and a grade of workmanship practicable in a well-equipped factory.

3.6.1 Welding. Welding procedures shall be in accordance with a nationally recognized welding code. The surface of parts to be welded shall be free from rust, scale, paint, grease, or other foreign matter. Welds shall be of sufficient size and shape to develop the full strength of the parts connected by the welds. Welds shall transmit stress without permanent deformation or failure when the parts connected by the weld are subjected to proof and service loadings.

4. QUALITY ASSURANCE PROVISIONS

4.1 Responsibility for inspection. Unless otherwise specified in the contract or purchase order, the contractor is responsible for the performance of all inspection requirements as specified herein. Except as otherwise specified in the contract or purchase order, the contractor may use his own or any other facilities suitable for the performance of the inspection requirements specified herein, unless disapproved by the Government. The Government reserves the

Source: https://assist.dla.mil -- Downloaded: 202610-16T07:22Z
Check the source to verify that this is the current version before use.

right to perform any of the inspections set forth in the specification where such inspections are deemed necessary to assure supplies and services conform to prescribed requirements.

4.1.1 Component and material inspection. Components and materials shall be inspected in accordance with all the requirements specified herein and in applicable referenced documents.

4.2 Classification of inspections. The inspection requirements specified herein are classified as follows:

a. First article inspection (see 4.2.1).
b. Quality conformance inspection (see 4.2.2).

4.2.1 First article inspection. The first article inspection shall be performed on one complete well point when a first article is required (see 3.1 and 6.4). This inspection shall include the examination of 4.4. The first article may be either a first production item or a standard production item from the supplier's current inventory provided the item meets the requirements of the specification and is representative of the design, construction, and manufacturing technique applicable to the remaining items to be furnished under the contract.

4.2.2 Quality conformance inspection. The quality conformance inspection shall include the examination of 4.4 and the packaging inspection of 4.5. This inspection shall be performed on the samples selected in accordance with 4.3.

4.3 Sampling. Sampling shall be in accordance with MIL-STD-105. All well points of one type offered for delivery at one time shall be considered a lot for the purpose of inspection. The inspection level shall be level II and the acceptable quality level (AQL) shall be 4.0 percent defective. If an inspection lot is rejected, the contractor may rework it to correct the defects, or screen out the defective units, and resubmit for a complete reinspection. Resubmitted lots shall be inspected using tightened inspection. Such lots shall be separate from new lots, and shall be clearly identified as reinspected lots.

4.4 Examination. Each well point selected in accordance with 4.3 shall be examined for compliance with the requirements specified in section 3 of this specification. Any redesign or modification of the contractor's standard product to comply with specified requirements, or any necessary redesign or modification following failure to meet specified requirements, shall receive particular attention for adequacy and suitability. This element of inspection shall encompass all visual examinations and dimensional measurements. Noncompliance with any specified requirements or presence of one or more defects preventing or lessening maximum efficiency shall constitute cause for rejection.

4.5 Packaging inspection. The preservation, packing, palletization, and marking of the item shall be inspected to verify conformance to the requirements of section 5.

Source: https://assist.dla.mil -- Downloaded: 2026-10-16T07:22Z
Check the source to verify that this is the current version before use.

5. PACKAGING

5.1 Preservation. Preservation shall be level A or commercial as specified (see 6.2).

5.1.1 Level A. Each well point shall be packaged in a close-fitting box conforming to PPP-B-636, class weather-resistant. Joints and seams of the boxes shall be waterproof sealed with tape in accordance with the appendix of the box specification.

5.1.2 Commercial. Material shall be packaged in accordance with MIL-STD-1188.

5.2 Packing. Packing shall be level A, B, or commercial as specified (see 6.2).

5.2.1 Levels A and B. Packing shall be in accordance with MIL-STD-794. Containers shall be selected from table I for the appropriate level.

5.2.2 Commercial. Material shall be packed in accordance with MIL-STD-1188.

5.3 Palletization. Material shall be palletized in accordance with MIL-STD-147 when the following criteria are met:

a. Load to consist of four or more unskidded containers.
b. Load shall utilize a minimum of 80 percent of the pallet base.

5.4 Marking. Marking shall be in accordance with MIL-STD-129.

6. NOTES

6.1 Intended use. The well points are suitable for driven wells in lightly compacted, sandy, or light gravel soils. Heavy gravel will tend to damage the screens. The location of the pump and well point should be such that the water level is not more than 25 feet below the pump, consideration being given to the possibility of lowering the water level when considerable water is being drawn from the well. Each type is applicable as follows:

a. Type I. For wells of moderate capacities in sandy soils. It should be noted that use of the phosphorous bronze or stainless-steel screen with this well point could cause electrolytic corrosion. Rust or iron oxide, resulting from the corrosion, deposits itself in the mesh openings and reduces the intake capacity of the well.
b. Type II. Where less corrosive conditions exist and the well point is not likely to be corroded and permanent installations of maximum capacities are required, the galvanized well point is appropriate. Where the water or soil condition is such that the well point would be corroded and permanent installations of maximum capacities are required, the stainless-steel well point is appropriate.

6.2 Ordering data. Acquisition documents should specify the following:

a. Title, number, and date of this specification.
b. Type required (see 1.2).

Source: https://assist.dla.mil -- Downloaded: 202610-16T07:22Z
Check the source to verify that this is the current version before use.

c. Issue of document required if other than as specified (see 2.1.1).
d. When a first article is required (see 3.1, 4.2.1, and 6.4).
e. Screen material required for type I is to be phosphorous bronze, stainless steel, or fiberglass (see 3.4.1).
f. If type II is to be 1.25- or 2-inch NPT; whether it is to be galvanized steel or stainless steel (see 3.4.2).
g. Level of preservation and level of packing required (see 5.1 and 5.2).

6.3 Data requirements. When this specification is used in an acquisition which incorporates a DD Form 1423 and invokes the provisions of paragraph 7-104.9(n) of the Defense Acquisition Regulations (DAR), the data requirements will be developed as specified by an approved Data Item Description (DD Form 1664) and delivered in accordance with the Contract Data Requirements List (DD Form 1423) incorporated into the contract. When the provisions of DAR 7-104.9(n) are not invoked, the data shall be delivered in accordance with the contract requirements.

6.4 First article. When a first article inspection is required, the item will be tested and should be a first production item or it may be a standard production item from the contractor's current inventory as specified in 4.2.1. The first article should consist of one complete well point. The contracting officer should include specific instructions in acquisition documents regarding arrangements for examination, test, and approval of the first article.

6.5 Cross-reference of classifications. Industry coordination of this revision has revealed that type I of MIL-W-406B(YD) is not readily available. Type I of this revision consists of an outer casing of steel pipe over screen, with a pvc lining.

MIL-W-406A	MIL-W-406B(YD)	MIL-W-406C(YD)
Class 1	Type I	Type I (changed)
Class 2, grade A	--	--
Class 2, grade B	--	--
Class 2, grade C	Type II	Type II
	Type III (added)	(option of type II)

6.6 Changes from previous issue. Asterisks are not used in this revision to identify changes with respect to the previous issue, due to the extensiveness of the changes.

Custodian:

Navy - YD

Review activity:

DLA - CS

Preparing activity:

Navy - YD

Project No. 3820-0161

Source: https://assist.dla.mil -- Downloaded: 202610-16T07:22Z
Check the source to verify that this is the currentversion before use.

STANDARDIZATION DOCUMENT IMPROVEMENT PROPOSAL

INSTRUCTIONS: This form is provided to solicit beneficial comments which may improve this document and enhance its use. DoD contractors, government activities, manufacturers, vendors, or other prospective users of the document are invited to submit comments to the government. Fold on lines on reverse side, staple in corner, and send to preparing activity. Attach any pertinent data which may be of use in improving this document. If there are additional papers, attach to form and place both in an envelope addressed to preparing activity. A response will be provided to the submitter, when name and address is provided, within 30 days indicating that the 1426 was received and when any appropriate action on it will be completed.

NOTE: This form shall not be used to submit requests for waivers, deviations or clarification of specification requirements on current contracts. Comments submitted on this form do not constitute or imply authorization to waive any portion of the referenced document(s) or to amend contractual requirements. 3820-0161

DOCUMENT IDENTIFIER *(Number)* AND TITLE

MIL-W-406C(YD) - WELL POINTS, DRIVE TYPE

NAME OF ORGANIZATION AND ADDRESS OF SUBMITTER

☐ VENDOR ☐ USER ☐ MANUFACTURER

1. ☐ HAS ANY PART OF THE DOCUMENT CREATED PROBLEMS OR REQUIRED INTERPRETATION IN PROCUREMENT USE? ☐ IS ANY PART OF IT TOO RIGID, RESTRICTIVE, LOOSE OR AMBIGUOUS? PLEASE EXPLAIN BELOW.

A. GIVE PARAGRAPH NUMBER AND WORDING

B. RECOMMENDED WORDING CHANGE

C. REASON FOR RECOMMENDED CHANGE(S)

2. REMARKS

SUBMITTED BY *(Printed or typed name and address – Optional)*

TELEPHONE NO.

DATE

DD FORM 1426 1 OCT 76

Replaces edition of 1 Jan 72 which may be used.

S/N 0102-LF-001-4260

Source: https://assist.dla.mil -- Downloaded: 202610-16T07:22Z
Check the source to verify that this is the current version before use.