W-C-586D
30 June 1986
SUPERSEDING
W-C-586C
5 February 1980

FEDERAL SPECIFICATION

CONDUIT OUTLET BOXES, BODIES, AND ENTRANCE CAPS, ELECTRICAL: CAST METAL

This specification was approved by the Commissioner, Federal Supply and Services, General Services Administration, for the use of all Federal agencies.

1. SCOPE AND CLASSIFICATION

1.1 Scope. This specification covers cast metal conduit outlet boxes, bodies, and entrance caps for use with threaded and threadless rigid conduit, intermediate metallic conduit, and electrical metallic conduit.

1.2 Classification.

1.2.1 Types, designs, and forms. The conduit boxes, bodies, and entrance caps shall be one of the following types, designs, and forms, as specified (see 6.2):

Type I — Conduit bodies which are essentially an enlarged section of conduit with hubs and access openings

- Design 1 — Standard size wiring chamber with threaded hub connection for rigid conduit
- Design 2 — Standard size wiring chamber with threadless hub connection for rigid conduit
- Design 3 — Standard size wiring chamber with threadless hubs for electrical metallic tubing
- Design 4 — Wiring chambers enlarged in both length and width and with threaded hub connection for rigid conduit
- Design 5 — Wiring chamber with increased length and with threaded hub connection for rigid conduit
- Design 6 — Wiring chamber with increased length and with threadless hub connection for electrical metallic tubing

Type II — Rectangular base general purpose conduit outlet boxes for wiring devices

- Design 7 — Threaded hub connection for rigid conduit, shallow depth
- Design 8 — Threaded hub connection for rigid conduit, deep depth

FSC 5975

DISTRIBUTION STATEMENT A. Approved for public release; distribution is unlimited.

AMSC N/A

Source: https://assist.dla.mil -- Downloaded: 202610-26T11:27Z
Check the source to verify that this is the current version before use.

Design 9 - Threadless hub connection for rigid conduit, shallow depth
Design 10 - Threadless hub connection for rigid conduit, deep depth
Design 11 - Threadless hub connection for electrical metallic tubing, shallow depth
Design 12 - Threadless hub connection for electrical metallic tubing, deep depth

Form 1 - Single gang
Form 2 - Two gang parallel
Form 3 - Three gang parallel
Form 4 - Four gang parallel
Form 5 - Two gang tandem

Type III - Round base general purpose conduit outlet boxes with threaded conduit hubs

Design 16 - Nominal 4-inch diameter for exposed installation

Type IV - Round base weather-resistant conduit outlet boxes, with threaded conduit hubs, for exposed installation

Design 18 - Nominal 3-1/2 inch diameter
Design 19 - Nominal 4-5/8 inch diameter

Type V - Round base explosion proof, dust-ignition-proof, and weather-resistant conduit outlet boxes with threaded conduit hubs

Design 20 3-1/2 inch diameter, threaded cover, plain base
Design 21 - 4-1/4 inch diameter, threaded cover, plain base
Design 22 - 5-3/4 inch diameter, threaded cover, flanged, mounting base
Design 23 - 3-1/2 inch diameter, threaded cover, flanged, mounting base
Design 25 - 3-1/2 inch diameter, cover attached by screws, plain base
Design 26 - 4-5/8 inch diameter, cover attached by screws, plain base

Type VI - Entrance caps, electrical

Design 27 - Threaded hub connection for rigid conduit
Design 28 - Threadless hub connection for electrical metallic tubing
Design 29 - Threadless hub connection for rigid conduit

Form 6 - With 3 wire (3-knockout) insulating cover
Form 7 - With 5 wire (5-knockout) insulating cover
Form 8 - With 7 wire (7-knockout) insulating cover
Form 9 - With 4 wire (4-knockout) insulating cover
Form 10 - With 6 wire (6-knockout) insulating cover

1.2.2 Styles. The outlets and devices shall be one of the styles listed below, as specified (see 6.2). For definition, the front shall be the surface where the access to the wiring chamber is located. The right and left side

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T11:27Z
Check the source to verify that this is the current version before use.

shall be determined by placing the hub end up and viewing toward the cover opening. Tables I through V indicate normal availability of the various styles with respect to type, design, form, and size.

Style A - One hub in the back
Style AA - Two hubs in the back
Style B - One hub in one side
Style BC One hub in each end, Mogul style
Style BLB One hub in one end and one hub at a 90 degree (°) angle at the opposite end in the back, mogul style
Style BUB - One hub at each end at a 45° angle, mogul style
Style BT - One hub at each end and one hub on one side, mogul style
Style C - One hub in each end
Style CA One hub in each end and one hub in the back
Style CC - One hub in one end and two hubs in the other
Style CD - Two hubs in each end directly opposite
Style CT (Type II) One hub in each end, and one hub in a side
Style E - One hub in one end
Style L - One hub in one end and one hub in the right side, with cover on back
Style LA - One hub in one end and one hub in the back
Style LB One hub in one end and one hub placed at a 90° angle at the opposite end in the back
Style LBD - One hub at one end and one hub at a 90° angle at the opposite end in the back with cover
Style LBL One hub in one end and one hub in the back and left side at the opposite end
Style LBR One hub in one end and one hub in the back and right side at the opposite end
Style LF One hub in one end and on hub placed at a 90° angle at the opposite end in the front
Style LFN One hub in one end and one hub 90° out in front at the opposite end with a mounting platform
Style LL One hub in one end and one hub placed at a 90° angle at the opposite end, on the left side
Style LR One hub in one end and one hub placed at a 90° angle at the opposite end, on the right side
Style LRL One hub in one end and one hub placed at a 90° angle at the opposite end on a side with access openings in both front and back
Style R - One hub in an end and one hub on the right side
Style S - Two hubs in one end
Style T - (Type I) One hub in each end, and one hub in a side
Style T - (Type II) One hub in each side, and one hub in one end
Style TA One hub in each end, one hub in a side, and a hub in the back
Style TB One hub in each end and one hub in the back
Style TM One hub in each end and one hub on one side with a mounting platform
Style UB One hub in each end, both hubs offset in the back at a 45° angle from the outlet centerline, with a projected included angle of 90°
Style X One hub in each side and in each end

Source: https://assist.dla.mil -- Downloaded: 202640-26T11:27Z
Check the source to verify that this is the current version before use.

1.2.3 Hub size. Conduit hub sizes shall be 1/2-, 3/4-, 1-, 1-1/4-, 1-1/2-, 2-, 2-1/2-, 3-, 3-1/2-, 4-, 5-, or 6-inch trade size, as specified (see 6.2). Hub sizes are related to type, design, form, and style shall be as shown in tables I through V.

1.2.3.1 System of measurement. The dimensions used in this specification are not intended to preclude the use of the metric system of measurement in the fabrication and production of the material, individual parts, and the finished product, provided form, fit, and function requirements are satisfied.

2. APPLICABLE DOCUMENTS

2.1 Government publications. The following documents, of the issues in effect on date of invitation for bids or request for proposal, form a part of this specification to the extent specified herein.

Federal Standards

FED STD-123 - Marking for Shipment (Civil Agencies)

(Activities outside the Federal Government may obtain copies of Federal specifications, standards, and commercial item descriptions as outlined under General Information in the Index of Federal Specifications, Standards, and Commercial Item Descriptions. The Index, which includes cumulative bimonthly supplements as issued, is for sale on a subscription basis by the Superintendent of Documents, U.S. Government Printing Office, Washington, DC 20402.

(Single copies of this specification and other Federal specifications and commercial item descriptions required by activities outside the Federal Government for bidding purposes are available without charge from General Services Administration Business Service Centers in Boston, MA; New York, NY; Philadelphia, PA; Washington, DC; Atlanta, GA; Chicago, IL; Kansas City, MO; Fort Worth, TX; Houston, TX; Denver, CO; San Francisco, CA; Los Angeles, CA; and Seattle, WA.

(Federal Government activities may obtain copies of Federal Specification documents, and the Index of Federal Specifications, Standards, and Commercial Item Descriptions from established distribution points in their agencies.)

Military Specification

MIL-E-17555 - Electronic and Electrical Equipment, Accessories, and Repair Parts, Packaging and Packing of

Military Standard

MIL-STD-105 - Sampling Procedures and Tables for Inspection by Attributes
MIL-STD-129 - Marking for Shipment and Storage

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T11:27Z
Check the source to verify that this is the current version before use.

(Copies of military specifications and standards required by contractors in connection with specific procurement functions should be obtained from the procuring activity or as directed by the contracting officer.)

2.2 Other publications. The following documents form a part of this specification to the extent specified herein. Unless a specific issue is identified, the issue in effect on date of invitation for bids or request for proposal shall apply.

American Society of Mechanical Engineers (ASME):

E 380 - Metric Practice

(Application for copies should be addressed to the American Society of Mechanical Engineers, United Engineering Center, 345 East 47th Street, New York, NY 10017.)

National Fire Protection Association (NFPA):

70 - National Electrical Code

(Application for copies should be addressed to the National Fire Protection Association, Batterymarch Park, Quincy, MA 02269.)

Society of Automotive Engineers, Inc. (SAE)

SAE J475a - Screwthreads
SAE J476a - Dryseal Pipe Threads

(Application for copies should be addressed to the Society of Automotive Engineers, Inc., 400 Commonwealth Drive, Warrendale, PA 15096.)

Underwriters Laboratories Inc. (UL):

UL 514B - Standard for Fittings for Conduit and Outlet Boxes
UL 886 Standard for Outlet Boxes and Fittings for Use in Hazardous Locations, Class I, Groups A, B, C, and D, and Class II, Groups E, F, and G.

(Application for copies should be addressed to the Underwriters Laboratories Inc., 333 Pfingsten Road, Northbrook, IL 60062.)

(Industry association specifications and standards are generally available for reference from libraries. They are also distributed among technical groups and using Federal agencies.)

2.3 Order of precedence. In the event of a conflict between the text of this specification and the references cited herein, the text of this specification shall take precedence.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T11:27Z
Check the source to verify that this is the current version before use.

3. REQUIREMENTS

3.1 Description. Conduit outlet boxes, bodies, and entrance caps shall consist of a cast metal body, a wiring chamber, and an access opening to the wiring chamber. All types shall have integral conduit hubs. Each hub shall have an integral end stop for the conduit or tubing, and shall provide a smooth, well rounded opening into the wiring chamber. Boxes without integral conduit hubs or end stops shall provide adequate room for the installation of a bushing.

3.2 Standard commercial product. The conduit outlet boxes, bodies, and entrance caps shall, as a minimum, be in accordance with the requirements of this specification and shall be the manufacturer's standard commercial product. Additional or better features which are not specifically prohibited by this specification but which are a part of the manufacturer's standard commercial product, shall be included in the conduit outlet boxes, bodies, and entrance caps being furnished. A standard commercial product is a product which has been sold or is being currently offered for sale on the commercial market through advertisements or manufacturer's catalogs, or brochures, and represents the latest production model.

3.3 Identical items. Conduit outlet boxes, bodies, or entrance caps of the same classification furnished under any specific contract shall be physically and mechanically identical. This requirement includes parts, assemblies, components, and accessories. No deviation will be acceptable without prior written approval of the contracting officer.

3.4 Design. Conduit outlet boxes, bodies, and entrance caps shall conform to UL 514B. In addition to complying with UL 514B, type V outlet boxes shall comply with the applicable requirements of UL 886 covering installation in class I, groups C and D, and class II, groups E, F, and G, division 1 locations as defined in the NFPA 70.

3.4.1 Standards compliance. Prior to approval of the first shipment, the contractor shall submit for the approval of the contracting officer, or his authorized representative, satisfactory evidence that the outlet boxes, bodies, and entrance caps he proposes to furnish under this specification meets the requirements of UL 514B and UL 886 as applicable.

3.4.2 UL 514B and UL 886. Acceptable evidence of meeting the requirements of UL 514B and UL 886 shall be the UL label, listing in the UL Electrical Appliance and Utilization Equipment List, or other evidence from a nationally recognized independent testing laboratory, acceptable to the contracting officer, indicating that the fittings offered have been tested and conforms to UL 514B and UL 886.

3.4.3 Measurement systems. Unless otherwise specified, either the U.S. Customary System of Units (US) or the International System of Units (SI) shall be used in the design and construction of the conduit outlet boxes (s 6.2). When only one system of measurement is acceptable, the particular

Source: https://assist.dla.mil -- Downloaded: 202640-26T11:27Z
Check the source to verify that this is the current version before use.

system required shall be as specified (see 6.2). In this specification, all measurements, dimensions, sizes and capacities are given in US units. These measurements may be converted to SI units through the use of the conversion factors and methods specified in ASTM E380.

3.5 Materials. Materials used shall be free from defects which would adversely affect the performance or maintainability of individual components or of the overall assembly. Materials not specified herein shall be of the same quality used for the intended purpose in commercial practice. Unless otherwise specified herein, all equipment, material, and articles incorporated in the work covered by this specification are to be new and fabricated using materials produced from recovered materials to the maximum extent possible without jeopardizing the intended use. The term "recovered materials" means materials which have been collected or recovered from solid waste and reprocessed to become a source of raw materials, as opposed to virgin raw materials. None of the above shall be interpreted to mean that the use of used or rebuilt products are allowed under this specification unless otherwise specified.

3.6 Construction. The construction of conduit outlet boxes, bodies, and entrance caps shall insure sufficient strength and rigidity in the finished product to enable the product to resist damage during shipment, rough handling, installation, and use.

3.6.1 Type I. Type I conduit bodies, shall essentially be an enlarged section of conduit. Covers for conduit bodies of the same size supplied under the same contract shall be interchangeable.

3.6.2 Type II. Type II outlet boxes shall have two tapped No. 6, 32 threads per inch device attaching screw holes located on 3-9/32 inch centers for each wiring device position. Covers for the same form supplied under the same contract shall be interchangeable.

3.6.3 Type III. Type III outlet boxes shall be cylindrical in shape and shall be designed to permit installation of standard 4-inch round outlet box covers with or without wiring devices. The outlet box surface mating with the cover shall be flat and smooth. Outlet boxes shall be designed for surface mounted installation.

3.6.4 Type IV. Type IV outlet boxes shall be cylindrical in shape and shall have the surface mating with cover smooth, flat, and designed for the reception of a gasket. Holes for attaching cover shall not communicate with the interior of the outlet box. Means shall be provided for attaching wiring devices or a fastening strap on which wiring devices can be mounted. When specified (see 6.2), outlet boxes shall be provided with mounting feet.

3.6.5 Type V. Type V outlet boxes shall be cylindrical in shape and designed for wiring in hazardous locations. Outlet boxes of design 20 through 23 shall be threaded for attachment of the cover, and the cover shall be

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T11:27Z
Check the source to verify that this is the current version before use.

provided with lugs or comparable devices to facilitate installing. When specifed (see 6.2), the base of design 20, 21, 22, 25, and 26 outlet boxes shall be furnished with at least two lugs to permit screw or nail mounting. The base of design 23 outlet box shall be extended to provide a mounting flange with four holes at quadrant intervals. Designs 25 and 26 outlet boxes shall have the cover attached by not less than four screws spaced equidistant around the perimeter.

3.6.6 Type VI. Entrance caps shall essentially be a conduit terminating fitting at the point of service entrance connection. The entrance cap shall assure a raintight condition within the conduit when the service entrance wires are installed with the proper drip loop. Entrance caps shall be provided with insulating covers containing knockouts of sufficient size to accommodate the wire sizes applicable to the particular conduit size.

3.7 Threaded conduit hubs. Internal conduit threads shall be in accordance with SAE J476a for tapered pipe thread form, except for hubs on service entrance caps which may be SAE straight thread form. The hubs of the outlet boxes and bodies shall be threaded in such a manner that the centerline of the conduit, when attached, shall be in alinement with the centerline of the hub.

3.8 Covers. Blank covers, threaded hub covers, or special purpose covers, with or without gaskets as required, shall be funished as specified (see 6.2). Mounting screws shall conform to SAE J475a for screw threads.

4. QUALITY ASSURANCE PROVISIONS

4.1 Responsibility for inspection. Unless otherwise specified in the contract or purchase order, the contractor is responsible for the performance of all inspection requirements as specified herein. Except as otherwise specified in the contract or purchase order, the contractor may use his own or any other facilities suitable for the performance of the inspection requirements specified herein, unless disapproved by the Government. The Government reserves the right to perform any of the inspections set forth in the specification where such inspections are deemed necessary to assure supplies and services conform to prescribed requirements.

4.1.1. Component and material inspection. Components and materials shall be inspected in accordance with all the requirements specified herein and in applicable referenced documents.

4.2 Sampling. Sampling and inspection procedures shall be in accordance with MIL-STD-105. The unit of product shall be one outlet box, body, or entrance cap. All outlet boxes, bodies, or entrance caps of the same classification offered for delivery at one time shall be considered a lot for the purpose of inspection. If an inspection lot is rejected, the contractor may rework it to correct the defects, or screen out the defective units, and resubmit for a complete reinspection. Resubmitted lots shall be reinspected

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T11:27Z
Check the source to verify that this is the current version before use.

using tightened inspection. If the rejected lot was screened, reinspection shall be limited to the defect causing rejection. If the lot was reprocessed, reinspection shall be performed for all defects. Rejected lots shall be separate from new lots, and shall be clearly identified as reinspected lots.

4.2.1 Sampling for examination. Examination shall be based on inspection level II and an Acceptable Quality Level (AQL) of 2.5 percent defective.

4.2.2 Sampling for tests. Tests shall be based on inspection level S-3 and an AQL of 4.0 percent defective.

4.3 Examination. Each sample selected shall be examined for compliance with the requirements specified in section 3 of this specification. Any redesign or modification of the contractor's standard product to comply with specified requirements, or any necessary redesign or modification following failure to meet specified requirements shall receive particular attention for adequacy and suitability. This element of inspection shall encompass all visual examinations and dimensional measurements. Noncompliance with any specified requirement shall constitute one defect.

4.3.1 Standards compliance. The contractor shall make available to the contracting officer or his authorized representative evidence of compliance with the applicable standard(s) cited in 3.4. The Government reserves the right to examine and test all units to determine the validity of the certification.

4.4 Tests. Each sample selected shall be tested in accordance with UL 514B. Type V shall also comply with the tests of UL 886. When specified (see 6.2), evidence of compliance as required in 3.4.2 is acceptable in lieu of sampling and testing requirements stated herein.

4.5 Preparation for delivery inspection. The inspection of the preservation, packaging, packing, palletization, and marking shall be in accordance with the requirements of the quality conformance inspection requirements of MIL-E-17555.

5 PREPARATION FOR DELIVERY

5.1 Preservation, packaging, and packing, and palletization. Preservation, packaging, packing and palletization, shall be in accordance with the requirements of MIL-E-17555 with the level of preservation, packaging and the level of packing as specified (see 6.2).

5.2 Marking.

5.2.1 Military agencies. Shipments to military agencies shall be marked in accordance with MIL-STD-129.

5.2.2 Civil agencies. Shipments to civil agencies shall be marked in accordance with FED-STD-123.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T11:27Z
Check the source to verify that this is the current version before use.

6. NOTES

6.1 Intended use. This specification covers outlet boxes, bodies, and entrance caps intended for use in rigid metal conduit, intermediate metal conduits, and electrical metallic wiring systems. Outlet boxes may be used as wire outlets or as mountings for lampholders, rosettes, switches, convenience outlets, to enclose wire splices, for mounting or enclosing surface wiring devices, and other similar applications. Outlet bodies provide turns, offsets, pull boxes, and other functions in conduit runs. Entrance caps provide a weather-resistant service entrance for wires.

6.2 Ordering data. Purchasers shall select the preferred options permitted herein and include the following information in procurement documents:

a. Title, number, and date of this specification.
b. Type, design, and form required (see 1.2.1).
c. Style required (see 1.2.2).
d. Hub size required (see 1.2.3).
e. When specific system of measurement required (see 3.4.3).
f. When the outlet boxes shall be furnished with mounting feet (see 3.6.4).
g. When the base of type V, designs 20, 21, 22, 25, and 26 are to be furnished with at least two mounting lugs (see 3.6.5).
h. Type of cover required (see 3.8).
i. Level of preservation and packaging and level of packing required (see 5.1).

6.3 Data requirements. When this specification is used in an acquisition and data as required to be delivered, the data requirements shall be developed as specified by an approved Data Item Description (DD Form 1664) and delivered in accordance with the approved Contract Data Requirements List (CDRL), incorporated into the contract. When the provisions of DOD FAR Supplement, Part 27, Sub-Part 27.410-6 (DD Form 1423) are invoked and the DD Form 1423 is not used, the data shall be delivered by the contract in accordance with the contract or purchase order requirements.

6.4 Product sample. It is believed that this specification adequately describes the characteristics necessary to secure the desired material, and that normally no samples will be necessary prior to award to determine compliance with this specification. If, for any particular purpose, samples with bids are necessary, they should be specifically asked for in the invitation for bids, and the particular purposed to be served by the bid samples should be definitely stated, the specification to apply in all other respects.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T11:27Z
Check the source to verify that this is the current version before use.

6.4 Limits of design. Federal specifications do not include all types, designs, forms, sizes, etc., of the commodities indicated by the titles of the specifications, or which are commercially available, but are intended to cover the types, etc., which are suitable for Federal Government requirements.

TABLE I. Type I conduit bodies with designs and hub size groups where all hubs are the same size.

	*Hub size groups					
Style	Design 1	Design 2	Design 3	Design 4	Design 5	Design 6
A	1, 2	-	-	-	-	-
BLB	-	-	-	-	2	-
BC	-	-	-	-	2	-
BUB	-	-	-	-	2	-
LBD	1,2,3,4	-	-	-	-	-
B	1, 2	-	-	-	-	-
BT	-	-	-	-	2	-
C	1, 2	3	3	1, 2	1, 2	1, 2
E	1, 2	1	-	1, 2	1, 2	-
LB	1	-	-	-	-	-
LF	3	-	-	-	-	-
LL	1, 2	1	1	1, 2	1, 2	1, 2
LR	1, 2	1	1	1, 2	1, 2	1, 2
LRL	1, 2	3	3	-	-	-
T	1, 2	3	3	1, 2	1, 2	1, 2
TA	3	-	-	-	-	-
TB	3	-	-	-	-	-
UB	3	-	-	-	-	1, 2
X	1	-	1	-	2	2

*Group 1 - Includes 1/2-, 3/4-, and 1-inch size hubs.
Group 2 - Includes 1-, 1-1/4-, 1-1/2-, 2-, 2-1/2-, 3-, 3-1/2-, and 4-inch size hubs.
Group 3 - Includes 1/2-, 3/4-, 1-, 1-1/4-, 1-1/2-, and 2-inch size hubs.
Group 4 - Incldes 5- and 6-inch size hubs.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T11:27Z
Check the source to verify that this is the current version before use.

TABLE II. Type I, design 1, 2, and 3 conduit bodies with styles and hub size where hubs are not all the same.

Style	Design	End	Side	End
	1, 2, 3	1/2	1/2	1/2
	1, 2, 3	3/4	1/2	3/4
	1, 2, 3	3/4	3/4	3/4
	1, 2, 3	1	1/2	1
	1, 2, 3	1	3/4	1
	1, 2, 3	1	1	1
T	1	1-1/2	1-1/4	1-1/4
	1	1-1/2	1-1/2	1-1/2
	1	2	2	2
	1	2-1/2	2-1/2	2-1/2
	1	3	3	3
	1	3-1/2	3-1/2	3-1/2
	1	4	4	4

*TABLE III. Type II outlet boxes with design and forms.

Style	Design	Form	Hub sizes (inch)	Design	Form	Hub sizes (inch)
A	7	1, 2	1/2, 3/4, & 1	8	1, 2	1/2, 3/4, & 1
AA	7	1	1/2, 3/4, & 1			
C	7, 9, 11	1, 2, 3 4 & 5	1/2, 3/4, & 1	8, 10 & 12	1, 2 3, & 4	1/2, 3/4, & 1
CA	7	1	1/2, 3/4, & 1	8	1	1/2, 3/4, & 1
CC	7	1, 2	1/2, 3/4, & 1	8	1, 2	1/2, 3/4, & 1
CD	7	1	1/2, 3/4			
E	7, 9, 11	1, 2, 3 & 4	1/2, 3/4, & 1	8, 10 & 12	1, 2 3, & 4	1/2, 3/4, & 1
L	7	1	1/2, 3/4, & 1	8	1	1/2, 3/4, & 1
LA	7	1	1/2, 3/4, & 1	8	1	1/2, 3/4, & 1
LBL	7	1	1/2, 3/4, & 1			
LBR	7	1	1/2, 3/4, & 1			
LFN	7	1	3/4			
R	7	1	1/2, 3/4, & 1	8	1	1/2, 3/4, 7 1
S	7	1, 2	1/2, 3/4, & 1	8	1, 2	1/2, 3/4, & 1
T	7	1	1/2, 3/4, & 1	8	1	1/2, 3/4, & 1
TH	7	1	3/4			
* X	7	1	1/2, 3/4, & 1	8	1	1/2, 3/4, & 1

*Forms 3 and 4 have the number of hubs on the one end equal to the form number with one hub on the other end.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T11:27Z
Check the source to verify that this is the current version before use.

TABLE IV. Types III and IV outlet boxes with styles, sizes, forms, and designs.

Style	Hub size (inch)	Type III design	Type IV design
B	1/2, 3/4, & 1	16	18 & 19
C	1/2, 3/4, & 1	16	18 & 19
L	1/2, 3/4, & 1	16	18 & 19
T	1/2, 3/4, & 1	16	18 & 19
X	1/2, 3/4, & 1	16	18 & 19

TABLE V. Type V, outlet boxes with design, styles, and sizes.

Style	Design 20	Design 21	Design 22	Design 23	Design 25	Design 26
C	1/2, 3/4, & 1	1-1/4	1 1/2, & 2	1/2, 3/4 & 1	1/2, 3/4 & 1	1/2, 3/4 & 1
CA	1/2, 3/4 & 1	-	1 1/4	-	-	-
E	1/2, 3/4, & 1	1-1/4	1-1/2, & 2	-	1/2, 3/4, & 1	1/2, 3/4, & 1
L	1/2, 3/4, & 1	1-1/4	1 1/2, & 2	1/2, 3/4, & 1	1/2, 3/4, & 1	1/2, 3/4, & 1
LA	1/2, 3/4	1-1/4	1-1/2 & 2	-	-	-
T	1/2, 3/4, & 1	1-1/4	1-1/2 & 2	1/2, 3/4, & 1	1/2, 3/4, & 1	1/2, 3/4, & 1
TA	1/2, 3/4	-	-	-	-	-
X	1/2, 3/4, & 1	1-1/4	1-1/2, & 2	1/2, 3/4, & 1	1/2, 3/4, & 1	1/2, 3/4 & 1

MILITARY INTEREST:

Custodians:

Army - ME
Navy - YD
Air Force - 99

Review Activity:

Army - GL

CIVIL AGENCY COORDINATING ACTIVITIES:

GSA - FSS

Preparing Activity:

Navy - YD

DoD Project 5975-0620

U.S. GOVERNMENT PRINTING OFFICE : 1986 - 491-241/53208

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T11:27Z
Check the source to verify that this is the current version before use.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T11:27Z
Check the source to verify that this is the current version before use.