FEDERAL SPECIFICATION

FILTER, RADIO FREQUENCY INTERFERENCE

This specification was approved by the Assistant Administrator, Office of Federal Supply and Services, General Services Administration, for the use of all Federal agencies.

1. SCOPE

1.1 Scope. This specification covers radio frequency interference suppression power line filters. These filters consist of capacitors and inductors used in combination with each other and may be provided with resistors. Filters covered by this specification are intended for commercial/industrial application and should not be used in military systems needing stringent environmental and electrical requirements.

2. APPLICABLE DOCUMENTS

2.1 Government publications. The following documents, of the issues in effect on the date of invitation for bids or request for proposal, form a part of this specification to the extent specified herein.

Federal Specifications

L-P-378	-	Plastic Sheet and Strip, Thin Gauge, Polyolefin.
NN-P-71	-	Pallet, Material Handling, Wood, Stringer Construction, 2 Way and 4 Way.
QQ-S-781	-	Strapping, Steel, and Seals.
PPP-B-566	-	Box, Folding, Paperboard.
PPP-B-585	-	Boxes, Wood, Wirebound.
PPP-B-601	-	Boxes, Wood, Cleated-Plywood.
PPP-B-621	-	Boxes, Wood, Nailed and Lock-Corner.
PPP-B-636	-	Boxes, Shipping, Fiberboard.
PPP-B-676	-	Boxes, Setup.

Federal Standards

Fed. Std. No. 123 - Marking for Shipment (Civil Agencies).

(Activities outside the Federal Government may obtain copies of Federal specifications, standards, and commercial item descriptions as outlined under General Information in the Index of Federal Specifications, Standards, and Commercial Item Descriptions. The Index, which includes cumulative bimonthly supplements as issued, is for sale on a subscription basis by the Superintendent of Documents, U.S. Government Printing Office, Washington, DC 20402.

(Single copies of this specification, and other Federal specifications and commercial item descriptions required by activities outside the Federal Government for bidding purposes are available without charge from General Services Administration Business Service Centers in Boston, MA; New York, NY; Washington, DC; Atlanta, GA; Chicago, IL; Kansas City, MO; Fort Worth, TX; Denver, CO; San Francisco, CA; Los Angeles, CA; and Seattle, WA.

(Federal Government activities may obtain copies of Federal standardization documents and the Index of Federal Specifications, Standards, and Commercial Item Descriptions from established distribution points in their agencies.)

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T11:37Z
Check the source to verify that this is the current version before use.

Military Specifications

MIL-P-116	-	Preservation, Methods Of.

Military Standards

MIL-STD-105	-	Sampling Procedures and Tables for Inspection by Attributes.
MIL-STD-129	-	Marking for Shipment and Storage.
MIL-STD-147	-	Palletized Unit Loads.
MIL-STD-220	-	Method of Insertion-Loss Measurement.
MIL-STD-1188	-	Commercial Packaging of Supplies and Equipment.
MIL-STD-1285	-	Marking of Electrical and Electronic Parts.
MIL-STD-45662	-	Calibration Systems Requirements.

(Copies of military specifications and standards required by contractors in connection with specific procurement functions should be obtained from procuring activity or as directed by the contracting officer.)

2.2 Other publications. The following document forms a part of this specification to the extent specified herein. Unless a specific issue is identified, the issue in effect on date of invitation for bids or request for proposal shall apply:

Underwriters' Laboratories, Inc. (UL) Standard:

UL1283 - Standard for Electromagnetic Interference Filters.

(Application for copies should be addressed to the Underwriters' Laboratories, Inc., 1285 Walt Whitman Road, Melville, L.I., New York 11746; 1655 Scott Boulevard, Santa Clara, California 95050; and 333 Pfingsten Road, Northbrook, Illinois 60062.)

3. REQUIREMENTS

3.1 Specification sheets. The individual item requirements shall be as specified herein, and in accordance with the applicable specification sheet. In the event of any conflict between this specification and the specification sheet, the latter shall govern.

3.2 Qualification. The filters furnished under this specification shall be products which are qualified for listing on the applicable qualified products list at the time set for opening of bids (see 4.5 and 6.3).

3.3 Material. The material for each part shall be as specified herein. However, when a definite material is not specified, a material shall be used which will enable the filters to meet the performance requirements of this specification. Acceptance or approval of any constituent material shall not be construed as a guaranty of the acceptance of the finished product.

3.4 Design and construction. The filters shall be of the design, construction and physical dimensions as specified (see 3.1).

3.4.1 Case. The filters shall be enclosed in suitable cases which shall protect the filter elements from moisture and mechanical damage. All external bonding or grounding surfaces shall be free from all insulating protective finishes.

3.5 Leakage current. When filters are tested in accordance with 4.7.2, the leakage current shall not exceed the value specified (see 3.1).

3.6 Insertion loss. When filters are tested in accordance with 4.7.3, the insertion loss shall be as specified (see 3.1).

3.7 Dielectric withstanding voltage. When filters are tested in accordance with 4.7.4, there shall be no breakdown, flashover or impairment of any characteristic qualities sufficient to cause failure of the filter.

3.8 Insulation resistance. When filters are tested in accordance with 4.7.5, the insulation resistance shall be not less than 2 megohms line to ground.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T11:37Z
Check the source to verify that this is the current version before use.

3.9 Overload. When filters are tested in accordance with 4.7.6, the filter shall not show evidence of sealant leakage, cracking, breakage or similar physical damage.

3.10 Temperature rise. The filters are tested in accordance with 4.7.7.

3.11 Endurance. When filters are tested in accordance with 4.7.8, the filter shall not show evidence of sealant leakage, cracking, breakage or similar physical damage. Following the test the filters shall meet the insertion loss requirements as specified in 3.6.

3.12 Marking.


3.12.1 Filters qualified in conjunction with UL Recognization Program (see 4.5b). Each filter shall be marked, as a minimum, in accordance with UL1283 with the following information:

a. The Federal Specification part number.
b. Manufacturer's part number.
c. Manufacturer's name, source code, or trademark.
d. Voltage rating.
e. Current rating.
f. The Federal Specification Verification mark (FS-UL) (see 3.12.3).
g. "Load" terminal identification.
h. "Line" terminal identification.

3.12.2 Filters not qualified in conjunction with UL Recognization Program (see 4.5a). Each filter shall be marked, as a minimum, with the following information in accordance with MIL-STD-1285:

a. The Federal Specification part number.
b. Manufacturer's part number.
c. Manufacturer's source code.
d. Voltage rating.
e. Current rating.
f. "Load" terminal identification.
g. "Line" terminal identification.

3.12.3 Federal Specification - Underwriters' Laboratories mark (FS-UL). The Federal Specification verification mark (FS-UL) shall appear on filters that meet all the requirements of UL1283 as required by this specification. The Federal Specification verification mark shall be in the following format:



3.13 Workmanship. The filters shall be manufactured and processed in such a manner as to be uniform in quality and shall be free from imperfections which may alter appearance, serviceability, or affect life.

4. QUALITY ASSURANCE PROVISIONS

4.1 Responsibility for inspection. Unless otherwise specified in the contract or purchase order, the contractor is responsible for the performance of all inspection requirements as specified herein. Except as otherwise specified in the contract or order, the contractor may use his own or any other facilities suitable for the performance of the inspection requirements specified herein, unless disapproved by the Government. The Government reserves the right to perform any of the inspections set forth in the specification where such inspections are deemed necessary to assure supplies and services conform to prescribed requirements.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T11:37Z
Check the source to verify that this is the current version before use.

4.1.1 Test equipment and inspection facilities. The manufacturer shall provide the required test equipment and facilities for conducting all tests which are to be made at the factory. Meters shall be of 1-percent accuracy and regularly calibrated. Compliance with the requirements of MIL-STD-45662 shall be acceptable.

4.2 Classification of inspection. The inspections specified herein are classified as follows:

a. Qualification inspection (see 4.5).
b. Quality conformance inspection (see 4.6).

4.3 Inspection of materials and components. In accordance with 4.1, the contractor is responsible for insuring that materials and components used were manufactured, tested, and inspected in accordance with the requirements of this specification and of referenced subsidiary specifications and standards to the extent specified, or if none, in accordance with this specification (see 3.3).

4.4 Inspection conditions. All inspections, examinations, and tests shall be performed in accordance with the applicable conditions specified in UL1283.

4.5 Qualification inspection. Qualification shall be obtained by either of the following:

a. By testing the filters in accordance with 4.5.1, qualification inspection shall be performed at a laboratory acceptable to the Government (see 6.3) on sample units produced with equipment and procedures normally used in production.
b. By having Underwriters' Laboratories Recognition and Federal Specification verification. Manufacturers electing this option shall submit a letter of certification to the qualifying activity listing the Underwriters' file number, report date, the government part number, and the manufacturer's part number for each filter for which qualification is desired. In order for qualification to be granted, testing performed under Underwriters' Laboratories Recognition Program shall be the tests of table I performed in accordance with UL1283.

4.5.1 Inspection routine (applicable to 4.5a only). The filters shall be subjected to inspection specified in table I, in the order shown. Sample size and number of failures permitted shall be as specified in table I.

4.5.2 Retention of qualification. To retain qualification, the contractor shall utilize the applicable procedures as follows.

a. The contractors that used the inspection requirements of 4.5.1 to obtain qualification shall forward a report at 12-month intervals to the qualifying activity. The qualifying activity shall establish the initial reporting date. The report shall consist of:

(1) A summary of the results of tests performed for inspection of product for delivery, groups A and B, indicating as a minimum the number of lots that have passed and the number that have failed. The results of tests of all reworked lots shall be identified and accounted for.
(2) A summary of the results of tests performed for periodic inspection, group C, including the number and mode of failures. The summary shall include results of all periodic inspection tests performed and completed during the 12-month period. If the summary of the test results indicates nonconformance with specification requirements, and corrective action acceptable to the qualifying activity has not been taken, action may be taken to remove the failing product from the qualified products list.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T11:37Z
Check the source to verify that this is the current version before use.

TABLE I. Qualification inspection.

Inspection	Requirement paragraph	Test method paragraph	Number of sample units to be inspected	Number of failures allowed
Group I				
Visual and mechanical inspection	3.1, 3.3, 3.4, 3.4.1, 3.12 and 3.13	4.7.1	11 1/	1
Leakage current	3.5	4.7.2		
Insertion loss	3.6	4.7.3		
Dielectric withstanding voltage	3.7	4.7.4		
Insulation resistance	3.8	4.7.5		
Overload	3.9	4.7.6		
Temperature rise	3.10	4.7.7		
Group II				
Endurance	3.12	4.7.8	10	1

1/ One additional sample unit is included in each sample of eleven to permit substitution for the allowable defect in group I.

Failure to submit the report within 30 days after the end of each 12-month period may result in loss of qualification for the product. In addition to the periodic submission of inspection data, the contractor shall immediately notify the qualifying activity at any time during the 12-month period that the inspection data indicates failure of the qualified products to meet the requirements of this specification.

In the event that no production occurred during the reporting period, a report shall be submitted certifying that the company still has the capabilities and facilities necessary to produce the items. If during two consecutive reporting periods, there has been no production, the manufacturer may be required, at the discretion of the qualifying activity, to submit a representative product of each style, voltage rating, and current rating to testing in accordance with the qualification inspection requirements.

b. The contractors that used Underwriters' Laboratories Recognition to obtain qualification shall submit certification that the qualified filters retain the UL Recognition and continue to meet all requirements as specified (see 3.1) at 12-month intervals to the qualifying activity. The initial reporting date shall be established by the qualifying activity. Failure to submit this certification within 30 days after the end of each 12-month period may result in loss of qualification for the product, at the discretion of the qualifying activity. Manufacturers shall notify the qualifying activity immediately of inspection data that indicates failure of the product to meet the requirements of UL1283.

4.6 Quality conformance inspection. Quality conformance inspection shall consist of groups A, B, and C inspections as specified herein. For filters which qualified in accordance with 4.5b, the Federal Specification-Underwriters' Laboratories mark (FS-UL) shall be evidence of compliance and groups A, B, and C inspection are not applicable.

4.6.1 Inspection of product for delivery. Inspection of product for delivery shall consist of groups A and B inspections.

4.6.1.1 Inspection lot. An inspection lot shall consist of all filters of one specification sheet produced under essentially the same conditions, and offered for inspection at one time.

4.6.1.2 Group A inspection. Group A inspection shall consist of the inspections specified in table II.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T11:37Z
Check the source to verify that this is the current version before use.

4.6.1.2.1 Sampling plan. Statistical sampling and inspection shall be in accordance with MIL-STD-105 for general inspection level II. The acceptable quality level (AQL) shall be 1.0 and 4.0 percent for major and minor defects, respectively. Major and minor defects shall be as defined in MIL-STD-105.

4.6.1.2.2 Rejected lots. If an inspection lot is rejected, the contractor may rework it to correct the defects, or screen out the defective units, and resubmit for reinspection. Resubmitted lots shall be inspected using tightened inspection. Such lots shall be separate from new lots, and shall clearly be identified as reinspected lots.

TABLE II. Group A inspection.

Inspection	Requirement paragraph	Test method paragraph	AQL (percent defective)	
			Major	Minor
Visual and mechanical inspection	3.1, 3.3, 3.4, 3.4.1, 3.12 and 3.13	4.7.1	1.0	4.0
Leakage current	3.5	4.7.2		---
Insertion loss (3 sample units only)	3.6	4.7.3		---
Dielectric withstanding voltage	3.7	4.7.4		---
Insulation resistance	3.8	4.7.5		---

4.6.2 Periodic inspection. Periodic inspection shall consist of groups B and C except where the results of this inspection show noncompliance with the applicable requirement (see 4.6.2.5), delivery of products which have passed group A shall not be delayed pending the results of these periodic inspection.

4.6.2.1 Group B inspection. Group B inspection shall consist of the tests specified in table III, in the order shown, and shall be made on sample units which have been subjected to and have passed the group A inspection.

4.6.2.2 Sampling plan. Every six months 10 sample units representing the highest current rating on each specification sheet shall be subjected to the tests of table III.

4.6.2.3 Defectives. If the number of defectives exceeds the number allowed in table III the sample shall be considered to have failed.

4.6.2.4 Disposition of sample units. Sample units subjected to group B inspection shall not be delivered on the contract or order.

TABLE III. Group B inspection.

Inspoection	Requirement paragraph	Test method paragraph	Number of sample units to be inspected	Number of defectives permitted
Overload	3.9	4.7.6	5	0
Temperature	3.10	4.7.7	5	0

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T11:37Z
Check the source to verify that this is the current version before use.

4.6.2.5 Noncompliance. If a sample fails to pass group B inspection, the contractor shall take corrective action on the materials or processes, or both, as warranted, and on all units of product which can be corrected and which were manufactured under essentially the same conditions with essentially the same materials, processes, etc., and which are considered subject to the same failure. Acceptance of the product shall be discontinued until corrective action, acceptable to the Government, has been taken. After the corrective action has been taken, group C inspection shall be repeated on additional sample units (all inspections, or the inspection which the original sample failed at the option of the Government). Groups A and B inspections may be reinstituted; however, final acceptance shall be withheld until group C reinspection has shown that the corrective action was successful. In the event of failure after reinspection, information concerning the failure and the corrective action taken shall be furnished to the cognizant inspection activity and the qualifying activity.

4.6.2.6 Group C inspection. Group C inspection shall consist of the inspections specified in table IV, in the order shown. Group C inspection shall be made on sample units selected from inspection lots which have passed the groups A and B inspections.

4.6.2.7 Sampling plan. Every twelve months 10 sample units representing the highest current rating on each specification sheet shall be subjected to the tests of table IV.

4.6.2.8 Defectives. If the number of defectives exceed the number allowed in table IV, the sample shall be considered to have failed.

4.6.2.9 Disposition of sample units. Sample units which have been subjected to group C inspection shall not be delivered on the contract or order.

4.6.2.10 Noncompliance. If a sample fails to pass group C inspection, the contractor shall take corrective action on the materials or processes, or both, as warranted, and on all units of product which can be corrected and which were manufactured under essentially the same conditions with essentially the same materials, processes, etc., and which are considered subject to the same failure. Acceptance of the product shall be discontinued until corrective action, acceptable to the Government, has been taken. After the corrective action has been taken, group C inspection shall be repeated on additional sample units (all inspections, or the inspection which the original sample failed at the option of the Government). Groups A and B inspections may be reinstituted; however, final acceptance shall be withheld until groups C reinspection has shown that the corrective action was successful. In the event of failure after reinspection, information concerning the failure and the corrective action taken shall be furnished to the cognizant inspection activity and the qualifying activity.

4.6.3 Inspection of packaging. Except when industrial packaging is specified, the sampling and inspection of the preservation and interior package marking shall be in accordance with the group A and B quality conformance inspection requirements of MIL-P-116. The sampling and inspection of the packing and marking for shipment and storage shall be in accordance with the quality assurance provisions of the applicable container specification and the marking requirements of MIL-STD-129. The inspection of industrial packaging shall be as specified in the contract (see 6.2).

TABLE IV. Group C inspection.

Inspection	Requirement paragraph	Test method paragraph	Number of sample units to be inspected	Number of defectives permitted
Endurance	3.11	4.7.8	10	1

4.7 Methods of inspections.

4.7.1 Visual and mechanical inspection. The filters shall be examined to verify that the material, design and construction, physical dimensions, marking and workmanship are in accordance with 3.1, 3.3, 3.4, 3.4.1, 3.12, and 3.13.

4.7.2 Leakage current (see 3.5). The filters shall be tested in accordance with UL1283.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T11:37Z
Check the source to verify that this is the current version before use.

4.7.3 Insertion loss. The filters shall be tested in accordance with MIL-STD-220, except that adapters shall be modified to fit the specific type of filter and unused terminals may be grounded. Measurements shall be taken at the frequencies specified (see 3.1).

4.7.4 Dielectric withstanding voltage (see 3.7). The filters shall be tested in accordance with UL1283.

4.7.5 Insulation resistance (see 3.8). The filters shall be tested in accordance with UL1283.

4.7.6 Overload (see 3.9). The filters shall be tested in accordance with UL1283.

4.7.7 Temperature rise (see 3.10). The filters shall be tested in accordance with UL1283.

4.7.8 Endurance (see 3.11). The filters shall be tested in accordance with UL1283.

5. PACKAGING

5.1 Preservation. Preservation shall be level A or industrial, as specified (see 6.2).

5.1.1 Level A.

5.1.1.1 Cleaning. The filters shall be cleaned in accordance with MIL-P-116, process C-1.

5.1.1.2 Drying. The filters shall be dried in accordance with MIL-P-116.

5.1.1.3 Preservative application. Preservatives shall not be used.

5.1.1.4 Unit packs. Each filter shall be individually unit packed in accordance with submethod IA-15 of MIL-P-116 insuring compliance with the applicable requirements of that specification. The container shall conform to PPP-B-566 or PPP-B-676.

5.1.1.5 Intermediate packs. The filters, unit packed as specified in 5.1.1.4, shall be placed in intermediate containers conforming to PPP-B-636, class weather resistant. Intermediate containers shall be uniform in size, shape and quantities, shall be of minimum tare and cube and shall contain multiples of five unit packs, not to exceed 100 unit packs. No intermediate packs are required when the total quantity shipped to a single destination is less than 100 unit packs.

5.1.2 Industrial. The industrial preservation of filters shall be in accordance with the requirements of MIL-STD-1188.

5.2 Packing. Packing shall be level A, B or industrial, as specified (see 6.2).

5.2.1 Level A. The packaged filters shall be packed in wood boxes conforming to PPP-B-601, overseas type; PPP-B-621, class 2 or PPP-B-585, class 3. Closure and strapping shall be in accordance with the applicable container specification.

5.2.2 Level B. The packaged filters shall be packed in fiberboard containers conforming to PPP-B-636, class weather resistant, style optional, special requirements. The requirements for box closure, waterproofing and reinforcing shall be in accordance with method V of the PPP-B-636 appendix.

5.2.3 Industrial. The packaged filters shall be packed in accordance with the requirements of MIL-STD-1188.

5.2.4 Unitized loads. Unitized loads, commensurate with the level of packing specified in the contract or order, shall be used whenever total quantities for shipment to one destination equal 40 cubic feet or more. Quantities less than 40 cubic feet need not be unitized. Unitized loads shall be uniform in size and quantities to the greatest extent practicable.

Source: https://assist.dla.mil -- Downloaded: 2026l0-26T11:37Z
Check the source to verify that this is the current version before use.

5.2.4.1 Level A. The filters, packed as specified in 5.2.1, shall be unitized on pallets in conformance with MIL-STD-147, load type I, with a wood cap (storage aid 5) positioned over each load.

5.2.4.2 Level B. The filters, packed as specified in 5.2.2, shall be unitized as specified in 5.2.4.1 except that weather resistant fiberboard caps (storage aid 4) shall be used in lieu of wood caps.

5.2.4.3 Industrial. Unitization is not required for industrial packing.

5.3 Marking.

5.3.1 Levels A and B. In addition to any special or other identification marking required by the contract (see 6.2), each unit, intermediate and exterior container and unitized load shall be marked in accordance with MIL-STD-129. The complete military or contractor's type or part number (including the FSCM), as applicable, shall be marked on all unit and intermediate packs in accordance with the identification marking provisions of MIL-STD-129.

5.3.2 Civil agency and industrial. The marking for civil agency acquisitions shall be in accordance with Fed. Std. No. 123. Industrial marking shall be in accordance with MIL-STD-1188.

5.4 General.

5.4.1 Exterior containers. Exterior containers (see 5.2.1, 5.2.2 and 5.2.3) shall be of a minimum tare and cube consistent with the protection required and shall contain equal quantities of identical stock numbered items to the greatest extent practicable.

5.4.2 Packaging inspection. The inspection of these packaging requirements shall be in accordance with 4.6.3.

5.4.3 Army acquisitions.

5.4.3.1 Level A packing. In addition to that specified 5.2.1, metal strapping shall conform to QQ-S-781, type I, finish A. When the gross weight exceeds 200 pounds or the container length and width is 48 x 24 inches or more and the weight exceeds 100 pounds, 3 x 4 inch skids (laid flat) shall be applied in accordance with the requirements of the container specification. If not described in the container specification, the skids shall be applied in a manner which will adequately support the item and facilitate the use of material handling equipment.

5.4.3.2 Level A and B unitization. Unitization (see 5.2.4) shall be necessary when skids are not required (see 5.4.3.1), when quantities per destination exceed either a total of 250 pounds (excluding the pallet), or when the volume equals 20 cubic feet or more and the container size permits the use of one of the pallet patterns of MIL-STD-147. A quantity of containers, packed as specified in 5.4.3.1, except that the container strapping may be omitted, shall be placed on a pallet, load type I, conforming to MIL-STD-147. The pallet shall conform to NN-P-71, type IV, using group I or II woods. The loads shall be bonded to the pallet by strapping conforming to QQ-S-781, type I, finish A, or shrink film conforming to L-P-378, type IV. Stretch wrap in accordance with MIL-STD-147 is authorized for shipments within the continental United States and for all containerized shipments.

6. NOTES

6.1 Intended use. The filters covered by this specification are intended for use in power lines to attenuate undesired radio-frequency signals generated from electromagnetic sources. Filters covered in this specification are intended for commercial/industrial applications and should not be used in military systems needing stringent environmental and electrical requirements.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T11:37Z
Check the source to verify that this is the current version before use.

6.2 Ordering data. Purchasers should select the preferred options permitted herein and include the following information in procurement documents:

a. Title, number and date of this specification.
b. Title, number and date of the applicable specification sheet and complete part number (see 3.1).
c. Inspection of industrial packaging (see 4.6.3).
d. Levels of preservation and packing required (see 5.1 and 5.2).
e. If special or additional identification marking is required (see 5.3.1).

6.3 Qualification. With respect to products requiring qualification, awards will be made only for products which are at the time set for opening of bids, qualified for inclusion in the applicable qualified products list whether or not such products have actually been so listed by that date. The attention of the contractors is called to this requirement, and manufacturers are urged to arrange to have the products that they propose to offer to the Federal Government tested for qualification, in order that they may be eligible to be awarded contracts or orders for the products covered by this specification. The activity responsible for the qualified products list is the Defense Electronics Supply Center, ATTN: DESC-E, Dayton, OH 45444, and information pertaining to qualification of products may be obtained from that activity.

MILITARY INTERESTS:

Custodians

Army - ER
Navy - EC
Air Force - 85

Review Activities

Army - AR, MI
Navy - SH
Air Force - 11, 17, 99

User Activities

Army - AT, AV, ME
Navy - AS, MC, OS, YD
Air Force - 19

CIVIL AGENCY COORDINATING ACTIVITIES:

GSA - FSS
NCS -
NASA - MSF, LRC, JFK

PREPARING ACTIVITY:

DLA - ES

DOD project 5915-0271

U.S. GOVERNMENT PRINTING OFFICE : 1984 - 421-595/3685

Orders for this publication are to be placed with General Services Administration, acting as an agent for the Superintendent of Documents. See section 2 of this specification to obtain extra copies and other documents referenced herein.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T11:37Z
Check the source to verify that this is the current version before use.

APPENDIX

PROCEDURE FOR QUALIFICATION INSPECTION

10. SCOPE

10.1 Scope. This appendix details the procedures for qualification inspection. The procedure for extending qualification is also outlined herein. This appendix is a mandatory part of the specification. The information contained herein is intended for compliance only.

20. APPLICABLE DOCUMENTS

This section is not applicable to this appendix.

30. SUBMISSION

30.1 Qualification based on Underwriters' Laboratories Recognized Components Program. Qualification of a filter may be obtained by having that part recognized under Underwriters' Laboratories Recognized Components Program. The manufacturer shall submit a letter of certification to the qualifying activity stating the following:

a. The tests of table I, have been performed by Underwriters' Laboratories.
b. The Underwriters' file number.
c. The government part number.
d. The manufacturer's part number.
e. The manufacturer's certification that the part being submitted for qualification meets all the requirements as specified (see 3.1).

30.2 Qualification testing in accordance with table I. A sample consisting of eleven filters for which qualification is sought shall be submitted to the tests of table I.

30.3 Description of items. The manufacturer shall submit a detailed description in writing to the qualifying activity, DESC-E, Dayton, OH 45444, of the filters being submitted, including the type and quantity of impregnant, material, thickness, and applied finish of case, and details of terminals.

40. EXTENT OF QUALIFICATION

40.1 Extent of qualification. Qualification for one filter may be the basis for qualification of another filter as indicated below:

a. For filters in the same specification sheet, with the same case, and electrical schematic, qualification of the highest and lowest current parts shall extend qualification to all filters with intermediate ratings.
b. For filters in the same specification sheet, qualification of one electrical schematic may be the basis for qualification of another schematic as indicated in table V.

TABLE V. Extent of qualification for electrical schematics.

Specification sheet	Qualification of electrical schematic	Will qualify electrical schematic
W-F-2190/1 through /6	B A	A, B A

c. Qualification of one specification sheet may be the basis for qualification of another specification sheet as indicated in table VI.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T11:37Z
Check the source to verify that this is the current version before use.

TABLE VI. Extent of qualification for specification sheets.

Qualification of specification sheet W-F-2190/	Will qualify 1/ specification sheet W-F-2190/
1	1, 2, 3
2	1, 2, 3
3	1, 2, 3
4	4, 5
5	4, 5
6	6, 10
7	7, 8, 9
8	7, 8, 9
9	7, 8, 9
10	6, 10
11	11, 12
12	11, 12

1/ This extension of qualification shall be within the constraints fo 40.1a and b.

d. For filters qualified in accordance with UL Recognition Program, the extent of qualification in 40.1a through 40.1c applies only if each filter has already been UL Recognized.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T11:37Z
Check the source to verify that this is the current version before use.