W–B–811b
JUNE 13, 1962

SUPERSEDING
Int. Fed. Spec. W–B–00811a(GSA–FSS)
March 21, 1960 and
Fed. Spec. W–B–811
March 5, 1953

FEDERAL SPECIFICATION

BUSWAY SYSTEM, POWER, ELECTRICAL, 600 VOLTS

This specification was approved by the Commissioner, Federal Supply Service, General Services Administration, for the use of all Federal agencies.

1. SCOPE AND CLASSIFICATION

1.1 Scope. This specification covers busways, consisting of an enclosure containing factory-mounted conductors of copper or aluminum bars, rods, or tubes and associated fittings for use in electrical power systems at not more than 600 volts nor 400 cycles per second.

1.2 Classification.

1.2.1 *Types, classes, and styles.* Busway systems furnished under this specification shall be of the following types, classes, and styles, as specified (see 6.1).

Types:

Type I.—Feeder busway system, indoor.
Type II.—Feeder busway system, outdoor.
Type III.—Plug-in busway system, indoor.
Type IV.—Plug-in feeder busway system, indoor.
Type V.—Trolley busway system, indoor.
Type VI.—Trolley and plug-in busway system, indoor.

Classes:

Class 1.—With copper conductors.
Class 2.—With aluminum conductors.

Styles:

Style A.—With ventilated enclosures.
Style B.—With unventilated enclosures.

2. APPLICABLE SPECIFICATIONS, STANDARDS, AND OTHER PUBLICATIONS

2.1 Specifications and standards. The following specifications and standards, of the issues in effect on date of invitation for bids, form a part of this specification:

Federal Specifications:

PPP–B–621—Boxes, Wood, Nailed and Lock Corner
PPP–B–636—Box, Fiberboard.
PPP–T–60 —Tape, Pressure Sensitive, Waterproof. For Packaging and Sealing.

Federal Standards:

Fed. Std. No. 102—Preservation, Packaging, and Packing Levels.
Fed. Std. No. 123—Marking for Domestic Shipment (Civilian Agencies).

(Activities outside the Federal Government may obtain copies of Federal Specifications, Standards, and Handbooks as outlined under General Information in the Index of Federal Specifications, Standards, and Handbooks and at the prices indicated in the Index. The Index, which includes cumulative monthly supplements as issued, is for sale on a subscription basis by the Superintendent of Documents, U. S. Government Printing Office, Washington 25, D. C.

(Single copies of this specification and other product specifications required by activities outside the Federal Government for bidding purposes are available without charge at the General Services Administration Regional Offices in Boston, New York, Wash-

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T11:33Z
Check the source to verify that this is the current version before use.

ington, D. C., Atlanta, Chicago, Kansas City, Mo., Dallas, Denver, San Francisco, and Auburn, Wash.

(Federal Government activities may obtain copies of Federal Specifications, Standards, and Handbooks and the Index of Federal Specifications, Standards, and Handbooks from established distribution points in their agencies.)

Military Specifications:

MIL–C–16173—Corrosion Preventive Compound, Solvent, Cutback, Cold Applications.

MIL–L–10547—Liners, Case, Waterproof.

Military Standards:

MIL–STD–129—Marking for Shipment and Storage.

(Copies of Military Specifications and Standards required by contractors in connection with specific procurement functions should be obtained from the procuring activity or as directed by the contracting officer.)

2.2 Other publications. The following publications, of the issues in effect on date of invitation for bids, form a part of this specification.

Underwriters' Laboratories, Inc., Standard:

UL–857—Standard for Busways and Associated Fittings.

(Application for copies should be addressed to the Underwriters' Laboratories, Inc., 161 Sixth Avenue, New York, N. Y.; 207 East Ohio Street, Chicago, Illinois, or 1655 Scott Boulevard, Santa Clara, California.)

3. REQUIREMENTS

3.1 General. Busway systems covered by this specification shall conform to the requirements of Underwriters' Laboratories, Inc., Standard UL–857 for Busways and Associated Fittings.

3.2 Rating and operation. The busway shall be rated in amperes, volts, and frequency and shall operate on a.c. and/or d.c., as specified (see 6.1).

3.3 Fire and casualty hazards.

3.3.1 Each bidder shall submit to the contracting agency proof that the equipment he proposes to supply under this specification conforms to the requirements of UL–857 for Busways and Associated Fittings. The label or listing of the Underwriters' Laboratories, Inc., may be accepted as evidence that the equipment conforms to this requirement.

3.3.2 In lieu of the label or listing, the bidder may submit independent proof satisfactory to the contracting agency that his equipment conforms to the published standards, including methods of tests of UL–857, for Busways and Associated Fittings.

3.3.3 Compliance with the above preliminary requirements does not absolve the bidder from complete compliance with the other requirements of this specification in order to secure acceptance of his busway system.

4. SAMPLING, INSPECTION AND TEST PROCEDURES

4.1 Supplier responsibilities for inspection. The supplier is responsible for the performance of all inspection requirements as specified herein. Except as otherwise specified, the supplier may utilize his own or any other inspection facilities and services acceptable to the Government. Inspection records of the examination and tests shall be kept complete and available to the Government as specified in the contract or order. The Government reserves the right to perform any of the inspections set forth in the specification where such inspections are deemed necessary to assure supplies and services conform to prescribed requirements.

4.2 Sampling, inspection, and tests shall be performed as set forth in UL–857 for Busways and Associated Fittings.

5. PREPARATION FOR DELIVERY

(For civil agency procurement, the levels of preservation, packaging and packing used are defined in Fed. Std. No. 102).

5.1 Preservation.

5.1.1 *Level A.*

5.1.1.1 *Enclosures and receptacles.* The enclosures of busway systems, including plug-in

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T11:33Z
Check the source to verify that this is the current version before use.

devices, shall have receptacle slots, ventilating openings, access doors and covers, sealed by means of pressure-sensitive tape conforming to PPP–T–60, type III, class 1, so as to prevent the free entrance of dust. The unpainted exterior ferrous-metal surfaces of enclosures and receptacles shall be protected from corrosion by the brush application of contact preservative conforming to MIL–C–16173, grade 1.

5.1.1.2 *Associated parts.* Associated parts, such as switches, circuit-breakers, fuses, fuseholders, wire connectors, etc., shall be preserved in conformance with the manufacturer's standard commercial practice.

5.1.2. *Level B or C.* Busway systems and associated parts shall be preserved in conformance with the manufacturer's commercial practice.

5.2 Packaging.

5.2.1 *Level A, B or C.*

5.2.1.1 *Trolley and feeder systems.* The enclosures of trolley and feeder busways, preserved and sealed as specified in 5.1.1, shall not require any further packaging.

5.2.1.2 *Plug-in devices.* Plug-in devices, preserved as specified in 5.1.1, shall be individually boxed in fiberboard boxes conforming to PPP–B–636, type I, class 1, style RSC. Closure, sealing, and strapping of the boxes shall be in accordance with the appendix to the box specification.

5.2.1.3 *Associated parts.* Parts shall be packed in accordance with commercial practice.

5.3 Packing

5.3.1 *Level A.* Busway systems, including plug-in devices and other associated parts, preserved and packaged as specified in 5.1 and 5.2 shall be packed in nailed wood boxes conforming to PPP–B–621, class 2, style 2, 2½, 3, or 4 for type 3 load. Packaged plug-in devices and other packaged parts shall be positioned and cushioned within the shipping container in such a manner as to prevent movement and damage during shipment and handling. Each shipping container shall be lined with a waterresistant barrier material conforming to MIL–L–10547, type I or II, grades B or C, class 2. Strapping shall be in accordance with the appendix to the box specification and shall be zinc coated.

5.3.2 *Level B.* Busway systems, including plug-in devices and other associated parts, preserved and packaged as specified in paragraph 5.1 and 5.2, shall be packed in fiberboard boxes conforming to PPP–B–636, type I, class 1, style RSC or FPF. Plug-in devices and other associated parts shall be packed within the fiberboard shipping container as specified in 5.3.1. Closure and strapping shall be in accordance with the appendix to PPP–B–636.

5.3.3 *Level C.* Busway systems, including plug-in devices and associated parts, shall be packaged and packed in substantial commercial containers of the type, size, and kind commonly used for the purpose, so constructed as to insure acceptance and safe delivery by common or other carriers at the lowest rate to point of delivery called for in the contract or purchase order.

5.4 Marking.

5.4.1 *Civil agencies.* In addition to any special marking required by the contract or order, shipping containers shall be marked in accordance with Fed. Std. No. 123.

5.4.2 *Military agencies.* In addition to any special marking required by the contract or order, shipping containers shall be marked in accordance with MIL–STD–129.

6. NOTES

6.1 Ordering data. Purchasers should exercise any desired options offered herein, and procurement documents should specify the following:

(*a*) Title, symbol, and date of this specification.

(*b*) Type, class, ~~and style~~ of system (see 1.2.1).

(*c*) Rating and operation (see 3.2).

(*d*) Administrative provisions for inspection records (see 4.1).

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T11:33Z
Check the source to verify that this is the current version before use.

(*e*) Applicable levels of packaging and packing (see 5.).

6.2 This specification does not include all types, classes, grades, sizes, etc., of the commodity indicated by the title of the specification, or which are commercially available, but is intended to cover the types, etc., which are normally procured to meet Federal Government requirements.

6.3 Transportation description. Transportation description and minimum weights applicable to this commodity are:

Rail:

Bus bar system, consisting of housings containing bus bars, insulators, with or without tapping connectors or trolleys.

Carload minimum weight 30,000 pounds.

Motor:

Bus bar system, consisting of housings containing bus bars and insulators, with or without tapping connectors or trolleys.

Truckload minimum weight (W) 30.6 pounds, (W) subject to Rule 34, National Motor Freight Classification.

Notice.—When Government drawings, specifications, or other data are used for any purpose other than in connection with a definitely related Government procurement operation, the United States Government thereby incurs no responsibility nor any obligation whatsoever; and the fact that the Government may have formulated, furnished, or in any way supplied the said drawings, specifications, or other data, is not to be regarded by implication or otherwise as in any manner licensing the holder or any other person or corporation, or conveying any rights or permission to manufacture, use, or sell any patented invention that may in any way be related thereto.

MILITARY INTEREST:
Army—E
Navy—Y
Air Force—Rome Air Materiel Area

Copies of this specification may be purchased for 5 cents each.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T11:33Z
Check the source to verify that this is the current version before use.