INTERIM FEDERAL SPECIFICATION

CIRCUIT BREAKER (PLUG TYPE)

This Interim Federal Specification was developed by General Services Administration, Federal Supply Service, Standardization Division, Washington, D. C. 20406, based upon currently available technical information. It is recommended that Federal agencies use it in procurement and forward recommendations for changes to the preparing activity at the address shown above.

1. SCOPE AND CLASSIFICATION

1.1 Scope. The circuit breakers furnished under this specification shall be of the edison screw base type for the protection of 125-volt alternating current service (see 6.1).

1.2 Classification. The circuit breakers furnished under this specification shall be of one type (see 1.1) and the following sizes, as specified (see 6.2):

Size I - 10 Amperes
Size II - 15 Amperes
Size III - 20 Amperes
Size IV - 30 Amperes

2. APPLICABLE DOCUMENTS

2.1 Specifications and standards. The following specifications and standards, of the issues in effect on date of invitation for bids or request for proposal, form a part of this specification to the extent specified herein.

Federal Specification:

PPP-B-636 - Box, Fiberboard.

Federal Standards:

Fed. Std. No. 123 - Marking for Domestic Shipment (Civilian Agencies).

(Activities outside the Federal Government may obtain copies of Federal Specifications, Standards, and Handbooks as outlined under General Information in the Index of Federal Specifications and Standards and at the prices indicated in the Index. The Index, which includes cumulative monthly supplements as issued, is for sale on a subscription basis by the Superintendent of Documents, U.S. Government Printing Office, Washington, D.C., 20402.

(Single copies of this specification and other product specifications required by activities outside the Federal Government for bidding purposes are available without charge at the General Services Administration Regional Offices in Boston, New York, Washington, D.C., Atlanta, Chicago, Kansas City, Mo., Dallas, Denver, San Francisco, Los Angeles, and Seattle, Wash.

(Federal Government activities may obtain copies of Federal Specifications, Standards, and Handbooks and the Index of Federal Specifications and Standards from established distribution points in their agencies.)

Military Specifications:

MIL-P-116 - Preservation, Methods of.

Military Standards:

MIL-STD-105 - Sampling Procedures and Tables for Inspection by Attributes.
MIL-STD-129 - Marking for Shipment and Storage.

(Copies of Military Specifications and Standards required by contractors in connection with specific procurement functions should be obtained from the procuring activity or as directed by the contracting officer.)

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T11:34Z
Check the source to verify that this is the current version before use.

2.2 Other publications. The following documents of the issue in effect on date of invitation for bids or request for proposal, form a part of the specification to the extent specified herein:

Underwriters' Laboratories, Inc. Standards (UL):

UL 489 - Standard for Branch-Circuit and Service Circuit-Breakers.
UL 60 I 16 - Listing-Circuit Protectors.

(Applications for copies should be addressed to Underwriters' Laboratories, Inc., Walt Whitman Road, Melville, New York 11749; 207 East Ohio Street, Chicago, Illinois 60611; or 1655 Scott Boulevard, Santa Clara, California 95050).

3. REQUIREMENTS.

3.1 Fire and casualty hazards.

3.1.1 Each contractor shall submit to the contracting agency proof that the circuit breaker he proposes to supply under this specification conforms to the applicable requirements of Underwriters' Laboratories, Inc., UL 489, Standard for Branch-Circuit and Service Circuit-Breakers and UL listing number 60 I 16, Circuit Protectors. The label, or listing with re-examination, of the Underwriters' Laboratories, Inc. may be accepted as evidence that the circuit breaker conforms to this requirement.

3.1.2 In lieu of the label, or listing with re-examination, the contractor may submit independent proof, satisfactory to the contracting agency, that the circuit breaker conforms to the applicable requirements of the published standards including methods of tests of UL 489 and listing 60 I 16.

3.1.3 Compliance with the above preliminary requirements in regard to fire and casualty hazards does not absolve the contractor from complete compliance with the requirements of this specification in order to secure acceptance of his material.

4. QUALITY ASSURANCE PROVISIONS

4.1 Responsibility for inspection. Unless otherwise specified in the contract or purchase order, the supplier is responsible for the performance of all inspection requirements as specified herein. Except as otherwise specified, the supplier may utilize his own facilities or any commercial laboratory acceptable to the Government. The Government reserves the right to perform any of the inspections set forth in the specification where such inspections are deemed necessary to assure that supplies and services conform to prescribed requirements.

4.1.1 Unless otherwise specified in the contract or purchase order, such inspections by the contractor may be performed on a statistical or production lot basis to assure that the quality of manufacture is equal to the standards set by Underwriters' Laboratories, Inc.

4.2 Inspection of preparation for delivery. An inspection shall be made to determine that the packaging, packing and marking comply with the requirements in section 5 of this specification. Defects shall be scored in accordance with table I. For examination of interior packaging the sample unit shall be one shipping container fully prepared for delivery, selected at random just prior to the closing operations. Sampling shall be in accordance with MIL-STD-105. Defects of closure listed shall be examined on shipping containers fully prepared for delivery. The lot size shall be the number of shipping containers in the end item inspection lot. The inspection level shall be S-2 with an acceptable quality level (AQL) of 2.5 defects per hundred units.

Table I - Classification of preparation for delivery defects.

Examine	Defects
Markings (exterior and interior)	Omitted; incorrect; illegible; improper size, location, sequence, or method of application.
Materials	Any component missing or damaged.
Workmanship	Inadequate application of components such as incomplete closure of container flaps, loose, strapping, or distortion of container.
Contents (exterior container)	Number per container is more or less than required. Net weight exceeds requirements.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T11:34Z
Check the source to verify that this is the current version before use.

5. PREPARATION FOR DELIVERY

5.1 Packaging. Packaging shall be level A, B, or C, as specified (see 6.2).

5.1.1 Level A. Twenty-five circuit breakers of one size shall be packaged in accordance with method IC-2 of MIL-P-116.

5.1.2 Level B. Twenty-five circuit breakers of one size shall be packaged in a close-fitting commercial container. The container shall be closed.

5.1.3 Level C. The circuit breakers shall be packaged to afford protection against corrosion and damage during shipment from the supplier to the initial destination.

5.2 Packing. Packing shall be level A, B, or C, as specified (see 6.2).

5.2.1 Level A. Unit packages of circuit breakers of one size in quantities as specified (see 6.2) shall be packed in a close-fitting box conforming to PPP-B-636, class weather-resistant. The box shall be closed, waterproofed and strapped in accordance with the appendix to the box specification.

5.2.2 Level B. Ten unit packages of circuit breakers of one size shall be packed in a close-fitting box conforming to PPP-B-636, class domestic. The box shall be closed in accordance with method I of the appendix to the box specification.

5.2.3 Level C. The circuit breakers shall be packed to insure carrier acceptance and safe delivery at destination in containers complying with the rules and regulations applicable to the mode of transportation.

5.3 Standard packaging (civil agencies). The standard packaging and packing for civil agencies shall be as specified in 5.1.2 and 5.2.2, respectively.

5.4 Marking.

5.4.1 Civil agencies. In addition to markings required by the contract or order, the interior packages and shipping containers shall be marked in accordance with Fed. Std. No. 123.

5.4.2 Military agencies. In addition to markings required by the contract or order, the interior packages and shipping containers shall be marked in accordance with MIL-STD-129.

6. NOTES

6.1 Intended use. The items furnished under this specification are intended for use as circuit protectors in fuse holders in lieu of a plug type fuse of the same rating.

6.2 Ordering data. Purchasers should select the preferred options permitted herein and include the following information in procurement documents:

(a) Title, symbol, and date of this specification.
(b) Size of circuit breaker required (see 1.2).
(c) Responsibility for inspection, if other than specified (see 4.1).
(d) Selection of applicable level of packaging and packing required (see 5.1 and 5.2).
(e) Quantity of unit packages required in shipping container (see 5.2.1).
(f) Marking, if other than specified (see 5.4).

6.3 Standard pack for civil agencies. The standard pack requirements in 5.3 are intended for use in procurements of stores stock replenishments. Procuring officers should use the standard pack requirements when it is known that the material will be shipped from a supplier to a domestic warehouse, supply depot or intermediate storage point for temporary storage, subsequent issue or shipment to eventual user.

GSA DC 67-13095

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T11:34Z
Check the source to verify that this is the current version before use.