W-F-1662A
INTERIM AMENDMENT-2
March 10, 1976
SUPERSEDING
Int. Amendment-1
November 15, 1974

INTERIM AMENDMENT

TO

FEDERAL SPECIFICATION

FIXTURE, LIGHTING (FLUORESCENT, ALTERNATING CURRENT, RECESSED AND SURFACE CEILING)

This interim amendment was developed by the General Services Administration, Federal Supply Service, Washington, DC 20406, based upon currently available technical information. It is recommended that Federal agencies use it in procurement and forward recommendations for changes to the preparing activity at the address shown above.

The General Services Administration has authorized Federal agencies to use this interim amendment as a part of Federal Specification W-F-1662A, dated July 1, 1974.

PAGE 1

Paragraph 1.2, delete the lead sentence in its entirety and replace with the following:

"Lighting fixtures (luminaires) furnished under this specification shall be of the direct lighting style, having the light distribution specified in 3.15.1, and shall be of the below specified classes, types, sizes, mountings, and lamp arrangements. The required class, type, size, mounting and lamp arrangement shall be indicated by purchaser (see 6.1)."

Paragraph 1.2, under "Types" delete all type designations and the subsequent "Note" and replace with the following:

"Type F - Recessed luminaire having horizontal flanges which conceal the edges of the ceiling opening. The fixture is mounted off integral adjustable supports or separate yokes.

Type FZ - Recessed luminaire the same as above Type F except that it may incorporate tile stops.

Type H - Recessed luminaire having horizontal flanges which conceal the edges of the ceiling opening and may incorporate tile stops. The fixture is end supported by an exposed ceiling member or a hook-on mounting bracket over a concealed ceiling member.

Type G - Recessed luminaire having edges which rest on an exposed inverted tee.

Type GR - Recessed luminaire the same as Type G above except that it is used in concealed tee ceiling system having a splay which is not a part of the luminaire.

Type GZ - Recessed luminaire having edges which lie on exposed ceiling members running parallel to the lamp direction. The ends of the fixture butt directly against tile.

Type D - Recessed luminaire having (1) turned-up edges which are parallel to the lamp and act as a tile support and (2) turned-up edges which are across the end of the fixture and align with the ceiling opening. The fixture is mounted off its ends by a hook over hangers.

Type SL - Recessed luminaire having horizontal flanges which conceal the edges of the ceiling opening. The fixture is not symmetrical about its center line. The fixture is mounted off integral adjustable supports or separate yokes.

Type Z - Recessed luminaire having vertical turned-up edges which align with the ceiling opening. The fixture is mounted off integral adjustable hangers or separate yokes.

Type L - Recessed luminaire having vertical turned-up edges which align with the ceiling opening. The fixture is mounted off integral adjustable supports or separate yokes.

Type M - Recessed luminaire having vertical turned-up edges which are parallel to the lamp and align the luminaire with a concealed tee-bar suspension system. The fixture is mounted off integral adjustable supports or separate yokes.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T11:34Z
Check the source to verify that this is the current version before use.

NOTE: The types cited above are National Electrical Manufacturers Association (NEMA) type designations and, except as may otherwise be specified, shall be in accordance with NEMA Standards Publication/No. LE 1-1974. Refer to this publication for a more detailed description of the above types."

PAGE 2

Paragraph 1.2, under "Sizes", delete the description for "Size 1" and replace with the following:

"Size 1 - 1 foot x 4 feet (in Lamp Arrangement A for all fixture classes and in Lamp Arrangement B for Class III and V fixtures only)."

PAGE 3

Paragraph 2.1, under "Federal Standards", delete the reference to "Fed. Test Method Std. No. 151" in its entirety and replace with:

"Fed. Test Method Std. No. 141 -.Paint, Varnish, Lacquer, and related materials; Methods of Inspection, Sampling, and Testing."

Paragraph 2.2, under "National Electrical Manufacturers Association (NEMA) Publications:", delete the reference to "Pub. No. LE 1-1969 - Fluorescent Luminaires" and replace with:

"NEMA Standards Publication/No. LE 1-1974"

PAGE 4

Paragraph 2.2, under the heading "American Society for Testing and Materials (ASTM) Standards:", add the following reference:

"No. B 117 - Standard Method of Salt Spray (Fog) Testing."

PAGE 5

Paragraph 3.1.1, revise the second sentence to read as follows:

"Listing by the UL will be accepted as evidence that the product conforms to this requirement."

Paragraph 3.2.2, revise the first sentence to read as follows:

"For lamp arrangement A, the lamps shall be equidistant from the center of the fixture; for lamp arrangement B, the middle lamp shall be on the centerline of the fixture and the two outside lamps shall be equidistant from the centerline of the fixture; for lamp arrangement C, the two outside lamps and the two inside lamps shall be equidistant from the centerline of the fixture."

PAGE 6

Paragraph 3.3.1.2, at end of paragraph delete the reference to "NEMA Pub. No. LE 1-1969" and replace with the following:

"NOTE: Refer to Part 2 of NEMA Standards Publication/No. LE 1-1974 for a more detailed description of modes of operation."

Paragraph 3.3.1.2.1, revise the last sentence to read:

"For heat exchange the design shall be such that return air passes into end slots and through lamp compartment to plenum or ducts."

Paragraph 3.3.1.2.3, end of fourth sentence, delete the wording "ficture engs" and replace with the words "fixture ends."

Paragraph 3.3.1.2.4, in paragraph title, delete the word "diffurers" and replace with "diffusers."

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T11:34Z
Check the source to verify that this is the current version before use.

Paragraph 3.3.1.2.4, beginning of third sentence, delete the word "deffusers" and replace with "diffusers."

PAGE 9

Paragraph 3.4.4.1, delete in its entirety and substitute the following:

"3.4.4.1 Class I, II and IV. Class I, II, and IV luminaires shall have flat bottom closures of the lens type, with lens being self supporting and of one piece construction. Bottom closures shall be either flush with or regressed into bottom of fixture housing. The lens of bottom closure shall be of plastic or glass and shall have a uniform overall pattern of prisms or spherical segments on either one or both sides. Side panels, if provided on Class IV luminaires, shall also be of the lens type and constructed of plastic or glass. All plastic lenses shall be of acrylic, meeting ASTM D-788 requirements (see 3.8). Glass side panels and size 1 and 2 luminaire glass lenses may be tempered or annealed, unless tempered glass only is specified. If tempered glass only is desired, the specification user shall so indicate (see 6.1). On size 4 luminaires, glass bottom closure lenses shall be tempered. The overall cross sectional thickness of plastic side panels and size 1 and 2 luminaire plastic bottom closure lenses shall be a nominal 0.125 inch (minimum 0.115 inch). The overall cross sectional thickness of size 4 luminaire plastic lenses shall be a nominal 0.187 inch (minimum 0.182 inch). The overall cross sectional thickness of glass side panels and bottom closures lenses shall be as indicated in UL Standard 57. For plastic bottom closures, lens sag - the vertical distance that bottom center of lens sags below lens periphery, when fixture with bottom closure installed is mounted in a normally functioning position – shall not exceed 1/8 inch for size 1 fixtures; 1/4 inch for size 2 fixtures; and 1/2 inch for size 4 fixtures. Bottom closure and engaging latches shall be constructed in such manner as to preclude accidental (unintentional) release or disassembly of bottom closure, or portions thereof, from fixture housing when in either the latched or open position. The fixture housing and bottom closure shall incorporate a light trap for preclusion of light leaks. Additionally, lens frame(s) shall be constructed in such manner as to permit the replacement of lenses without the use of tools other than screwdrivers or pliers. Also, lens frames shall be sufficiently rigid so as to preclude sag of more than 0.047 inch below luminaire housing flanges. Bottom closure and side panel lenses may be tinted, provided that photometric and other requirements of this specification are adhered to."

Paragraph 3.4.5.1, delete in its entirety and replace with the following:

"3.4.5.1 Recessed luminaires (Class I, II, and III). Fixture shall be furnished with all necessary mounting hardware and shall be so constructed that ceiling installation can be safely and readily effected. Fixture and mounting design shall be such as as to preclude accidental disassembly (falling) of any luminaire or portions thereof from ceiling. Specific mounting requirements, if desired, shall be indicated in 6.1. Otherwise, fixture construction and mounting hardware shall be the suppliers option provided that all applicable requirements of this specification are adhered to."

PAGE 10

Paragraph 3.4.6, second sentence, delete in its entirety, and replace with the following:

"Unless otherwise specified (see 6.1), length and width tolerances for Class I, II, and III recessed fixtures shall be as cited in NEMA Standards Publication No. LE 1-1974.

PAGE 11

Paragraph 3.9.1.1, end of last sentence, delete the word "date" and replace with the word "data."

PAGE 15

Paragraph 4.4.1, bottom of Table II, revise the wording "Workmanship, not a specified" to read "Workmanship not as specified."

PAGE 16

Paragraph 4.5.2, first sentence, delete reference to "Method 811.1 of Fed. Test Method No. 151" and replace with "ASTM Standard No. B 117."

GSA DC 78-7004

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T11:34Z
Check the source to verify that this is the current version before use.