MIL-F-51541(EA)
14 December 1988
SUPERSEDING
(See section 6)

MILITARY SPECIFICATION

FILTER, GAS, FFU-17/E, 600 CFM

This specification is approved for use within the Chemical Research, Development and Engineering Center, Department of the Army, and is available for use by all Departments and Agencies of the Department of Defense.

1. SCOPE

1.1 Scope. This specification covers one type of gas filter.

2. APPLICABLE DOCUMENTS

2.1 Government documents.

2.1.1 Specifications and standards. The following specifications and standards form a part of this specification to the extent specified herein. Unless otherwise specified, the issues of these documents shall be those listed in the issue of the Department of Defense Index of Specifications and Standards (DODISS) and supplement thereto, cited in the solicitation.

SPECIFICATIONS

FEDERAL

BB-F-1421 - Fluorocarbon Refrigerants.

MILITARY

MIL-C-13724 - Charcoal, Activated Impregnated, ASC.
MIL-B-117 - Bag, Sleeve and Tubing - Interior Packaging.
MIL-B-131 - Barrier Materials, Watervaporproof, Greaseproof, Flexible, Heat-Sealable.

: Beneficial comments (recommendations, additions, deletions) and any pertinent data which may be of use in improving this document should be addressed: to: Commander, U.S. Army Chemical Research, Development and Engineering Center, ATTN: SMCCR-SPT-S, Aberdeen Proving Ground, MD 21010-5423 by using the self-addressed Standardization Document Improvement Proposal (DD Form 1426) appearing at the end of this document or by letter.

AMSC N/A FSC 4240

DISTRIBUTION STATEMENT A. Approved for public release; distribution is unlimited.

Source: https://assist.dla.mil -- Downloaded: 2026-10-22T21:04Z
Check the source to verify that this is the current version before use.

STANDARDS

FEDERAL

FED. TEST METHOD STD. NO. 101 - Test Procedures for Packaging Materials.

MILITARY

MIL-STD-105 - Sampling Procedures and Tables for Inspection by Attributes.
MIL-STD-414 - Sampling Procedures and Tables for Inspection by Variables for Percent Defective.
MIL-STD-282 - Filter Units, Protective Clothing, Gas Masks Components and Related Products, Performance Test Methods.

2.1.2 Drawings. The following drawings form a part of this specification to the extent specified herein. Unless otherwise specified, the issues shall be those in effect on the date of the solicitation.

DRAWINGS

U.S. ARMY ARMAMENT, MUNITIONS AND CHEMICAL COMMAND

CHEMICAL RESEARCH, DEVELOPMENT AND ENGINEERING CENTER

5-19-6505 - Filter, Gas, FFU-17/E.

SPECIAL PACKAGING INSTRUCTIONS (SPI)

P5-19-6505 - Filter, Gas.

(Copies of specifications, standards, and drawings required by contractors in connection with specific acquisition functions should be obtained from the contracting activity or as directed by the contracting activity.)

2.2 Publications. The following document forms a part of this specification to the extent specified herein. Unless otherwise specified, the issues of the documents which are DOD adopted shall be those listed in the issue of the DODISS specified in the solicitation. Unless otherwise specified, the issues of documents not listed in the DODISS shall be the issue of the nongovernment documents which is current on the date of the solicitation.

AMERICAN SOCIETY FOR TESTING AND MATERIALS (ASTM)

D 2867 - Moisture Content of Activated Carbon.

(Applications for copies should be addressed to ASTM, 1916 Race Street, Philadelphia, PA 19103.)

Source: https://assist.dla.mil -- Downloaded: 2026-10-22T21:04Z
Check the source to verify that this is the current version before use.

(Nongovernment standards and other publications are normally available from the organizations which prepare or which distribute the documents. These documents also may be available in or through libraries or other informational services.)

2.3 Order of precedence. In the event of a conflict between the text of this specification and the references cited herein (except for associated detail specifications, specification sheets or MS standards), the text of this specification shall take precedence. Nothing in this specification, however, shall supersede applicable laws and regulations unless a specific exemption has been obtained.

3. REQUIREMENTS

3.1 Materials and components.

3.1.1 Materials. All materials cited on Drawing 5-19-6505 and subsidiary drawings shall conform to the specifications listed thereon or to the specific characteristics set forth on the drawings.

3.1.2 Components. All components for the gas filter shall conform to the specifications and drawings listed on Drawing 5-19-6505 and subsidiary drawings.

3.1.2.1 Terne steel parts. Terne steel parts shall be recoated after perforating operations.

3.2 Manufacture and assembly. The gas filter shall be assembled and marked in accordance with Drawing 5-19-6505 (see 6.3).

3.3 Moisture content of charcoal sorbent. The moisture content of the charcoal sorbent in the filter shall not exceed 2.0 percent when tested as specified in 4.4.4.1.

3.4 Leakage. The gas filter shall not leak when dichlorodifluoromethane (R-12) conforming to type 12 of BB-F-1421 is introduced at the influent side of the filter as specified in 4.4.4.2 at the following parameters:

Airflow rate	120 ± 10 cfm
R-12 influent concentration	1000 V ppm
Airstream relative humidity	0 to 30 percent
Airstream temperature	75° ± 5°F

A leak is defined as the detection of more than 1 volume part per million (V ppm) at the effluent side of the filter within 2 minutes after the introduction of R-12.

3.5 Airflow resistance. The airflow resistance of the filter shall not exceed 1.25 inches of water at a 600 cubic feet per minute (cfm) airflow when tested as specified in 4.4.4.3.

Source: https://assist.dla.mil -- Downloaded: 2026-10-22T21:04Z
Check the source to verify that this is the current version before use.

3.6 Airflow resistance and dimethylmethylphosphonate (DMMP) gas life after rough handling. After the filter has been rough handled in accordance with 4.4.4.6 the filter shall show no evidence of cracks, dents or charcoal granule leakage. The filter shall comply with airflow resistance requirements (3.5) and the DMMP gas life shall be no less than 35 minutes when tested in accordance with 4.4.4.4 at the following test parameters:

Airflow rate	600 ± 30 cfm
Airstream temperature	110 ± 5°F
DMMP influent concentration	5.0 ± 0.1 mg/l
DMMP break concentration	0.04 ug/l

The DMMP gas life is defined as the time from the introduction of DMMP at the influent side of the filter to the detection of the specified break concentration at the effluent side of the filter.

3.7 Cyanogen chloride (CK) gas life of charboal sorbent. After completion of all manufacturing steps, the gas filter's charcoal shall comply with the CK gas sorbent requirement of MIL-C-13724 for grade IV unaged charcoal when tested in accordance with 4.4.4.5.

3.8 Preproduction. Prior to the start of regular production, a preproduction lot of gas filters of the same type shall be produced in accordance with this specification for examination and test (see 4.3).

3.9 Workmanship. The filter shall be free from foreign matter such as dirt, grease, oil, or viscous material or damage such as cracked or distorted frame or torn cloth.

4. QUALITY ASSURANCE PROVISIONS

4.1 Responsibility for inspection. Unless otherwise specified in the contract or purchase order, the contractor is responsible for the performance of all inspection requirements as specified herein. Except as otherwise specified in the contract or purchase order, the contractor may use his own or any other facilities suitable for the performance of the inspection requirements specified herein, unless disapproved by the Government. The Government reserves the right to perform any of the inspections set forth in the specification where such inspections are deemed necessary to assure supplies and services conform to prescribed requirements.

4.1.1 Responsibility for compliance. All items must meet all requirements of sections 3 and 5. The inspection set forth in this specification shall become a part of the contractor's overall inspection system or quality program. The absence of any inspection requirements in the specification shall not relieve the contractor of the responsibility of assuring that all products or supplies submitted to the Government for acceptance comply with all requirements of the contract. Sampling in quality conformance does not authorize submission of known defective material, either indicated or actual, nor does it commit the Government to acceptance of defective material.

Source: https://assist.dla.mil -- Downloaded: 202640-22T21:04Z
Check the source to verify that this is the current version before use.

4.1.2 Objective evidence. The contractor shall provide objective evidence acceptable to the contracting officer that the requirements of 3.1 and section 5 for which specific inspection has not been provided in this specification have been satisfied.

4.1.3 Government responsibility. Unless otherwise specified, the Government will be responsible for performance of the tests specified in 4.4.4.4 and 4.4.4.5. Samples will be forwarded to the laboratory designated by the contracting officer (see 6.2).

4.2 Classification of inspections. The inspection requirements specified herein are classified as follows:

(a) Preproduction inspection (see 4.3)
(b) Quality conformance inspection (see 4.4)

4.3 Preproduction inspection.

4.3.1 Lotting. A preproduction lot of four packaged filters and one empty sample unit pack container shall be manufactured in accordance with this specification using the same methods, materials, equipment and processes as will be used during regular production.

4.3.2 Sampling.

4.3.2.1 For examination. Each filter in the preproduction lot shall be examined in accordance with 4.3.3.1.

4.3.2.2 For nondestructive tests.

(a) Airflow resistance. Each filter in the preproduction lot shall be tested for airflow resistance.

(b) R-12 leakage. Each filter in the preproduction lot shall be tested for R-12 leakage.

(c) Moisture content of charcoal sorbent. A sample of charcoal (25 grams) shall be taken during the filling of each filter in the preproduction lot. Each sample shall be placed in a bag made from one layer of fines cloth (used in the manufacture of the filter), and shall experience the same conditions that its respective filter experiences until the filter is sealed into the required barrier bag.

(d) CK gas life of charcoal sorbent. A sample specimen of charcoal sorbent (approximately 1 pound) shall be taken during the filling of each filter in the preproduction lot. Each sample specimen shall be placed in a bag made of one layer of fines cloth (used in the manufacture of the filter), and shall accompany its respective filters to the packaging step. The samples shall then be packaged separately in air-tight containers.

Source: https://assist.dla.mil -- Downloaded: 202640-22T21:04Z
Check the source to verify that this is the currentversion before use.

(e) Unit pack container leakage test (SPI P5-19-6505). Each filter packaged in the required barrier bag shall be tested for container leakage in accordance with 4.4.4.7.

4.3.2.3 For destructive tests.

(a) Airflow resistance and DMMP gas life after rough handling. Four filters shall be tested for airflow resistance and DMMP gas life after rough handling.

(b) Heat seal seam separation test. The empty unit pack container bag from the preproduction lot shall have four representative heat seal seam specimens randomly selected from it for testing in accordance with 4.4.4.8.

4.3.3 Inspection procedure.

4.3.3.1 For examination. Each packaged filter shall be examined for the defects listed in the classification of defects.

4.3.3.2 For nondestructive tests.

(a) Airflow resistance. Airflow resistance testing shall be performed in accordance with 4.4.4.3.

(b) R-12 leakage. R-12 leakage testing shall be performed in accordance with 4.4.4.2.

(c) Moisture content. Determination of moisture content shall be in accordance with 4.4.4.1. This test shall be performed immediately after the unit pack container leakage test has been successfully completed for the filter represented by the sample.

(d) CK gas life of charcoal sorbent. Charcoal samples shall be tested in accordance with 4.4.4.5.

(e) Unit package container leakage test (SPI P5-19-6505). Each filter sealed in the required barrier bag shall be tested in accordance with 4.4.4.7.

4.3.3.3 For destructive tests.

(a) Airflow resistance and DMMP gas life after rough handling. After rough handling in accordance with 4.4.4.6, sample filters shall be tested for airflow resistance and DMMP gas life in accordance with 4.4.4.3 and 4.4.4.4.

(b) Heat seal seam separation test. The four representative heat seal seam specimens shall be tested in accordance with 4.4.4.8.

Source: https://assist.dla.mil -- Downloaded: 2026-10-22T21:04Z
Check the source to verify that this is the current version before use.

4.3.4 Acceptance/rejection criteria. The preproduction lot shall comply with all requirements of this specification when examined and tested in accordance with 4.3.3 to be acceptable. The contractor shall obtain written approval from the contracting officer prior to proceeding with regular production.

4.4 Quality conformance inspection.

4.4.1 Lotting. A lot shall consist of the filters produced by one manufacturer, at one plant, from the same materials, and under essentially the same manufacturing conditions. However, no more than one lot of charcoal sorbent shall be represented in any one lot of finished filters.

4.4.2 Sampling.

4.4.2.1 For examination. Sampling shall be conducted in accordance with MIL-STD-105.

4.4.2.2 For nondestructive tests.

(a) Airflow resistance. Each filter shall be tested for airflow resistance.

(b) R-12 leakage. Each filter shall be tested for R-12 leakage.

(c) Moisture content. A sample of charcoal (25 grams) shall be taken during the filling of each filter. Each filter shall be placed in a bag made from one layer of fines cloth (used in the manufacture of the filter), and shall experience the same conditions that its respective filter experiences until the filter is sealed into the required barrier bag during packaging.

(d) CK gas life of charcoal sorbent. A sample specimen of charcoal sorbent (approximately I pound) shall be taken during the filling of four filters, chosen at random. Each sample specimen shall be placed in a bag made of one layer of fines cloth (used in the manufacture of the filter), and shall accompany its respective filter to the packaging step. The samples shall then be packaged separately in an air-tight container (see 6.7).

(e) Unit pack container leakage test (SPI P5-19-6505). Each filter packaged in the required barrier bag shall be tested for leakage test in accordance with 4.4.4.7.

4.4.2.3 For destructive tests.

(a) Airflow resistance and DMMP gas life after rough handling. Sampling shall be conducted in accordance with MIL-STD-414, level I, AQL 1.0 percent.

(b) Heat seal seam separation test. Four bags shall be randomly selected from each production lot. From each bag four representative heat seal seam specimens shall be randomly selected.

Source: https://assist.dla.mil -- Downloaded: 202610-22T21:04Z
Check the source to verify that this is the current version before use.

4.4.3 Inspection procedure.

4.4.3.1 For examination. Sample filters selected in accordance with 4.4.2.1 shall be examined and the lot(s) accepted or rejected in accordance with the classification of defects and MIL-STD-105.

4.4.3.2 For nondestructive tests.

(a) Airflow resistance. Each filter shall be tested for airflow resistance in accordance with 4.4.4.3. Any filter failing to meet the requirement shall be rejected.

(b) R-12 leakage. Each filter shall be tested for R-12 leakage in accordance with 4.4.4.2. Any filter failing to meet the requirement shall be rejected.

(c) Moisture content. The moisture content of the charcoal sample associated with each filter shall be determined as specified in 4.4.4.1 immediately after the filter has been sealed into the required barrier bag, and the unit pack container leakage test has been passed. Any filter for which the sample fails to meet the requirement of 3.3 shall be rejected.

(d) CK gas life of charcoal sorbent. The CK gas life of the charcoal samples shall be determined in accordance with 4.4.4.5. Any sample failing to meet the requirement shall cause the lot of filters to be rejected.

(e) Unit pack container leakage test (SPI P5-19-6505). Each filter sealed in the required barrier bag shall be subjected to the unit pack container leakage test in accordance with 4.4.4.7. Any packaged filter failing to meet the requirement shall be rejected.

4.4.3.3 For destructive tests.

(a) Airflow resistance and DMMP gas life after rough handling. Sample filters shall be tested for airflow resistance and DMMP gas life in accordance with 4.4.4.3 and 4.4.4.4. The production lot of filters shall be rejected if any filter fails to meet the requirement of 3.6.

(b) Heat seal seam separation test. The representative heat seal seam specimens shall be tested in accordance with 4.4.4.8. The lot shall be rejected if any specimen fails to meet the requirement.

4.4.3.4 For critical defects. Each filter in the lot shall be tested for the critical characteristics listed in the classification of defects. Any filter failing to meet the requirements of 3.4 and 3.5 shall be rejected. Each packaged filter in the lot shall be tested for critical characteristics listed in the classification of defects (4.4.3.5(f)) and only the packaged filter failing to meet the specified test requirement shall be rejected.

Source: https://assist.dla.mil -- Downloaded: 202640-22T21:04Z
Check the source to verify that this is the current version before use.

4.4.3.5 Classification of defects.

(a) Filter, gas, FFU-17/E (Drawing 5-19-6505).

Categories	Defects	Acceptance standards
Critical:		
1	Leakage	4.4.4.2
2	Airflow resistance	4.4.4.3
Major: AQL 1.0 percent defective		
101	Gasket incorrectly assembled	
102	Marking missing or incorrect	
103	Assembly incorrect	
104	Terne coating missing on raw edges of perforated components	
105	Workmanship (3.9)	

(b) Cover assembly (Drawing 5-19-6512).

Categories	Defects
Critical:	None defined
Major: AQL 1.0 percent defective	
101	Hole diameters and locations incorrect
102	Baffle strip incorrectly formed or located
103	Dimensions incorrect
104	Inner plate overall dimensions incorrect
105	Outer plate overall dimensions incorrect
106	Soldering incorrect

(c) Casing (Drawing 5-19-6518).

Categories	Defects
Critical:	None defined
Major: AQL 1.0 percent defective	
101	Hole diameters and location incorrect
102	Dimensions incorrect

Source: https://assist.dla.mil -- Downloaded: 2026-10-22T21:04Z
Check the source to verify that this is the current version before use.

(d) Finger plate assembly 6 points (Drawing 5-19-6516).

Categories		Defects
Critical:		None defined
Major:	AQL 1.0 percent defective	
	101	Dimensions incorrect
	102	Cementing application incorrect

(e) Finger plate assembly 7 points (Drawing 5-19-6517).

Categories		Defects
Critical:		None defined
Major:	AQL 1.0 percent defective	
	101	Dimensions incorrect
	102	Cementing application incorrect

(f) Packaging inspection (SPI P5-19-6505).

Categories		Defects	Inspection method
Critical:			
	1	Unit pack container leakage	4.4.4.7
Major:	AQL 2.5 percent defective		
	101	Item not completely cleaned and dried	
	102	Packaging materials/assemblies incorrect or missing	
	103	Barrier bag and closure missing or not as specified	
	104	Strapping incorrect, loose or missing	
	105	Marking incorrect or illegible	
	106	Exterior container not as specified or missing	

4.4.4 Tests. Tests shall be conducted as follows:

4.4.4.1 Moisture content of charcoal sorbent. The moisture content of the charcoal samples shall be determined according to ASTM D 2867.

4.4.4.2 Leakage. The filter shall meet the R-12 leakage requirement when tested as follows:

Source: https://assist.dla.mil -- Downloaded: 202610-22T21:04Z
Check the source to verify that this is the currentversion before use.

(a) Connect the filter to a source of forced air.

(b) Regulate the airflow through the filter to the specified flow.

(c) Introduce R-12 into the intake of the blower. Monitor and maintain the specified concentration of R-12 in air on the influent side of the filter for the specified time.

(d) Determine the leakage using a suitable leak detector (see 6.4) for sampling and detecting R-12 in the effluent side of the filter.

(e) Purge the filter by passing fresh air in the reverse direction through the filter at its rated flow for 1 minute.

4.4.4.3 Airflow resistance. The filter shall meet the airflow resistance requirement when tested as follows:

(a) Connect the filter to a source of forced air.

(b) Regulate the airflow through the filter to the specified flow.

(c) Determine the difference in static pressure head upstream of the filter to that downstream of the filter.

4.4.4.4 Dimethylmethylphosphonate (DMMP) value after rough handling. After the filter has been rough handled for 15 minutes as specified in 4.4.4.6, the filter shall be tested for DMMP value in an apparatus that is capable of establishing and maintaining the test conditions identified in 3.6 as follows:

(a) Preheat sample filter to 120 $\pm$ 10°F for a minimum of 30 minutes.

(b) While in the bypass mode adjust the controls until rated airflow is reached and the temperature is 110 $\pm$ 5°F. Generate DMMP vapor until the influent concentration detector (see 6.5) indicates 5.00 $\pm$ .01 micrograms of DMMP per liter of air.

(c) Insert preheated filter into the test apparatus using an appropriate test fixture if necessary.

(d) Switch to test mode and start timer. Make final adjustments to airflow, temperature, and DMMP concentration.

(e) Stop the test and record when the effluent concentration detector (see 6.6) indicated that the break concentration (0.04 mirograms/liter) has been reached.

(f) Start the timer when the influent concentration detector first indicates DMMP in the system (see 6.5).

Source: https://assist.dla.mil -- Downloaded: 2026-10-22T21:04Z
Check the source to verify that this is the current version before use.

(g) Stop the test and record the time when the effluent concentration detector indicates that the break concentration has been reached (see 6.6).

4.4.4.5 CK gas life of charcoal sorbent. The CK gas life shall be determined as follows:

(a) Prepare four M11 canisters in accordance with MIL-C-13724 using the charcoal specimens. Care shall be taken not to mix the specimens from different filters.

(b) Test the four M11 canisters for CK gas life in accordance with MIL-C-13724.

4.4.4.6 Rough handling. Place the filter in the vibrating machine in an upright position as determined by markings on the filter. Rough handle the filter in accordance with test method T105.10 of MIL-STD-282.

4.4.4.7 Unit pack container leakage test (SPI P5-19-6505). The leakage of the unit pack container containing the item shall be determined by subjecting the sample to the vacuum retention technique of method 5009.2 of FED. TEST METHOD STD. NO. 101.

4.4.4.8 Heat seal seam separation test (SPI P5-19-6505). The heat seal seams of the unit pack container shall be tested in accordance with method 2024 of FED. TEST METHOD STD. NO. 101, except that the static load shall be 45 to 50 ounces, and 5 percent reduction in this static load shall be permitted where room temperature in the test area exceeds 90°F.

5. PACKAGING

5.1 Packaging. Packaging shall be as specified in SPI P5-19-6505.

6. NOTES

6.1 Intended use. The gas filter is intended to be used in ventilating systems to protect personnel against toxic gases. It is to be used in conjunction with the M20 particulate filter (MIL-F-51068).

6.2 Ordering data. Acquisition documents should specify the following:

(a) Title, number, and date of this specification.
(b) Laboratory to which samples are to be sent for Government testing.
(c) Preproduction:

(1) Time allowed for contractor submission of samples for Government test and evaluation after award of contract.
(2) Name and address of the test facility and shipping instructions when testing is performed by the Government.

Source: https://assist.dla.mil -- Downloaded: 2026-10-22T21:04Z
Check the source to verify that this is the current version before use.

(3) Time required for the Government to notify the contractor whether to proceed with production.

(d) Production:

(1) Name and address of the test facility and shipping instructions when testing is performed by the Government.
(2) Time required for the Government to notify the contractor whether a lot has been accepted.

(e) The level(s) of packaging and packing that are required.

6.3 Manufacture. The method of manufacture described in 6.3.1 has been found to produce a satisfactory gas filter. This procedure is furnished with the distinct understanding:

(a) That the contractor is not required to follow the method.
(b) That the provisions of the specification must be met regardless of the method of manufacture.
(c) That the Government makes no warranty that material made in accordance with this method will pass the specification requirements.

6.3.1 Charcoal sorbent filling and packing procedure.

(a) Vibrating filling. Add charcoal to the filter container while the container and filling attachments bounce freely on the Q110 Vibrating Machine (Drawing 26-18-69) (on steel table at 0.5 amplitude without holding bars). Charcoal flow rate is regulated by a 1/4 inch plywood orifice plate in the charcoal hopper (35 half-inch diameter orifices, placed 3-1/4 inch apart in a square array).

The filter and attachments are held together by baling straps and kept from creeping off the table by a wooden retaining frame. (Holding bars specified for the Rough-Handling Test to prevent bouncing are not used in this procedure.) Screw holes in the top finger plates are plugged with screws or masking tape to prevent charcoal leakage. Overfill slightly (an inch or more above finger plates) and remove hopper and orifice plate.

(b) Vibratory compaction without pressure. Bounce the filter and filling extension on the Q110 Vibrating Machine for 20 minutes (at 0.5 inch amplitude on steel table without holding bars). Maintain overfill at about 1 inch. Remove filling extension.

(c) Final compaction and installation of cover. Scrape excess charcoal down to level of cover flange with a straight-edge. Place a sheet of 1/4 inch closed-cell Neoprene foam rubber on top of the filter and position cover with four corner screws. Press cover down by applying a 200 pound load. Remove rubber sheet. Brush charcoal from cover flange and finger plates carefully into charcoal beds. Screw on cover securely.

Source: https://assist.dla.mil -- Downloaded: 2026-10-22T21:04Z
Check the source to verify that this is the current version before use.

NOTE: This filling is to be accomplished with every precaution to eliminate charcoal dust from contaminating the surrounding areas by covering the filter with plastic when vibrating on the rough handling methods.

6.4 Leak detector. The General Electric Company Type H-2 Halogen Leak Detector as modified for use with the Q143 DOP and Freon Leakage Tester is suitable for use as a leakage indicator.

6.5 DMMP influent concentration detectors. The Beckman L/B Infrared Analyzer, model no. 15a, has been found to be a suitable detector for DMMP influent concentrations.

6.6 DMMP effluent concentration detector. The Melloy Laboratories Sulfur, Phosphorous, and Hydrocarbon Analyzer, model no. SH 202, with phosphorous filter has been found to be suitable DMMP effluent concentration detector.

6.7 Packaging of charcoal sorbent. Suggested packaging of charcoal sorbent for CK analysis is:

(a) Hermetically sealed can.

(b) Screw top jar or can.

(c) Double-barrier bag in accordance with MIL-B-117, type I, class E, made from material in accordance with MIL-B-131, class 1.

6.8 Subject term (key word) listing.

Filter, gas

6.9 Supersession data. This specification supersedes Chemical Research and Development Center Purchase Description EA-F-1080A, dated 29 January 1975.

Custodian:

Army - EA

Preparing activity:

Army - EA

Project No. 4240-A956

Source: https://assist.dla.mil -- Downloaded: 202610-22T21:04Z
Check the source to verify that this is the current version before use.

STANDARDIZATION DOCUMENT IMPROVEMENT PROPOSAL

(See Instructions – Reverse Side)

1. DOCUMENT NUMBER	2. DOCUMENT TITLE
MIL-F-51541(EA)	FILTER, GAS, FFU-17/E, 600 CFM

3a. NAME OF SUBMITTING ORGANIZATION	4. TYPE OF ORGANIZATION *(Mark one)*
	☐ VENDOR
	☐ USER
b. ADDRESS *(Street, City, State, ZIP Code)*	☐ MANUFACTURER
	☐ OTHER *(Specify)*:

5. PROBLEM AREAS

a. Paragraph Number and Wording:

b. Recommended Wording:

c. Reason/Rationale for Recommendation:

6. REMARKS

7a. NAME OF SUBMITTER *(Last, First, MI)* – Optional	b. WORK TELEPHONE NUMBER *(Include Area Code)* – Optional
c. MAILING ADDRESS *(Street, City, State, ZIP Code)* – Optional	8. DATE OF SUBMISSION *(YYMMDD)*

Source: https://assist.dla.mil -- Downloaded: 2026/10-22T21:04Z
Check the source to verify that this is the current version before use.