MILITARY SPECIFICATION

WATER SUPPLY KIT, PUMP-FILTER, TYPE FM-176A

This specification is mandatory for use by all Departments and Agencies of the Department of Defense.

1. SCOPE

1.1 This specification covers one type of Water Supply Kit.

1.1.1 A product issue number will be placed following the suffix letter in the typed designation. This production issue number will be established in accordance with provisions of MIL-STD-155 and will be furnished when required upon application by the contractor to the procuring activity after the award of each contract. This complete type designation will then be used on name-plates, shipping records, in instruction books and whenever reference is made to the specific equipment defined by the complete designation.

2. APPLICABLE DOCUMENTS

2.1 The following documents of the issue in effect on date of invitation for bids or request for proposal, form a part of this specification to the extent specified herein.

SPECIFICATION

Federal

| | |
|---|---|
| NN-P-530 | Plywood, Flat Panel |
| QQ-A-250/5 | Aluminum Alloy Alclad 2024, Plate and Sheet |
| QQ-A-601 | Aluminum Alloy Sand Castings |
| TT-V-109 | Varnish, Spar, Alkyd-Resin |
| TT-P-636 | Primer Coating, Alkyd, Wood and Ferrous Metal |
| PPP-B-576 | Boxes, Wood, Cleated, Veneer, Paper Overlaid |
| PPP-B-585 | Boxes, Wood, Wirebound |
| PPP-B-591 | Boxes, Fiberboard, Wood-Cleated |
| PPP-B-601 | Boxes, Wood, Cleated-Plywood |
| PPP-B-621 | Boxes, Wood, Nailed and Lock-Corner |

Military

| | |
|---|---|
| MIL-P-116 | Preservation, Methods of |
| MIL-V-173 | Varnish, Moisture-and-Fungus-Resistant (For the Treatment of Communications, Electronic, and Associated Electrical Equipment) |



Source: https://assist.dla.mil -- Downloaded: 2026-10-23T09:52Z
Check the source to verify that this is the current version before use.

| | |
|---|---|
| MIL-D-1000 | Drawings, Engineering and Associated Lists |
| MIL-C-3767 | Connectors, Plug and Receptacle, Electrical, (Power, Bladed Type), General Specification for |
| MIL-S-5002 | Surface Treatments and Metallic Coatings for Metal Surfaces of Weapons Systems |
| MIL-C-5756 | Cable and Wire, Power, Electric Portable |
| MIL-E-7729 | Enamel, Gloss |
| MIL-A-8625 | Anodic Coatings, for Aluminum and Aluminum Alloys |

STANDARDS

Federal

| | |
|---|---|
| FED-STD-595 | Colors |

Military

| | |
|---|---|
| MIL-STD-105 | Sampling Procedures and Tables for Inspection by Attributes |
| MIL-STD-129 | Marking for Shipment and Storage |
| MIL-STD-130 | Identification Marking of U.S. Military Property |
| MIL-STD-143 | Specifications and Standards Order of Precedence for the Selection of |
| MIL-STD-155 | Joint Photographic Type Designation System |
| MIL-STD-205 | Frequencies for Electric Power |
| MIL-STD-681 | Identification Coding and Application of Hook Up and Lead Wire |
| MIL-STD-826 | Electromagnetic Interference Test Requirements and Test Methods |
| MIL-STD-831 | Test Reports, Preparation of |
| MS33586 | Metals, Definition of Dissimilar |

PUBLICATIONS

Air Force - Navy Aeronautical Bulletin

| | |
|---|---|
| 275 | Guide for Selection of Lubricants, Fluids, and Compounds for use in Flight Vehicles and Components |
| 400 | Electronic Equipment, Aircraft and Guided Missiles, Applicable Documents |

(Copies of documents required by the contractor in connection with specific procurement functions should be obtained from the procuring activity or as directed by the contracting officer.)

2.2 Other publications. The following documents form a part of this specification to the extent specified herein. Unless otherwise indicated, the issue in effect on date of invitation for bids or request for proposal shall apply.



Source: https://assist.dla.mil -- Downloaded: 202610-23T09:52Z
Check the source to verify that this is the currentversion before use.

National Fire Protection Association

NFPA 70 (1965) National Electrical Code

(Copies of NFPA 70 (1965) may be obtained from the National Fire Protection Association, 60 Batterymarch Street, Boston, Mass. 02110).

3. REQUIREMENTS

3.1 Preproduction. This specification makes provisions for preproduction testing (see 4.3).

3.2 Materials

3.2.1 Fungus-proof materials. Where non-fungus-proof materials are used, such susceptible parts and materials shall be impregnated with fungistatic coating material of Type I varnished in accordance with MIL-V-173.

3.2.1.1 Metals. Metals used in the construction of the water supply kit shall be of the corrosion-resistant type, or suitably protected to prevent corrosion during storage and normal service life. When metals not specifically designated are used, they shall be entirely suitable for the purpose. Metals used in construction of the kit shall be as lightweight as possible, consistent with providing maximum strength and rigidness.

3.2.1.2 Dissimilar metals. Dissimilar metals shall not be used in intimate contact unless suitably protected against electrolytic corrosion. When it is necessary that any combination of such dissimilar metals be assembled, an interposed material compatible to each shall be used. Dissimilar metals are defined in MS33586.

3.2.1.3 Aluminum-alloy plate. Parts fabricated of aluminum shall have their composition in accordance with QQ-A-250/5.

3.2.1.4 Aluminum-alloy castings. When used, castings shall be made of aluminum alloy conforming to QQ-A-601.

3.2.2 Plywood. Plywood shall be in accordance with NN-P-530, Hardwood Type I.

3.2.3 Protective treatment. When materials are used in the construction of the kit that are subject to deterioration when exposed to climatic and environmental conditions likely to occur during service usage, they shall be protected against such deterioration in a manner that will in no way prevent compliance with the performance and requirements of this specification. The use of any protective coating that will crack, chip, or scale with age, extremes of climatic and environmental conditions, shall be avoided.



Source: https://assist.dla.mil -- Downloaded: 2026-10-23T09:52Z
Check the source to verify that this is the current version before use.

3.3 Selection of specifications and standards. Specifications and standards for necessary commodities and services not specified herein shall be selected in accordance with MIL-STD-143. Nonstandard electrical and electronic parts, and materials shall be defined as those items not covered by a specification in ANA Bulletin 400.

3.4 Design and construction. The water supply kit shall be designed to filter dirt and clay particles of 25 microns and larger from water. The filters on the water supply kit shall be cleanable metal or throw away cartridge type filters.

3.4.1 The detailed mechanical and electrical design of the water supply kit shall be accomplished by the manufacturer subject to the requirements of this specification. These requirements are detailed only to the extent deemed necessary to insure the performance and permanence of the desired mechanical and electrical characteristics. The design, layout, and assembly of the water supply kit shall be such as to facilitate quantity and quality production.

3.5 Components. The water supply kit shall consist of the following components:

| ITEM NO | DESCRIPTION | QUANTITY |
|---|---|---|
| 1 | Motor | 1 ea |
| 2 | Pump | 1 ea |
| 3 | Filter Assembly | 1 ea |
| 4 | Suction Hose | 1 ea (25 Ft) |
| 5 | Supply Hoses | 3 ea (25 Ft) |
| 6 | Shut Off Valve | 2 ea |

3.5.1 Safety design. Safe design shall include the preventation of reversed assembly or installation of connectors, fasteners, parts and units where possible malfunction and personnel hazard might occur. The water supply kit shall function in such a manner so that during normal operation there is no possibility the operator will suffer injury.

3.5.2 Maintenance. The design shall utilize readily removable and replaceable units to facilitate easy assembly, disassembly, location of trouble sources, and repair of the water supply kit. The design shall be such that adjustment, minor repairs, and replacement of parts may be made by service personnel with a minimum of training, using commercial tools and instructional guides.

3.6 Construction. All parts and components of the equipment shall be constructed to withstand strains, jars, vibrations, and other conditions incident to shipping, storage, and operation, without deterioration, distortion, misalignment, malfunction, damage, etc. The structure shall be such as to give the least overall weight consistent with required strength and stability to maintain proper alignment of all parts during the life of the unit.



Source: https://assist.dla.mil -- Downloaded: 2026-10-23T09:52Z
Check the source to verify that this is the current version before use.

3.6.1 Lubrication. The water supply kit shall be lubricated prior to testing and shipment. Lubricants shall be selected from those listed in ANA Bulletin 275. Where it is necessary to use lubricants not listed in ANA Bulletin 275 such as silicone greases, molybdenum disulfide, or colloidal suspensions of graphite, approval shall be obtained from the procuring activity.

3.7 Performance.

3.7.1 Environmental conditions. There shall be no failure or impairment of function when the water supply kit is operated under the following conditions:

Ambient temperature and humidity:

(a) Ambient temperatures from +40° to +120° Fahrenheit (F).
(b) Subsequent to prolonged storage at any or all temperatures within the range from - 20°F to 160°F.
(c) Relative humidities of 95 ± 5 percent, in combination with temperatures over a range of +65° to 122°F.

3.7.2 Interference. Interference control requirements shall conform to MIL-STD-826.

3.7.3 Dielectric. All circuits of the water supply kit shall be capable of withstanding the conditions specified herein. There shall be no flashover or breakdown when the rated test voltage specified herein is applied between any electrical circuit and ground. All adjacent metal parts not in the circuit under test, shall be considered as ground.

3.7.4 Leakage current. Following exposure to the humidity and temperature conditions specified herein, the leakage current between all electrical circuits and ground shall not exceed a total of 2 milliamperes. All adjacent metal parts not in the circuit under test shall be considered as ground.

3.8 Detail of components.

3.8.1 Base. The base shall be constructed of metal adequate to support the weight of the filters, pump, motor, and valves under all conditions of use.

3.8.1.1 Base dimensions. The base shall be approximately 20 inches by 30 inches, and shall serve as the bottom of the shipping crate.

3.8.2 Pump motor. The pump motor shall operate from 50/60 cycle, 115 ± 10 Volts alternating current (A.C.). Maximum load shall not exceed 1,000 watts.

3.8.3 Pump. The pump shall be capable of providing filtered water at 10 gallons per minute (gpm) and 45 pounds per square inch (psi) pressure at the end of 3 sections of discharge hose (75 feet).



Source: https://assist.dla.mil -- Downloaded: 2026-10-23T09:52Z
Check the source to verify that this is the current version before use.

3.8.4 Filter(s). The filter(s) shall be metallic, cleanable or disposable cartridge type, capable of filtering 1,500 gallons of contaminated water without cleaning or replacing the filter cartridge.

3.9 Interchangeability. All parts having the same manufacturer's part number shall be functionally and dimensionally interchangeable. The drawing number requirements of MIL-D-1000 shall govern changes in the manufacturer's part numbers.

3.10 Electrical characteristics.

3.10.1 The water supply kit shall be designed for operation on 115 $\pm$ 10 Volts, 50 or 60 cycle, single phase, alternating current.

3.10.2 Wiring. The arrangement of the electrical wiring shall be in accordance with MIL-STD-681. The size of wire, insulation, switch mounting, and all other electrical items and connections shall be adequate to meet the requirements specified herein. All wiring shall conform to NFPA 70.

3.10.2.1 Radio interference. Interference limits shall be in accordance with the requirements of MIL-STD-826.

3.10.3 Insulation. All electrical wiring shall be suitably insulated or shall be enclosed in a conduit of material resistant to any photographic chemical solutions with which it may come in contact during normal operation.

3.10.4 Connector and power cord. A 3-conductor, flexible, waterproof cord, 10 feet long, conforming to MIL-C-5756, shall be provided with each water supply kit. One end shall be permanently attached to the water supply kit, and the other end of the cord shall be equipped with a MIL-C-3767 plug. The connectors shall be attached in such a manner that tension on the cord shall not be transmitted directly to the terminals. The third wire shall be internally connected so as to serve as an equipment ground.

3.11 Dimensions. The water supply kit shall not exceed the following dimensions: Length: 30 inches; Width: 20 inches; Height: 22 inches.

3.11.1 Dimensions and tolerances. Dimensions and tolerances not specified shall be as close as is consistent with the best shop practices. Where dimensions and tolerances may affect the interchangeability, operation, or performance of the kit, they shall be held or limited accordingly.

3.12 Weight. The maximum weight of the water supply kit, including hoses, valves, and tools, shall not exceed 250 pounds.

3.13 Color. The color of the exterior finish of the water supply kit shall be light gray hammertone, color 16376 in accordance with FED-STD-595, except as otherwise specified.



Source: https://assist.dla.mil -- Downloaded: 2026-10-23T09:52Z
Check the source to verify that this is the current version before use.

3.14 Contaminated water. Contamination of water shall be equal to two pounds of dry clay dissolved in 100 to 300 gallons of water.

3.15 Screw assemblies. Assembly screws, bolts, and nuts shall be tightened sufficiently and secured in such a manner that they will not become loose due to vibration incident to the environment in which the equipment is operated. The manner in which they are secured shall not prevent removal for maintenance or repair.

3.15.1 Riveting. Riveting operation shall be carefully performed to insure that the rivets are tight and satisfactorily headed. Heads of driven rivets shall be uniform in shape and concentric with rivet shank axis and shall have full bearing on the surfaces of the joined members. Rivet tension shall not be created by driving in incorrectly fitted members. A rivet with a head deficient in size, not uniform in shape, off center, loose, burred, or deformed in any way, shall be considered defective.

3.15.2 Cleaning. The water supply kit shall be thoroughly cleaned of loose spattered or excess solder, metal chips and other foreign material, after final assembly. Burrs and sharp edges, as well as resin flash that may crumble, shall be removed.

3.16 Data. No data is required by this specification, or by applicable documents referenced in section 2, unless specified in the contract or order (see 6.3).

3.17 Finishes.

3.17.1 Exterior. All exterior metal parts of the water supply kit shall be finished with either a baked synthetic enamel, or plating except as follows.

3.17.1.1 All corrosion-resistant steel parts shall be buffed to a smooth finish.

3.17.1.2 All ferrous metal parts not of corrosion-resistant alloys, shall be cleaned in accordance with MIL-S-5002 and shall receive two coats of primer in accordance with TT-P-636 applied to all surfaces before assembly followed by one or two coats of enamel conforming to MIL-E-7729.

3.17.1.3 All aluminum sheet metal parts or castings, shall be anodized in accordance with MIL-A-8625, Type I.

3.17.1.4 All wood parts shall be given two coats of sealer conforming to TT-V-109 diluted to 30 percent with organic solvents and one or more coats of enamel conforming to MIL-E-7729 before assembly.



Source: https://assist.dla.mil -- Downloaded: 202640-23T09:52Z
Check the source to verify that this is the currentversion before use.

3.18 Operation markings. Condensed operating instructions, with illustrations and diagrams, if necessary, shall be permanently attached to the water supply kit. All warnings shall be placed on the equipment close to the part concerned in a permanent manner with paint, decalcomania or metal plates of such sizes and colors that will be readily visible.

3.18.1 Check list. A permanent and legible check list shall be fastened to the water supply kit listing all unattached parts and accessories.

3.19 Identification of product. The kit, parts, and assemblies shall be marked for identification in accordance with MIL-STD-130.

3.20 Accessories. Unless otherwise specified, the following spare parts shall be provided with each water supply kit. Provisions shall be made for storage of spares in the case.

a. Extra Hose Washers
b. Tool Kit
c. Valve Washers

3.21 Workmanship. The water supply kit, including all parts and accessories shall be constructed and finished in a thoroughly workmanlike manner. Particular attention shall be given to neatness and thoroughness of soldering, wiring, marking of parts and assemblies, welding and brazing, painting, riveting, machine screw assemblies, freedom of parts from burrs and sharp edges.

## 4. QUALITY ASSURANCE PROVISIONS

4.1 Responsibility for inspection. Unless otherwise specified in the contract or purchase order, the supplier is responsible for the performance of all inspection requirements as specified herein. Except as otherwise specified in the contract or order, the supplier may use his own or any other facilities suitable for the performance of the inspection requirements specified herein, unless disapproved by the Government. The Government reserves the right to perform any of the inspections set forth in the specification where such inspections are deemed necessary to assure supplies and services conform to prescribed requirements.

4.2 Classification of tests. The inspection and testing of the water supply kit shall be classified as follows:

a. Preproduction tests . . . . . See 4.3
b. Acceptance tests . . . . . See 4.5

4.3 Preproduction tests

4.3.1 Preproduction samples. When specified (see 6.3), before production is commenced, a sample of the item covered by this specification shall be submitted or made available to the contracting officer or his authorized representative for approval. The approval of the preproduction sample authorizes the commencement of production, but does not relieve the contractor of responsibility for compliance with all applicable provisions of this specification.



Source: https://assist.dla.mil -- Downloaded: 2026-10-23T09:52Z
Check the source to verify that this is the current version before use.

4.3.2 Preproduction test report. When preproduction test reports conforming to MIL-STD-831 are required by the contract, the contractor shall furnish a reproducible and three copies of the report to the procuring activity (see 6.3).

4.4 Test conditions

4.4.1 Temperature and humidity. Unless otherwise specified, the tests shall be conducted under prevailing room ambient temperature, barometric pressure and relative humidity.

4.4.2 Line voltage. Unless otherwise specified, the line voltage during the test shall be 115 ± 10 volts, 60 cycle, single-phase alternating current.

4.4.3 Test set up and procedures

4.4.3.1 The water supply kit shall be set up with the suction hose intake 5 feet below the pump inlet. The discharge outlet shall be 5 feet above the level of the filter outlet.

4.4.3.2 Filter test. The contaminated water as prepared in 3.14 shall be filtered through the water supply kit. The filtered water shall appear clear and free from clay stains.

4.4.3.3 Pressure test. The pressure shall be monitored and shall not fall below 45 psi at any time during testing.

4.4.3.4 Flow test. The output flow of the water supply kit shall be monitored and shall not fall below 10 gpm at any time during the testing of the kit.

4.4.3.5 High temperature. The water supply kit shall be subjected to ambient temperature of +120°F and water temperature of +85°F. The output pressure and the flow rate (GPM) shall not decrease more than 10%.

4.4.3.6 Humidity and rainfall. The water supply kit shall be capable of continuous operation in 100% humidity and rainfall to two inches per hour.

4.4.3.7 Leakage current. Following exposure to the temperature test and humidity test the leakage current shall be determined with the pump motor connected to an alternating current power source having a potential of 115 ± 10 volts. This test shall be between the power terminal and the ground. The leakage current between any electrical circuit and between any electrical circuit and ground shall not exceed 2 milliamperes.

4.4.3.8 Dielectric. The insulation strength of all electrical circuits shall be tested to withstand twice rated voltage + 1000 volts. The test potential may be direct current or peak alternating current of the same value and shall be applied for one minute between all wiring and adjacent conductors not in the circuit and between all wiring and ground. This test shall be conducted prior to the installation of, or with the radio noise filter disconnected.



Source: https://assist.dla.mil -- Downloaded: 2026-10-23T09:52Z
Check the source to verify that this is the current version before use.

4.4.3.9 Radio noise. The water supply kit shall meet the interference limits of MIL-STD-826 when tested as specified, but with the following variations of the test procedure.

a. Radiation interference measurements shall be free from 0.15 to 400 megacycles.
b. The rod, dipole or whip antenna shall be located and oriented for maximum indication at a distance of 5 feet from the radiating source of the equipment and connecting assemblies.

4.5 Acceptance tests. The acceptance tests shall consist of the following:

a. Examination of product
b. Sampling tests

4.5.1 Examination of product. Examination of the water supply kit shall be in accordance with the classification of defects specified in paragraph 4.5.1.1. Sampling shall be performed in accordance with provisions set forth in MIL-STD-105, except where otherwise indicated herein. The Acceptance Quality Level (AQL) shall be 4.0 percent defective for major defects and 10.0 percent defective for minor defects. The Inspection Level shall be II.

4.5.1.1 Classification of defects. The water supply kit shall be inspected for the following defects:

| EXAMINE | DEFECT | CLASSIFICATION MAJOR | MINOR |
|---|---|---|---|
| Finish | Components and parts not finished, treated or painted as specified | x | |
| | Treatment or Painting scratched, chipped, stained or discolored | | x |
| Construction & Workmanship | Any part or component not as specified, damaged or missing | x | |
| | Material not as specified | x | |
| | Assembly incomplete or incorrect | x | |
| | Dimensions not as specified | x | |
| | Parts not free from scale, rust, grease or foreign matter | | x |
| | Cracks or imperfections in welds not affecting operation | | x |



Source: https://assist.dla.mil -- Downloaded: 2026-10-23T09:52Z
Check the source to verify that this is the current version before use.

| EXAMINE | DEFECT | CLASSIFICATION MAJOR | MINOR |
|---|---|---|---|
| Identification Marking | Missing; incomplete; incorrect illegible; wrong location; or wrong size letters | | x |
| Construction & Workmanship | Screwed and riveted assemblies not right | | x |

4.6 Inspection of preservation. Inspection of the preservation, packaging, packing and marking for shipment and storage. Sample item or packs and the inspection of the preservation, packaging, packing, and marking for shipment and storage shall be in accordance with the requirements of Section 5, or the documents specified therein.

5. PREPARATION FOR DELIVERY

5.1 Preservation and packaging. Preservation and packaging shall be Level A or C as specified (see 6.3).

5.1.1 Level A. Each water supply kit shall be preserved in accordance with MIL-P-116, Method II. Unit quantities shall be one each.

5.1.2 Level C. Each water supply kit shall be packaged to afford adequate protection against deterioration and physical damage during shipment from supply source to the first receiving activity for immediate use.

5.2 Packing. Packing shall be Level A, B, or C as specified (see 6.3).

5.2.1 Level A. Water supply kit preserved and packaged to meet paragraph 5.1.1 shall be packed in exterior type shipping containers in accordance with PPP-B-576, PPP-B-585, PPP-B-601, or PPP-B-621. As far as practical, exterior containers shall be of uniform shape and size, be of minimum cube and tare consistent with the protection required. As far as practical, exterior containers shall be of uniform shape and size and contain identical quantities. The gross weight of each pack shall be limited to approximately 500 pounds. Containers shall be closed and strapped in accordance with applicable container specification or appendix thereto.

5.2.2 Level B. Water supply kit preserved and packaged to meet paragraph 5.1.1 shall be packed in domestic type exterior containers in accordance with PPP-B-576, PPP-B-585, PPP-B-591, PPP-B-601, or PPP-B-621. Exterior containers shall be of minimum cube and tare consistent with the protection required. As far as practical, exterior containers shall be of uniform shape and size and contain identical quantities. The gross weight of each pack shall be limited to approximately 500 pounds. Containers shall be closed and strapped in accordance with applicable container specification or appendix thereto.



Source: https://assist.dla.mil -- Downloaded: 2026-10-23T09:52Z
Check the source to verify that this is the current version before use.

5.2.3 Level C. Packages which require overpacking for acceptance by the carrier shall be packed in exterior type shipping containers in a manner that will insure safe transportation at the lowest rate to the point of delivery. Containers shall meet Consolidated Freight Classification rules or regulations of other common carriers as applicable to the mode of transportation.

5.3 Marking. Interior and exterior containers shall be marked in accordance with MIL-STD-129. The nomenclature shall be as follows:

WATER SUPPLY KIT, TYPE FM-176A

6. NOTES

6.1 Intended use. The water supply kit is intended for use in areas where no water source other than streams or ponds is available to provide filtered water for photographic chemicals.

6.2 A frequency of 60 + 5 or - 10 cycles is specified to insure that equipment procured under this specification will operate from 50 to 60 cycle power sources and also from sources which conform to MIL-STD-205, which specifies 60 cycles ± 5%.

6.3 Ordering data. Procurement documents should specify the following:

a. Title, number, and date of this specification.
b. Stock number.
c. Selection of applicable levels of preservation and packaging and packing (see 5.1 and 5.2).
d. Number of preproduction samples, point of inspection, and concurrent delivery of each sample (see 4.3.1).
e. Whether test reports or other data are required (see 3.16 and 4.3.2).

Custodian:
Air Force - 70
Navy - AS

Reviewer:
Navy - AS

User:
Navy - MC

Preparing activity:
Air Force - 70

Project No 6780-F017



Source: https://assist.dla.mil -- Downloaded: 202610-23T09:52Z
Check the source to verify that this is the current version before use.

# SPECIFICATION ANALYSIS SHEET

Form Approved
Budget Bureau No. 22-R255

INSTRUCTIONS: This sheet is to be filled out by personnel, either Government or contractor, involved in the use of the specification in procurement of products for ultimate use by the Department of Defense. This sheet is provided for obtaining information on the use of this specification which will insure that suitable products can be procured with a minimum amount of delay and at the least cost. Comments and the return of this form will be appreciated. Fold on lines on reverse side, staple in corner, and send to preparing activity. Comments and suggestions submitted on this form do not constitute or imply authorization to waive any portion of the referenced document(s) or serve to amend contractual requirements.

SPECIFICATION

ORGANIZATION

CITY AND STATE

CONTRACT NUMBER

MATERIAL PROCURED UNDER A

☐ DIRECT GOVERNMENT CONTRACT ☐ SUBCONTRACT

1. HAS ANY PART OF THE SPECIFICATION CREATED PROBLEMS OR REQUIRED INTERPRETATION IN PROCUREMENT USE?

A. GIVE PARAGRAPH NUMBER AND WORDING.

B. RECOMMENDATIONS FOR CORRECTING THE DEFICIENCIES

2. COMMENTS ON ANY SPECIFICATION REQUIREMENT CONSIDERED TOO RIGID

3. IS THE SPECIFICATION RESTRICTIVE?

☐ YES ☐ NO *(If "yes", in what way?)*

4. REMARKS *(Attach any pertinent data which may be of use in improving this specification. If there are additional papers, attach to form and place both in an envelope addressed to preparing activity)*

SUBMITTED BY *(Printed or typed name and activity - Optional)*

DATE

DD FORM 1 JAN 66 1426

Source: https://assist.dla.mil -- Downloaded: 202610-23T09:52Z
Check the source to verify that this is the current version before use.

FOLD

POSTAGE AND FEES PAID

OFFICIAL BUSINESS

Ogden Air Materiel Area
ATTN: OONEO
Hill Air Force Base, Utah 84401

FOLD

Source: https://assist.dla.mil -- Downloaded: 2026-10-23T09:52Z
Check the source to verify that this is the current version before use.