WW-D-001991 (GSA-FSS)
January 27, 1978

INTERIM FEDERAL SPECIFICATION

DRAIN, LAVATORY AND STOPPER, WASTE DRAIN

This Interim Federal Specification was developed by the General Services Administration, Federal Supply Service, Washington, DC 20406, based upon currently available technical information. It is recommended that Federal agencies use it in procurement and forward recommendations for changes to the preparing activity at the address shown above.

1. SCOPE AND CLASSIFICATION

1.1 Scope. This specification covers two items:

(1) A lavatory drain with stopper.
(2) Waste drain stoppers in five sizes.

1.2 Classification.

1.2.1 Types and sizes. Lavatory drains and separate stoppers covered by this specification shall be of the following types and sizes as specified (see 6.2):

Type I - Drain, lavatory.

Type II - Stopper, waste drain.

Size - 1 inch.
Size - 1-1/8 inch.
Size - 1-1/4 inch.
Size - 1-3/8 inch.
Size - 1-1/2 inch.

2. APPLICABLE DOCUMENTS

2.1 The following documents, of the issues in effect on date of invitation for bids or request for proposal, form a part of this specification to the extent specified herein.

Federal Specification:

PPP-B-636 - Boxes, Shipping, Fiberboard.

(Activities outside the Federal Government may obtain copies of Federal Specifications, Standards, and Handbooks as outlined under General Information in the Index of Federal Specifications and Standards and at the prices indicated in the index. The Index, which includes cumulative monthly supplements as issued, is for sale on a subscription basis by the Superintendent of Documents, U.S. Government Printing Office, Washington, DC 20402.

(Single copies of this specification and other Federal Specifications required by activities outside the Federal Government for bidding purposes are available without charge from Business Service Centers at the General Services Administration Regional Offices in Boston, New York, Philadelphia, Washington, DC, Atlanta, Chicago, Kansas City, MO, Fort Worth, Houston, Denver, San Francisco, Los Angeles, and Seattle, WA.

(Federal Government activities may obtain copies of Federal Specifications, Standards, and Handbooks and the Index of Federal Specifications and Standards from established distribution points in their agencies.)

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T12:24Z
Check the source to verify that this is the current version before use.

Military Standard:

MIL-STD-105 - Sampling Procedures and Tables for Inspection by Attributes.

(Copies of Military Specifications and Standards required by contractor in connection with specific procurement functions should be obtained from the procuring activity or as directed by the contracting officer.)

2.2 Other publications. The following documents form a part of this specification to the extent specified herein. Unless a specific issue is identified, the issue in effect on date of invitation for bids or request for proposal shall apply.

National Motor Freight Traffic Association, Inc., Agent:

National Motor Freight Classification.

(Application for copies should be addressed to the American Trucking Associations, Inc., Traffic Department, 1616 P Street, N.W., Washington, DC 20036.)

Uniform Classification Committee, Agent:

Uniform Freight Classification.

(Application for copies should be addressed to the Uniform Classification Committee, Room 1106, 222 South Riverside Plaza, Chicago, IL 60606.)

3. REQUIREMENTS

3.1 Standard product. Items covered by this specification shall, as a minimum, be in accordance with the requirements of this specification and shall be the manufacturer's standard current commercial product.

3.2 Materials. Materials shall conform to the requirements specified hereinafter. Materials not definitely specified shall be of the type and quality recognized by industry for the intended purpose.

3.3 Type I, drain. The drain tube shall be of copper alloy or stainless steel. The drain shall have cross bars, an overflow opening and shall include a 1-1/4 ± 0.005 inch OD tail piece 5 ± 1/16 inch long. The OD of the drain flange shall be 2-1/16 inch ± 1/16 inch. The drain shall include the items in 3.3.1 thru 3.3.4.

3.3.1 Jam nut. The jam nut shall secure the drain in place.

3.3.2 Washer. Washer shall be of a suitable elastomeric material. It shall be of a design to cushion the jam nut and form a water-tight joint between the lavatory and tail piece.

3.3.3 Stopper. The stopper shall be of rubber or other suitable elastomeric material. The stopper shall include a ring with attached chain.

3.3.4 Chain. Chain shall be bead chain of copper alloy or stainless steel. Size of beads shall be 1/8 inch or larger. The chain shall be not less than 10 inches in length and shall be furnished with chain couplings attached to each end. One end shall be coupled to the stopper ring and the free end shall be attached to a suitable ring for attachment to chain stay.

3.4 Type II, stoppers. Stoppers shall be solid rubber or suitable elastomeric material. The stopper shall have a steel or copper alloy post and ring. Size of waste stoppers shall be as specified in 1.2.1. Size of stopper shall apply to the outside diameter at the bottom. Tolerance on diameter shall be ± 1/64 inch.

3.5 Finish.

3.5.1 Drain and stopper chain. Surfaces of the drain, exposed from the top of the bowl after installation, and chain shall be finished as the manufacturer's standard commercial product for stainless steel and a bright chromium or nickel plated finish for other metals.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T12:24Z
Check the source to verify that this is the current version before use.

3.5.2 Stopper post and rings. Stainless steel stopper post and rings shall be finished in accordance with the manufacturer's standard practice. Other metal stopper posts and rings shall be chromium or nickel plated.

3.6 Performance, drain. Drains shall not leak when tested in accordance with 4.4.

3.7 Workmanship. Metal surfaces shall be free of sharp edges, burrs, and dents which may affect serviceability. Color of stoppers shall be uniform. Stoppers will be free of surface defects which impair serviceability.

4. QUALITY ASSURANCE PROVISIONS

4.1 Responsibility for inspection. Unless otherwise specified in the contract or purchase order, the contractor is responsible for the performance of all inspection requirements as specified herein. Except as otherwise specified in the contract or order, the contractor may use his own or any other facilities suitable for the performance of the inspection requirements specified herein, unless disapproved by the Government.

4.2 Sampling for examination and tests. Samples for examination shall be selected in accordance with level S-4 in MIL-STD-105. Samples for tests shall be selected in accordance with 4.3.2.

4.3 Examination and tests.

4.3.1 Examination. Samples selected in accordance with 4.2 shall be examined for the defects listed in table I. The Acceptable Quality Levels (AQL's) shall be 2.5 percent defective for major defects and 6.5 percent defective for total defects.

TABLE I. Classification of defects, end item

Defects	Major	Minor
Material not as specified	X	
Cracks in drain	X	
Finish not as specified		X
Dimensions not as specified	X	
Damage or defects not affecting function or serviceability		X
Damage or defects affecting function or serviceability	X	

4.3.2 Tests. Three drains shall be tested on the initial contract inspection as specified in 4.4, and thereafter upon change of design, material, or location or method of manufacture.

4.4 Test method for drain. Install drain in a lavatory bowl in accordance with the manufacturer's instructions. Place a horizontal mark on the bowl 1/2 to 3/4 inch below the overflow drain. Place stopper in drain and fill bowl to mark. Let stand for 1 hour and observe for conformance to 3.6. Failure to pass this test shall be cause for rejection.

4.5 Examination of preparation for delivery. An examination shall be made to determine compliance with the requirements of section 5. The sample unit shall be one container fully prepared for delivery. Sampling shall be in accordance with MIL-STD-105. The inspection level shall be S-2 with an AQL of 4.0 expressed as percent defective.

TABLE II. Classification of defects

Examine	Defects
Markings	Omitted, incorrect, illegible; improper size, location, sequence or method of application.
Material	Any component missing or damaged.
Workmanship	Inadequate application of components such as incomplete closure of container flaps, loose strapping, inadequate stapling, or distortion of container.
Contents	Quantity per container is more or less than required. Gross weight exceeds requirements of the box specification.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T12:24Z
Check the source to verify that this is the current version before use.

5. PREPARATION FOR DELIVERY

5.1 Packaging. Packaging shall be level A or Commercial, as specified (see 6.2).

5.1.1 Level A.

5.1.1.1 Stoppers. Fifty stoppers shall be packaged in a paperboard or fiberboard box. The box shall be secured to prevent accidental opening.

5.1.1.2 Drains. Each drain shall be packaged in a paperboard or fiberboard box. Ten drains shall be further packaged in a paperboard or fiberboard box. The boxes shall be secured to prevent accidental opening.

5.1.2 Commercial.

5.1.2.1 Stoppers. The stoppers shall be packaged in accordance with normal commercial practice. The complete package shall be designed to protect the stoppers against damage during shipment, handling, and storage.

5.1.2.2 Drains. The drains shall be packaged in accordance with normal commercial practice. The complete package shall be designed to protect the drains against damage during shipment, handling, and storage.

5.2 Packing. Packing shall be level A or Commercial, as specified (see 6.2).

5.2.1 Level A.

5.2.1.1 Stoppers. Twenty packages (1,000 stoppers) packaged as specified in 5.1.1.1 shall be packed in a close fitting box conforming to PPP-B-636, grade V3c, style RSC or FOL. The box shall be closed in accordance with the appendix to the box specification. Alternatively, cleated plywood, wire bound or nailed wood boxes shall acceptable shipping containers when lined with waterproof barrier material. The edges of the barrier material shall be sealed with waterproof tape or adhesive.

5.2.1.2 Drains. Ten packages (100 drains) packaged is specified in 5.1.1.2 shall be packed in a close fitting box conforming to PPP-B-636, grade V3c, style RSC or FOL. The box shall be closed in accordance with the appendix to the box specification. Alternatively, cleated plywood, wire bound or nailed wood boxes shall be acceptable shipping containers when lined with waterproof barrier material. The edges of the barrier material shall be sealed with waterproof tape or adhesive.

5.2.2 Commercial.

5.2.2.1 Stoppers. The packaged stoppers shall be packed in boxes to insure safe delivery at destination, to provide for safe redistribution by the initial receiving activity, and shall be acceptable by common carrier under National Motor Freight Classification or Uniform Freight Classification.

5.2.2.2 Drains. The packaged drains shall be packed in boxes to insure safe delivery at destination, to provide for safe redistribution by the initial receiving activity, and shall be acceptable by common carrier under National Motor Freight Classification or Uniform Freight Classification.

5.3 Unitization. When shipments to Government depots are full car or truckload, the shipping containers shall be unitized to facilitate handlind, in accordance with normal commercial practice. The unitized load shall not exceed 2,500 pounds in weight, 63 inches in height, 56 inches in length, and 45 inches in width.

5.4 Marking. Marking shall be as specified in the contract or order.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T12:24Z
Check the source to verify that this is the current version before use.

6. NOTES

6.1 Intended use.

6.1.1 Drains. Drains covered by this specification are intended for use with domestic type lavatories.

6.1.2 Stoppers. Stoppers covered by this specification are intended for use with sinks, bath, and laundry tubs.

6.2 Ordering data. Purchasers should select the preferred options permitted herein, and include the following information in procurement documents:

(a) Title, number, and date of this specification.
(b) Type and size required (see 1.2.1).
(c) Level of packaging and packing required (see 5.1 and 5.2).

GSA DC 78-3144

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T12:24Z
Check the source to verify that this is the current version before use.