XX-D-385E
October 28, 1982
SUPERSEDING
XX-D-385D
August 25, 1975

FEDERAL SPECIFICATION

DISPENSING PUMP, HAND DRIVEN, LIQUID PETROLEUM FUEL

This specification was approved by the Assistant Administrator, Office of Personal Property, General Services Administration, for the use of all Federal agencies.

1. SCOPE AND CLASSIFICATION

1. Scope. This specification covers hand-driven, liquid-dispensing pumps rated at 10-gallons per minute.

1.1.1 Federal specification coverage. Federal specifications do not include all varieties of the commodity as indicated by the title of the specification, or which are commercially available, but are intended to cover only those generally used by the Federal Government.

1.2 Classification.

1.2.1 Type. The dispensing pumps covered by this specification shall be of the following types as specified (see 6.2):

Type I - Rotary
Type II - Diaphragm
Type III - Piston

2. APPLICABLE DOCUMENTS

2.1 The following documents, of the issues in effect on date of invitation for bids or request for proposal, form a part of this specification to the extent specified herein:

Federal Specifications:

P-D-580	- Dry Cleaning Solvent
FF-P-101	- Padlocks
FF-W-92	- Washer, Flat, (Plain)
QQ-P-416	- Plating, Cadmium (Electrodeposited)
PPP-B-601	- Boxes, Wood, Cleated-Plywood

FSC 4930

Source: https://assist.dla.mil -- Downloaded: 202610-26T12:24Z
Check the source to verify that this is the current version before use.

PPP-B-636	- Boxes, Shipping, Fiberboard.
PPP-B-640	- Boxes, Fiberboard, Corrugated, Triple-Wall.
PPP-P-40	- Packaging and Packing of Hand Tools.
PPP-T-60	- Tape: Packaging, Waterproof.

Federal Standards:

FED. STD. H28	- Screw-Thread Standards for Federal Services.
FED. STD. 123	- Marking for Shipment (Civil Agencies).
FED. STD. 595	- Colors.

(Activities outside the Federal Government may obtain copies of Federal specifications, standards, and commercial item descriptions as outlined under General Information in the Index of Federal Specifications, Standards and Commercial Item Descriptions. The Index, which includes cumulative bimonthly supplements as issued, is for sale on a subscription basis by the Superintendent of Documents, U.S. Government Printing Office, Washington, DC 20402.

(Single copies of this specification and other Federal specifications, and commercial item descriptions required by activities outside the Federal Government for bidding purposes are available without charge from General Services Administration Business Service Centers in Boston, MA; New York, NY; Washington, DC; Philadelphia, PA; Atlanta, GA; Chicago, IL; Kansas City, MO; Fort Worth, TX; Houston, TX; Denver, CO; San Francisco, CA; Los Angeles, CA; and Seattle, WA.

(Federal Government activities may obtain copies of Federal Standardization documents, and the Index of Federal Specifications, Standards and Commercial Item Descriptions from established distribution points in their agencies.)

Military Specifications:

MIL-P-116	- Preservation, Methods of.
MIL-P-514	- Plate, Identification, Instruction and Marking, Blank.
MIL-T-704	- Treatment and Painting of Materiel.
MIL-G-3056	- Gasoline, Automotive, Combat.
MIL-B-7883	- Brazing of Steels, Copper, Copper Alloys, Nickle Alloys, Aluminum and Aluminum Alloys.
MIL-H-11588	- Hose Assembly, Rubber, Synthetic, Liquid Petroleum Fuels, Dispensing, Collapsible.
MIL-P-19834	- Plate, Identification, Metal Foil, Adhesive Backed.
MIL-L-21260	- Lubricating Oil, Internal Combustion Engine, Preservative and Break-In.
MIL-N-52110	- Nozzles, Fuel and Oil Servicing, Non-Automatic Shut-Off, and Nozzles, Fuel Servicing, Automatic Shut-Off.

Source: https://assist.dla.mil -- Downloaded: 2026l0-26T12:24Z
Check the source to verify that this is the currentversion before use.

Military Standards:

MIL-STD-105	- Sampling Procedures and Tables for Inspection by Attributes.
MIL-STD-129	- Marking for Shipment and Storage.
MIL-STD-130	- Identification Marking of US Military Property.
MIL-STD-810	- Environmental Test Methods
MIL-STD-889	- Dissimilar Metals.
MIL-STD-1188	- Commercial Packaging of Supplies and Equipment.
MS27021	- Coupling Half, Quick Disconnect, Cam-Locking Type, Male, Hose Shank Type II.
MS27022	- Coupling Half, Quick Disconnect, Cam-Locking Type, Male, External Pipe Thread, Type III.
MS27025	- Coupling Half, Quick Disconnect, Cam-Locking Type, Female, Hose Shank, Type VI.
MS27026	- Coupling Half, Quick Disconnect, Cam-Locking Type, Female, External Pipe Thread, Type VII.
MS27127	- Nut, Welding - Without Pilot.

DRAWINGS

ME

TA13217E2300	- Dispensing Pump, Hand Driven, Piston Type.

(Copies of military specifications and standards required by contractors in connection with specific procurement functions should be obtained from the procuring activity or as directed by the contracting officer.)

2.2 Other publications. The following documents form a part of this specification to the extent specified herein. The issues of the documents which are indicated as DoD adopted shall be the issue listed in the current DoDISS and the supplement thereto, if applicable.

Society of Automotive Engineers (SAE):

J429 - Mechanical and Material Requirements for Externally Threaded Fasteners.
J492 - Rivets and Riveting.

(Application for copies should be addressed to the Society of Automotive Engineers, 400 Commonwealth Drive, Warrendale, PA 15086.)

3. REQUIREMENTS

3.1 Description. The dispensing pump shall include all the features, components, and accessories necessary for dispensing liquid petroleum fuels from

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T12:24Z
Check the source to verify that this is the current version before use.

barrels, drums, and tanks. The dispensing pump shall include a pump head, suction pipe, drain pan assembly, discharge spout or nozzle, and hose assembly as specified herein. The complete unit shall not weight more than 55 pounds. All parts subject to wear, breakage, or distortion shall be accessible for replacement, adjustment, and repair.

3.2 First article. When specified (See 6.2), the contractor shall furnish sample unit (s) for first article inspection and approval (see 4.3 and 6.4).

3.3 Material. Material shall be as specified herein. Material not definitely specified shall be of the quality necessary to produce a pump to meet the requirements specified herein (see 6.6). Dissimilar metals as defined in MIL-STD-889 shall not be used in intimate contact with each other unless the metals are protected against galvanic corrosion.

3.4 Interchangeability. All parts having the same part number shall be functionally and dimensionally interchangeable. Interchangeable parts are defined as two or more parts possessing such functional and physical characteristics as to be equivalent in performance and durability and capable of being exchanged one for the other without alteration of the parts themselves or of adjoining parts except for adjustment, and without selection for fit or performance.

3.5 Construction. The dispensing pump shall be complete, so that when installed in a barrel, drum, or tank it can be used for the purpose intended. It shall be constructed to withstand the strains, jars, vibration, and other conditions incident to shipping, storage, installation, and service.

3.5.1 Threads. All threaded parts shall conform to the applicable requirements of FED. STD. H28.

3.5.2 Fastening devices. All screws, pins, bolts, and similar parts, shall be installed with means for preventing loss of tightness. All such parts, when subject to removal or adjustment, shall not be swaged, peened, staked, or otherwise permanently deformed.

3.6 Components.

3.6.1 Pump. The pump shall be of the type as specified (see 1.2.1), self-priming, and continuous flow. Diaphragm and piston type pumps shall be double acting. The intake and outlet openings shall provide 3/4- or 1-inch NPT internal threads to accommodate the suction pipe and discharge spout or the discharge hose assembly. The pump shall be equipped with gaskets and packing and shall not leak when tested as specified in 4.5.2.4. Parts which are in contact with the liquid being pumped shall not be adversely affected by continued soaking in petroleum products.

3.6.2 Suction assembly.

3.6.2.1 Suction pipe. Each dispensing pump shall be equipped with an adjustable telescopic type suction pipe. The suction pipe shall be made from

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T12:24Z
Check the source to verify that this is the current version before use.

standard weight NPS galvanized or cadmium plated steel pipe or aluminum tubing. The suction pipe shall be 3/4 inch or 1 inch, as specified (see 6.2). The suction pipe shall be approximately 21 inches long in the fully retracted position and approximately 40 inches long in the fully extended position. The pump end connection for the suction pipe shall be 3/4- or 1-inch NPT external thread as designated by the suction pipe size. The suction pipe end that contacts the bottom of the fuel containers shall be designed to allow full flow with a minimum of resistance.

3.6.2.2 Seal. The material for the seal used on the telescoping suction pipe shall be suitable for use with petroleum fuels and shall be suitable for use at temperatures between -25°F and +110°F. The suction pipe shall show no evidence of leaking when tested as specified in 4.5.2.3.

3.6.2.3 Screen. A removable 80-mesh metal screen shall be installed in the inlet port of the pump. The screen shall be 80 mesh of corrosion resistant metal wire or wire cloth with an effective flow area of at least two times the inlet port area.

3.6.2.4 Bung adapter. The bung adapter shall be either cast iron, malleable iron, bronze, or die-cast zinc base alloy. The bung adapter may be part of the pump body and of the same material. The bung adapter shall be threaded for use on a 2-inch straight pipe thread bung opening.

3.6.3 Hose and nozzle assembly (1 inch). When specified (see 6.2), the dispensing pump shall be equipped with a hose, nozzle assembly, and a quick-disconnect coupling conforming to MS27022-5.

3.6.3.1 Hose assembly. The hose assembly shall conform to MIL-H-11588, Type I, Class 3, and the hose shall be 1-inch size by 20 feet long. The coupling halves shall conform to MS27021-5 and MS27025-5.

3.6.3.2 Nozzle assembly. The nozzle assembly shall conform to MIL-N-52110, Type I, Size 1, Class A, Style 1. The nozzle inlet shall have a quick-disconnect coupling conforming to MS27026-5.

3.6.4 Hose and nozzle assembly (3/4 inch). When specified (see 6.2), the dispensing pump shall be equipped with a hose, nozzle assembly, and a quick-disconnect coupling conforming to MS27022-3.

3.6.4.1 Hose assembly. The hose assembly shall conform to MIL-H-11588, Type I, Class 3, except the hose shall be 3/4-inch size by 20 feet long. The coupling halves shall conform to MS27021-3 and MS27025-3.

3.6.4.2 Nozzle assembly. The nozzle assembly shall conform to MIL-N-52110, Type I, Size 1, Class A, Style 1. The nozzle inlet shall have a quick-disconnect coupling conforming to MS27026-3.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T12:24Z
Check the source to verify that this is the current version before use.

3.6.5 Discharge spout and drain pan assembly. When specified (see 6.2), the dispensing pump shall be equipped with a discharge spout and drain pan assembly, in lieu of a hose, nozzle assembly, and quick-disconnect coupling (see 3.6.3 and 3.6.4).

3.6.5.1 Discharge spout. The spout shall be threaded at both ends with NPT threads. One end of the spout shall be NPT external threads to mate with the outlet port of the pump.

3.6.5.2 Drain pan. The drain pan shall return dripping and overflowed liquid back into the container. The drain pan shall be attached below the pump. A noncorrosive strainer shall be provided for preventing foreign particles from entering the container. The strainer shall have a nominal thickness of 0.022 inch having not less than 100 holes per square inch of 1/16-inch nominal diameter or the strainer shall be 60 by 60 wire mesh with 0.007-inch nominal diameter wire. The base shall be provided with a threaded portion suitable for installation in a 2-inch NPT bung opening.

3.6.6 Handcrank or hand lever. The handcrank or hand lever shall be of malleable iron, cast iron, or steel with a wooden or plastic handgrip suitable for use with arctic mittens. The handgrip on the handcrank or hand lever shall be 3.75 inches minimum in length and 1 inch minimum in diameter. On the handcrank, the handgrip shall be designed so that it turns freely on its shaft, and the cranking radius shall be between 6 and 16 inches. When specified (see 6.2), the dispensing pump shall have a padlock conforming to FF-P-101, Type EW, to lock the handcrank or hand lever when not in use. When specified (see 6.2), the pump shall be provided with holes to accommodate a lock.

3.7 Performance.

3.7.1 Capacity. The pump, when tested as specified in 4.5.2.1, shall deliver not less than the rated capacities of liquid petroleum fuels when operated as specified below:

Type I	- 10 gpm at 115 rpm.
Type II	- 10 gpm at 50 cpm.
Type III	- 10 gpm at 50 cpm.

3.7.2 Dry operation. The pump, when tested as specified in 4.5.2.2, shall not be adversely affected by dry operation.

3.7.3 Temperature range. The pump, when tested as specified in 4.5.2.5 and 4.5.2.6, shall operate as specified throughout ambient temperatures from -25°F to +110°F.

3.7.4 Pump performance. The pump, when tested as specified in 4.5.2.2, shall be self-priming and when tested as specified in 4.5.2.1 shall have a dry suction lift of not less than 5 feet.

Source: https://assist.dla.mil -- Downloaded: 202610-26T12:24Z
Check the source to verify that this is the current version before use.

3.7.5 Pump handle. The force required to operate the pump handle or crank, when tested as specified in 4.5.2.1, shall not exceed 25 pounds.

3.7.6 Brace. Unless otherwise specified (see 6.2), the Type II and Type III dispensing pumps shall be provided with a bracing attachment constructed in accordance with TA13217E2300, as specified in QQ-P-416, Class 1, Type II. The washer shall conform to FF-W-92, Type A, Grade 1, Class A, cadmium plated. The welding nut shall conform to MS27127-4. The brace shall be assembled to the pump and a 55-gallon drum as shown on TA13217E2300. The brace when tested as specified in 4.5.2.3 shall provide a rigid support for the pump without permanent deformation, failure or distortion to the pump, 55-gallon drum, or itself.

3.8 Finish. Normally painted exterior surfaces shall be cleaned, treated, and painted in accordance with MIL-T-704, Type A. Unless otherwise specified (see 6.2), the color shall be in accordance with Color No. 24087 of FED. STD. 595.

3.9 Identification marking.

3.9.1 Military agencies. The pump unit shall be identified in accordance with MIL-STD-130. The marking shall be applied to the pump unit on plates conforming to MIL-P-514, Type I, Style 3, Composition C, of Type I, Grade A, Class 1 material. Plates shall be attached by screws, bolts, pressure sensitive seal in accordance with MIL-P-19834, Type I or rivets in a conspicuous protected location.

3.9.2 Civil agencies. The pump unit shall have the contractor's standard commercial identification marking.

3.10 Workmanship.

3.10.1 Castings and forgings. All parts, components, and assemblies of the dispensing pumps which include castings and forgings shall be clean of harmful extraneous material such as sand, dirt, sprues, scale, and flux. Rework shall be limited to procedures which do not reduce strength or affect function.

3.10.2 Metal fabrication. Metal used in fabrication shall be free from kinks and sharp bends. The straightening of material shall be done by methods that will not cause injury to the material. Corners shall be square and true. Flame cutting, using tips suitable for the thickness of the steel, may be employed instead of shearing and sawing. All bends shall be made with controlled means to insure uniformity of size and shape. Precaution shall be taken to avoid overheating. Heated steel shall be allowed to cool slowly. External surfaces shall be free of burrs and sharp edges and corners, except when sharp edges or corners are required or where they are not detrimental to safety.

3.10.3 Riveted connections. Rivets shall fill the holes completely. The upset rivet heads shall be full, neatly made, concentric with the rivet holes, and in full contact with the surface of the member, and shall be in accordance with SAE J492.

Source: https://assist.dla.mil -- Downloaded: 202610-26T12:24Z
Check the source to verify that this is the current version before use.

3.10.4 Machine work. Tolerances and gages for metal fits shall conform to the limits specified herein and on applicable drawings and to the standards of the industry.

3.10.5 Brazing. Brazing of steels, copper alloys and nickel alloys shall conform to MIL-B-7883.

3.10.6 Bolted connections. Boltholes shall be accurately formed and shall have the burrs removed. Washers or lockwashers shall be provided where necessary. Matching thread areas securing bolts conforming to SAE J429 or capscrews shall be of sufficient strength to withstand the working strength of the bolt. All fasteners shall be correctly torqued and shall have full thread engagement.

3.10.7 Welding. The surfaces of parts to be welded shall be free from rust, scale, paint, grease, mill scale that can be removed by chipping and wire brushing, and other foreign matter. Welds shall transmit stress without permanent deformation or failure when the parts connected by the welds are subjected to proof and service loading. Parent materials, weld filler metals, and fabrication techniques shall be as required to enable the dispensing pumps to conform to the examination and test requirements specified in Section 4. Parts to be joined by fillet welds shall be brought into as close contact as possible and in no event shall be separated by more than 3/16 inch, unless appropriate bridging techniques are used. Unless otherwise specified (see 6.2), the welding process used in fabrication of the dispensing pumps shall be at the option of the contractor.

4. QUALITY ASSURANCE PROVISIONS

4.1 Responsibility for inspection. Unless otherwise specified in the contract, the contractor is responsible for the performance of all inspection requirements as specified herein. Except as otherwise specified in the contract, the contractor may use his own or any other facilities suitable for the performance of the inspection requirements specified herein, unless disapproved by the Government. The Government reserves the right to perform any of the inspections set forth in the specification where such inspections are deemed necessary to assure supplies and services conform to prescribed requirements.

4.1.1 Component and material inspection. The contractor is responsible for insuring that components and materials used are manufactured, examined, and tested in accordance with referenced specifications and standards, as applicable.

4.2 Classification of inspection. The inspection requirements specified herein are classified as follows:

a. First article inspection (see 4.3).
b. Quality conformance inspection (see 4.4).
c. Inspection of packaging (see 4.6).

4.3 First article inspection. First article inspection shall be performed on one or more units (see 6.2). The inspection will be performed by the Government

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T12:24Z
Check the source to verify that this is the current version before use.

at a site selected by the Government. Failure of the first article to pass the examination and tests shall be cause for rejection. The first article may be a standard production unit from the contractor's current inventory provided the unit meets the requirements of the specification and is representative of the manufacturing technique applicable to the remaining units to be furnished under the contract.

4.3.1 Examination. The first article dispensing pump shall be examined as specified in 4.5.1. Presence of one or more defects shall be cause for rejection.

4.3.2 Tests. The first article dispensing pump shall be tested as specified in 4.5.2.1 through 4.5.2.6. Failure of any test shall be cause for rejection.

4.4 Quality conformance inspection.

4.4.1 Sampling. Sampling for examination and tests shall be in accordance with MIL-STD-105, Inspection Level II.

4.4.2 Examination.

4.4.2.1 Samples. Samples selected in accordance with 4.4.1 shall be examined for the major and minor defects specified in 4.5.1. AQL shall be 2.5 percent defective for major defects and 6.5 percent defective for minor defects.

4.4.3 Tests.

4.4.3.1 Samples. Samples selected in accordance with 4.4.1 shall be tested as specified in 4.5.2.2 and 4.5.2.4. AQL shall be 2.5 percent defective.

4.5 Inspection procedure

4.5.1 Examination. The dispensing pump shall be examined as specified herein for the following defects:

Major

101. Parts not interchangeable as specified.
102. Material not as specified or not in compliance with MIL-STD-889.
103. Construction of dispensing pump not as specified.
104. Pump performance not as specified.
105. Suction pipe not as specified.
106. Seal not as specified.
107. Screen not as specified.
108. Bung adapter not as specified.
109. Hose and nozzle assembly not as specified.
110. Discharge spout not as specified.
111. Drain pan not as specified.
112. Handcrank or hand lever not as specified.
113. Dry operation of the pump not as specified.
114. Temperature range of operation of the pump not as specified.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T12:24Z
Check the source to verify that this is the current version before use.

115. Pump performance not as specified.
116. The force required to operate the pump handle or crank not as specified.
117. Brace not as specified.
118. Workmanship not as specified.

Minor

201. Treatment and painting not as specified.
202. Identification marking not as specified.

4.5.2 Tests.

4.5.2.1 Capacity. The dispensing pump shall be located 5 feet above the level of the test fluid, with a 1-inch diameter hose connecting the pump to the test fluid container. The test fluid shall be fuel conforming to MIL-G-3056 or solvent conforming to P-D-680. Each dispensing pump tested shall be subjected to a 5-minute break-in run. The dispensing pump shall be operated for a period of 10 minutes. Mechanical devices may be used to operate the pump and measure the handle force. Nonconformance to 3.7.1 and 3.7.5 shall constitute failure of this test.

4.5.2.2 Priming. The dispensing pump shall be located as specified in 4.5.2.1. The dry pump shall be operated at 50 rpm for type I or 50 cpm for type II or III. Full flow shall occur within 30 seconds. Nonconformance to 3.7.2 or 3.7.4 shall constitute failure of this test.

4.5.2.3 Pump brace. When assembled and mounted on a 55-gallon drum as specified in 3.7.6, the type II and type III dispensing pumps shall be operated, dispensing test fluid until the drum is empty. A mechanical device may be used to operate the pump. Nonconformance to 3.7.5 or 3.7.6 shall constitute failure of this test.

4.5.2.4 Leakage. The outlet of the dispensing pump shall be plugged, and air at a pressure of 10 psig shall be applied to the pump inlet. The dispensing pump shall be submerged in water for a period of 5 minutes and examined for air leakage as evidenced by bubbles. Nonconformance to 3.6.1 shall constitute failure of this test.

4.5.2.5 Low temperature. When specified (see 6.2), the dispensing pump shall be tested as specified in MIL-STD-810, Test Method 502, Procedure I. Nonconformance to 3.7.3 shall constitute failure of this test.

4.5.2.6 High temperature. When specified (see 6.2), the dispensing pump shall be tested as specified in MIL-STD-810, Test Method 501, Procedure I. Nonconformance to 3.7.3 shall constitute failure of this test.

4.6 Inspection of preparation for delivery.

4.6.1 Quality conformance inspection of pack.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T12:24Z
Check the source to verify that this is the current version before use.

4.6.1.1 Unit of product. For the purpose of inspection, a completed pack prepared for shipment shall be considered a unit of product.

4.6.1.2 Sampling. Sampling for examination shall be in accordance with MIL-STD-105.

4.6.1.3 Examination. Samples selected in accordance with 4.6.1.2 shall be examined for the following defects. AQL shall be 2.5 percent defective.

119. Materials, methods, and containers not as specified for Level A or B. Each incorrect material, method, or container shall be considered one defect.
120. Disassembly not as specified for Level A or B.
121. Pump not preserved and openings sealed as specified for Level A or B.
122. Maintenance tools not preserved and packaged in accordance with referenced document for Level A or B.
123. Consolidated packaging not as specified for Level A or B.
124. Packing not as specified for Level A or B.
125. Quantities packed together exceed the limitations of the applicable box for Level A or B.
126. Fiberboard boxes not closed as specified for Level A or B.
127. Marking missing, illegible, incorrect, or incomplete for Level A, B, or Commercial.

5. PREPARATION FOR DELIVERY

5.1 Preservation and packaging. Preservation and packaging shall be Level A, B, or Commercial as specified (see 6.2).

5.1.1 Level A.

5.1.1.1 Disassembly. The dispensing pump shall be disassembled the minimum amount to provide economy in packaging. Specifically the hose assembly, nozzle assembly, suction pipe, and the handcrank or lever shall be removed when removal will reduce the overall cube of the pack. Removed bolts, nuts, and washers shall be placed in one of the mating parts and secured or preserved together in accordance with MIL-P-116, Method IC-1.

5.1.1.2 Pump. The pump interior shall be coated with lubricating oil conforming to MIL-L-21260, Type I, Grade 30. Coating shall be accomplished by pumping the oil through the pump and then draining. The inlet and outlet openings shall be sealed with plastic or metal plugs or tape conforming to PPP-T-60, Type IV.

5.1.1.3 Instructional material. Instructional material shall be preserved together in accordance with MIL-P-116, Method IC-1 or IC-3.

5.1.1.4 Repair parts. When provided (see 6.5), repair parts shall be preserved and packaged in accordance with the applicable criteria of MIL-P-116.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T12:24Z
Check the source to verify that this is the current version before use.

5.1.1.5 Maintenance tools. When provided (see 6.5), maintenance tools shall be preserved and packaged in accordance with the Level A requirements of PPP-P-40.

5.1.1.6 Consolidated packaging. Components comprising one complete dispensing pump shall be consolidated packaged together in a close-fitting box conforming to PPP-B-636, W5c. The contents shall be immobilized within the container by the use of fiberboard inserts, pads, or cushions, fabricated from the same material as the box. The box shall be closed by Method V as specified in the appendix to the box specification.

5.1.2 Level B (civil agencies). Each complete dispensing pump shall be preserved and packaged as specified in 5.1.1 for level A except the maintenance tools, when provided (see 6.5), shall be preserved and packaged in accordance with PPP-P-40, Level B and the box and the inserts, pads, or cushions, used in consolidated packaging shall conform to PPP-B-636, Type CF, Class Domestic, Grade 200. Box closure shall be in accordance with the appendix to the box specification.

5.1.3 Commercial. Each complete dispensing pump shall be preserved and packaged in accordance with MIL-STD-1188.

5.2 Packing. Packing shall be level A, B, or commercial, as specified (see 6.2).

5.2.1 Level A. Dispensing pumps of like description, preserved and packaged as specified in 5.1, shall be packed together in a close-fitting box conforming to PPP-B-601, Overseas Type, style optional in quantities not to exceed the weight limitation of the box. Box closure and strapping shall be in accordance with the appendix to the box specification.

5.2.2 Level B.

5.2.2.1 Military agencies. Dispensing pumps of like description, preserved and packaged as specified in 5.1, shall be packed together as specified in 5.2.1 except boxes shall be domestic type. As an alternate, the pumps may be packed in a close-fitting box conforming to PPP-B-640, Class 2, or PPP-B-636, V3c, V11c, V13c, or V15c, style optional. The gross weight or size of each box shall not exceed the limitations of the applicable box specification. Fiberboard boxes shall be waterproof sealed in accordance with the applicable box specification appendix.

5.2.2.2 Civil agencies. The dispensing pumps shall be packed in a close-fitting fiberboard box conforming to PPP-B-636, Class Domestic, style optional. Closure shall be in accordance with method II of the appendix to PPP-B-636.

5.2.3 Commercial. Dispensing pumps, preserved and packaged as specified in 5.1, shall be packed in accordance with MIL-STD-1188.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T12:24Z
Check the source to verify that this is the current version before use.

5.3 Marking.

5.3.1 Civil agencies. In addition to any special marking required by the contract or order (see 6.2), interior packages and shipping containers shall be marked in accordance with FED. STD. 123.

5.3.2 Military agencies. In addition to any special marking required by the contract or order (see 6.2), interior packages and shipping containers for level A or B shall be marked in accordance with MIL-STD-129. Marking for commercial packaging shall be in accordance with MIL-STD-1188.

6. NOTES

6.1 Intended use. The dispensing pumps covered by this specification are used to transfer liquid petroleum products from drums into vehicle and aircraft tanks and into smaller containers.

6.2 Ordering data. Acquisition documents should specify the following:

a. Title, number, and date of this specification.
b. Type of dispensing pump required (see 1.2.1 and 3.7.1).
c. When sample units will be required for first article, inspection and number of units required (see 3.2, 4.3 and 6.4).
d. Size of suction pipe (see 3.6.2.1).
e. When a hose, nozzle assembly and quick-disconnect coupling (1 inch) is required (see 3.6.3).
f. When a hose, nozzle assembly and quick-disconnect coupling (3/4 inch) is required (see 3.6.4).
g. When a discharge spout and drain pan assembly is required (see 3.6.5).
h. When a padlock is required (see 3.6.6).
i. When holes in pump to accommodate lock are required (see 3.6.6).
j. When a brace is required for type II and type III pumps (see 3.7.6).
k. Color required if other than as specified (see 3.8).
l. Welding process required when other than as specified (see 3.10.7).
m. When low temperature test is required (see 4.5.2.5).
n. When high temperature test is required (see 4.5.2.6).
o. Level of preservation and packaging and level of packing required (see 5.1 and 5.2).
p. Special marking required (see 5.3.1 and 5.3.2).

6.3 Contract data requirements. When this specification is used in a acquisition which incorporates a DD Form 1423 and invokes the provisions of paragraph 7-104.9(n) of the Defense Acquisition Regulation (DAR), the data requirements will be developed as specified by an approved Data Item Description (DD Form 1664) and delivered in accordance with the Contract Data Requirements List (DD Form 1423) incorporated into the contract. When the provisions of DAR 7-104.9(n) are not invoked, the data shall be delivered in accordance with the contract requirements.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T12:24Z
Check the source to verify that this is the current version before use.

6.4 First article. When a first article is required, it will be tested and approved under the appropriate provisions of paragraph 7-104.55 of the DAR. The first article may be a standard production item from the contractor's current inventory as specified in 4.3. The first article should consist of the number of units specified (see 6.2). The contracting officer should include specific instructions in all acquisition instruments, regarding arrangements for examinations, test and approval of the first article.

6.5 Provisioning. The contracting officer should include provisioning requirements for repair parts and maintenance tools as necessary (including any special tools), and instructions on shipment of dispensing pumps.

6.6 Recycled material. It is encouraged that recycled material be used, when practical, as long as it meets the requirements of the specification (see 3.3).

MILITARY INTERESTS:

Custodians:

Army - ME
Navy - YD
Air Force - 99

Review activity:

DLA - CS

User activities:

Army - CE
Navy - CG, MC

CIVIL AGENCY COORDINATING ACTIVITY:

GSA - OPP

PREPARING ACTIVITY:

Army - ME

Project 4930-0298

Orders for this publication are to be placed with General Services Administration, acting as agent for the Superintendent of Documents. See section 2 of this specification to obtain extra copies and other documents referenced herein.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T12:24Z
Check the source to verify that this is the current version before use.

STANDARDIZATION DOCUMENT IMPROVEMENT PROPOSAL

INSTRUCTIONS: This form is provided to solicit beneficial comments which may improve this document and enhance its use. DoD contractors, government activities, manufacturers, vendors, or other prospective users of the document are invited to submit comments to the government. Fold on lines on reverse side, staple in corner, and send to preparing activity. Attach any pertinent data which may be of use in improving this document. If there are additional papers, attach to form and place both in an envelope addressed to preparing activity. A response will be provided to the submitter, when name and address is provided, within 30 days indicating that the 1426 was received and when any appropriate action on it will be completed.
NOTE: This form shall not be used to submit requests for waivers, deviations or clarification of specification requirements on current contracts. Comments submitted on this form do not constitute or imply authorization to waive any portion of the referenced document(s) or to amend contractual requirements.

DOCUMENT IDENTIFIER *(Number)* AND TITLE XX-D-385E Dispensing Pump, Hand Driven, Liquid Petroleum Fuel

NAME OF ORGANIZATION AND ADDRESS OF SUBMITTER

☐ VENDOR ☐ USER ☐ MANUFACTURER

1. ☐ HAS ANY PART OF THE DOCUMENT CREATED PROBLEMS OR REQUIRED INTERPRETATION IN PROCUREMENT USE? ☐ IS ANY PART OF IT TOO RIGID, RESTRICTIVE, LOOSE OR AMBIGUOUS? PLEASE EXPLAIN BELOW.

A. GIVE PARAGRAPH NUMBER AND WORDING

B. RECOMMENDED WORDING CHANGE

C. REASON FOR RECOMMENDED CHANGE(S)

2. REMARKS

SUBMITTED BY *(Printed or typed name and address — Optional)*

TELEPHONE NO.

DATE

DD FORM 1 OCT 76 1426 EDITION OF 1 JAN 72 WILL BE USED UNTIL EXHAUSTED.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T12:24Z
Check the source to verify that this is the current version before use.

FOLD

POSTAGE AND FEES PAID



OFFICIAL BUSINESS
PENALTY FOR PRIVATE USE $300

Commander
US Army Mobility Equipment R & D Command
ATTN: DRDME-DS
Fort Belvoir, VA 22060

FOLD

Source: https://assist.dla.mil -- Downloaded: 202610-26T12:24Z
Check the source to verify that this is the current version before use.