SS-P-1229a
May 2, 1968
SUPERSEDING
Int. Fed. Spec. SS-P-001229(GSA-FSS)
Dec 12, 1966 and
Fed. Spec. SS-T-310
July 30, 1942

FEDERAL SPECIFICATION

PIPE, CLAY (DRAIN)

This specification was approved by the Commissioner, Federal Supply Service, General Services Administration, for the use of all Federal agencies.

1. SCOPE AND CLASSIFICATION

1.1 Scope. This specification covers drain pipe, with butt ends, made from surface clay, fire clay, shale or mixtures thereof, and burned.

1.2 Classification. Pipe covered by this specification shall be of the following types, as specified (see 6.2):

Class 1 - Standard
Class 2 - Extra quality
Class 3 - Heavy Duty

1.3 Sizes. Drain pipe covered by this specification is available in 4,5,6,8, 10, 12, 14, 15, 16, 18, 21, 24, 27, and 30 inch internal diameters (see 6.2):

2. APPLICABLE DOCUMENTS

2.1 Specifications and standards. The following specifications and standards, of the issues in effect on date of invitation for bids, form a part of this specification to the extent specified herein.

Federal Specifications:

QQ-S-781 - Steel, Strapping, Flat
PPP-B-621 - Boxes, Wood, Nailed and Locked Corner
PPP-C-650 - Crates, Wood, Open and Covered

Federal Standard:

Fed. Std. No. 123 - Marking for Domestic Shipment (Civilian Agencies).

(Activities outside the Federal Government may obtain copies of Federal Specifications, Standards, and Handbooks as outlined under General Information in the Index of Federal Specifications and Standards and at the prices indicated in the Index. The Index, which includes cumulative monthly supplements as issued, is for sale on a subscription basis by the Superintendent of Documents, U.S. Government Printing Office, Washington, D.C., 20402.

(Single copies of this specification and other product specifications required by activities outside the Federal Government for bidding purposes are available without charge at the General Services Administration Regional Offices in Boston, New York, Washington, D. C., Atlanta, Chicago, Kansas City, Mo., Dallas, Denver, San Francisco, Los Angeles, and Seattle, Wash.

(Federal Government activities may obtain copies of Federal Specifications, Standards, and Handbooks and the Index of Federal Specifications and Standards from established distribution points in their agencies.)

Military Specification:

Mil-C-11133 - Crate, Wood, Open, Wirebound.

FSC 5630

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T12:14Z
Check the source to verify that this is the current version before use.

Military Standards:

Mil-Std-105 - Sampling Procedures and Tables for Inspection by attributes
Mil-Std-129 - Marking for Shipment and Storage
Mil-Std-147 - Palletized and Containerized Unit Loads 40"x 48" 4-Way (Partial) Pallet Skids, Runners, or Pallet-Type Base.

(Copies of Military Specifications and Standards required by contractors in connection with specific procurement functions should be obtained from the procuring activity or as directed by the contracting officer.)

2.2 Other publication. The following document forms a part of this specification to the extent specified herein. Unless otherwise indicated, the issues in effect on date of invitation for bids shall apply.

American Society for Testing and Materials (ASTM) Publication:

C4 - Specification for Clay Drain Tile

(Application for copies should be addressed to the American Society for Testing and Materials, 1916 Race Street, Philadelphia, Pa. 19103.)

American Trucking Association (ATA)

National Motor Freight Classification Rules

(Application for copies should be addressed to American Trucking Association, 1616 P Street, N.W., Washington, D. C. 20036).

Uniform Classification Committee

Uniform Freight Classification Rules

(Application for copies should be addressed to the Uniform Classification Committee, 202 Union Station, 516 W. Jackson Blvd., Chicago, Ill. 60606).

3. REQUIREMENTS

3.1 Drain pipe. Pipe covered by this specification shall meet the requirements of ASTM C4 (see 4.4).

4. QUALITY ASSURANCE PROVISIONS

4.1 Responsibility for inspection. Unless otherwise specified in the contract or order, the supplier is responsible for the performance of all inspection requirements as specified herein. Except as otherwise specified, the supplier may utilize his own facilities or any commercial laboratory acceptable to the Government. The Government reserves the right to perform any of the inspections set forth in the specification where such inspections are deemed necessary to assure that supplies and services conform to prescribed requirements.

4.2 Lot. Unless otherwise specified (see 6.2), a lot shall consist of all pipe of the same class and size offered for delivery at the same time.

4.3 Visual and dimensional examination of end item. Samples shall be selected in accordance with MIL-STD-105, using level S-4. Samples shall be examined for defects in accordance with table I, using an Acceptable Quality Level (AQL) of 2.5 defects per 100 units for major defects and 6.5 defects per 100 units for total defects.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T12:14Z
Check the source to verify that this is the current version before use.

Table I. Classification of defects, end item

Defects	Major	Minor
Class or size of pipe not as specified	X	
Cracks, checks, or chips extending into the body of the pipe in such a manner as to weaken the pipe	X	
Breaks in pipe that would admit dirt.	X	
Pipe more than 3 percent out of straightness.	X	
Exterior blisters or lumps more than 20 percent of wall thickness	X	
Damage or defects not affecting function or serviceability.		X
Damage or defects affecting function or serviceability	X	

4.4 Test methods. Test pipe in accordance with ASTM C4 (see 3.1).

4.5 Inspection of preparation for delivery. An inspection shall be made to determine that the packaging, packing and marking requirements comply with section 5 of this specification,

5. PREPARATION FOR DELIVERY

5.1 Packing. Packing shall be level A, B or C as specified (see 6.2).

5.1.1 Level A. The pipe shall be packed in boxes, crates, or palletized unit loads conforming to PPP-B-621 (class 2), PPP-C-650, MIL-C-11133 (type III), and MIL-STD-147 (load type XIII), respectively. Pipe shall be packed, when practicable, in a vertical position. Pipe lengths shall be securely blocked by wood strips to prevent movement. A two-inch minimum thickness of suitable cushioning material shall be placed between the pipe lengths and wood blocking, and between the pipe and the side ends, tops, and bottom of the boxes. Flat steel strapping shall be type I, class B in accordance with QQ-S-781.

5.1.2 Level B. The pipe shall be packed as specified for level A, except that nailed wood boxes shall conform to PPP-B-621 (class 1) and flat steel strapping need not be zinc coated.

5.1.3 Level C. The pipe shall be packed in a manner which will insure arrival at destination in satisfactory condition and be acceptable to the carrier at lowest rates. Containers and packing shall comply with Uniform Freight Classification Rules or National Motor Freight Classification Rules."

5.2 Marking (see 6.2)

5.2.1 Civil agencies. In addition to markings required by the contract or order, the pipe shall be marked in accordance with Federal Standard No. 123.

5.2.2 Military activities. In addition to markings required by the contract or order, the pipe shall be marked in accordance with MIL-STD-129.

6. NOTES

6.1 Intended use. Pipe covered by this specification is intended for use in the drainage and dispersion of excess ground water.

6.2 Ordering data. Purchasers should select the preferred options permitted herein and include the following information in procurement documents:

(a) Title, number, and date of this specification.
(b) Class and size of pipe desired (see 1.2 and 1.3).
(c) Size of lot, if different from 4.2.
(d) Selection of applicable level of packing required (see 5.1).
(e) Marking required (see 5.2).

6.3 Product name. Clay pipe covered by this specification is commonly called drain tile within the industry and by users.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T12:14Z
Check the source to verify that this is the current version before use.

6.4 Supersession data. Changes in classification data in Fed. Spec. SS-P-1229a, Int. Fed. Spec. SS-P-001229 and Fed. Spec. SS-T-310 are as follows (see 1.2):

Specification	Classification		
SS-P-1229a SS-P-001229 SS-T-310	Class 1, standard Type I, standard Standard strength grade	Class 2, extra quality Type II, extra quality Extra strength grade	Class 3, heavy duty Type III, heavy duty

MILITARY CUSTODIANS

Navy - YD
Army - ME
Air Force - 84

Review Activities

Navy - YD
Air Force - 84

User Activities

Navy - MC, CG
Army - ME, CE

Order for this publication are to be placed with General Services Administration, acting as an agent for the Superintendent of Documents. See section 2 of this specification to obtain extra copies and other documents referenced herein. cents each.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T12:14Z
Check the source to verify that this is the current version before use.