METRIC

DOD-B-24531/3(SH)
23 February 1976

MILITARY SPECIFICATION SHEET

BATTERY, STORAGE, SILVER-ZINC ALKALINE (EMERGENCY), FOR TRIESTE:

TYPE 12 V - 100 Ah (METRIC)

This specification sheet is approved for use by the Naval Sea Systems Command and is available for use by all Departments and Agencies of the Department of Defense.

The complete requirements for procuring the battery described herein shall consist of this document and the latest issue of DOD-B-24531.

REQUIREMENTS:

Electrical rating: The rating of each 8-cell battery shall be not less than that shown in table I.

Table I - Electrical rating.

Rate ampere (A)	Time hours (h)	Capacity ampere-hour (Ah)	Minimum battery voltage (V)	Minimum average cell voltage 1/ (V)	Minimum cell voltage (V)
25	4	100	10.4	1.45	1.30
50	1.8	90	9.5	1.38	1.20

1/ The "average voltage" is defined as the average readings taken at 1/2-hour intervals, starting with the first reading taken between 1/2 and 1 minute after applying the load and including the cut-off voltage.

Life: 5000 Ah total output or 1 year, whichever occurs first, before the capacity drops to 70 percent of the rated capacity.

Dimensions (in millimeters) (mm) (maximum envelope):

Maximum length - 353
Maximum width - 134
Maximum height - 121
(including terminals)

Mass: Maximum 10.5 kilograms (wet)

Terminals:

Size: 3/8-24 (two nuts per terminal post for each cell as required).


Maximum height - 13 mm above cell cover.

Note: Battery case and cover not required. The cells shall be bussed with intercell connectors and banded together to form an 8-cell battery, as shown on figure 1, to fit maximum envelope dimensions.

Preparing activity:
Navy - SH
(Project 6140-N422-3)

FSC 6140

Source: https://assist.dla.mil -- Downloaded: 202610-19T22:24Z
Check the source to verify that this is the current version before use.



INTERCELL CONNECTION: TYPICAL ONLY.
SCALE: NONE.

SH 11015

Figure 1 - Cell and intercell connection layout.

Source: https://assist.dla.mil -- Downloaded: 202610-19T22:24Z
Check the source to verify that this is the current version before use.

STANDARDIZATION DOCUMENT IMPROVEMENT PROPOSAL

OMB Approval
No. 22-R255

INSTRUCTIONS: The purpose of this form is to solicit beneficial comments which will help achieve procurement of suitable products at reasonable cost and minimum delay, or will otherwise enhance use of the document. DoD contractors, government activities, or manufacturers/vendors who are prospective suppliers of the product are invited to submit comments to the government. Fold on lines on reverse side, staple in corner, and send to preparing activity. Comments submitted on this form do not constitute or imply authorization to waive any portion of the referenced document(s) or to amend contractual requirements. Attach any pertinent data which may be of use in improving this document. If there are additional papers, attach to form and place both in an envelope addressed to preparing activity.

DOCUMENT IDENTIFIER AND TITLE

NAME OF ORGANIZATION AND ADDRESS

CONTRACT NUMBER

MATERIAL PROCURED UNDER A

☐ DIRECT GOVERNMENT CONTRACT ☐ SUBCONTRACT

1. HAS ANY PART OF THE DOCUMENT CREATED PROBLEMS OR REQUIRED INTERPRETATION IN PROCUREMENT USE?
   A. GIVE PARAGRAPH NUMBER AND WORDING.

   B. RECOMMENDATIONS FOR CORRECTING THE DEFICIENCIES

2. COMMENTS ON ANY DOCUMENT REQUIREMENT CONSIDERED TOO RIGID

3. IS THE DOCUMENT RESTRICTIVE?

   ☐ YES ☐ NO *(If "Yes", in what way?)*

4. REMARKS

SUBMITTED BY *(Printed or typed name and address - Optional)*

TELEPHONE NO.

DATE

DD FORM 1 JAN 72 1426 REPLACES EDITION OF 1 JAN 68 WHICH MAY BE USED

S/N 0102-014-1802

Source: https://assist.dla.mil -- Downloaded: 202640-19T22:24Z
Check the source to verify that this is the current version before use.

FOLD

COMMANDER
NAVAL SHIP ENGINEERING CENTER
CENTER BUILDING - SEC 6124
PRINCE GEORGES CENTER
HYATTSVILLE, MARYLAND 20782

OFFICIAL BUSINESS
PENALTY FOR PRIVATE USE $300

POSTAGE AND FEES PAID
DEPARTMENT OF NAVY

DOD 316

COMMANDER
NAVAL SHIP ENGINEERING CENTER
CENTER BUILDING - SEC 6124
PRINCE GEORGES CENTER
HYATTSVILLE, MARYLAND 20782

FOLD

Source: https://assist.dla.mil -- Downloaded: 202610-19T22:24Z
Check the source to verify that this is the current version before use.