INCH-POUND
MIL-T-24494B(SH)
19 October 1988
SUPERSEDING
MIL-T-24494A(SH)
4 August 1981
(See 6.7)

MILITARY SPECIFICATION

TETRA-, TRI-, AND DISODIUM SALTS OF ETHYLENEDIAMINETETRAACETIC ACID (EDTA) WATER TREATMENT CHEMICALS, BOILER, SHIPBOARD USE

This specification is approved for use by the Naval Sea Systems Command, Department of the Navy, and is available for use by all Departments and Agencies of the Department of Defense.

1. SCOPE

1.1 Scope. This specification covers three types of sodium salts of ethylenediaminetetraacetic acid (EDTA).

1.2 Classification. EDTA shall be of the following types, as specified (see 6.2):

TYPES

Type I - Tetrasodium EDTA
Type II - Trisodium EDTA
Type III - Disodium EDTA

2. APPLICABLE DOCUMENTS

2.1 Government documents.

2.1.1 Specifications and standard. The following specifications and standard form a part of this document to the extent specified herein. Unless otherwise specified, the issues of these documents are those listed in the issue of the Department of Defense Index of Specifications and Standards (DoDISS) and supplement thereto, cited in the solicitation (see 6.2).

Beneficial comments (recommendations, additions, deletions) and any pertinent data which may be of use in improving this document should be addressed to: Commander, Naval Sea Systems Command, SEA 55Z3, Department of the Navy, Washington, DC 20362-5101 by using the self-addressed Standardization Document Improvement Proposal (DD Form 1426) appearing at the end of this document or by letter.

AMSC N/A FSC 6810
DISTRIBUTION STATEMENT A. Approved for public release; distribution is unlimited.

Source: https://assist.dla.mil -- Downloaded: 202610-19T22:13Z
Check the source to verify that this is the current version before use.

SPECIFICATIONS

FEDERAL

PPP-C-2020 - Chemicals, Liquid, Dry, and Paste: Packaging of.
PPP-F-320 - Fiberboard; Corrugated and Solid, Sheet Stock (Container Grade), and Cut Shapes.

MILITARY

MIL-L-19140 - Lumber and Plywood, Fire-Retardant Treated.

STANDARD

FEDERAL

FED-STD-313 - Material Safety Data, Transportation Data and Disposal Data for Hazardous Materials Furnished to Government Activities.

(Unless otherwise indicated, copies of federal and Military specifications and standards are available from the Naval Publications and Forms Center, (ATTN: NPODS), 5801 Tabor Avenue, Philadelphia, PA 19120-5099.)

2.2 Non-Government publications. The following documents form a part of this document to the extent specified herein. Unless otherwise specified, the issues of the documents which are DoD adopted are those listed in the issue of the DoDISS cited in the solicitation. Unless otherwise specified, the issues of documents not listed in the DoDISS are the issues of the documents cited in the solicitation (see 6.2).

AMERICAN CHEMICAL SOCIETY (ACS)

Reagent Chemicals.

(Application for copies should be addressed to Applied Publications, American Chemical Society, 1155 16th Street, N.W., Washington, DC 20036.)

AMERICAN SOCIETY FOR TESTING AND MATERIALS (ASTM)

D 1193 - Standard Specification for Reagent Water. (DoD adopted)

(Application for copies should be addressed to the American Society for Testing and Materials, 1916 Race Street, Philadelphia, PA 19103.)

(Nongovernment standards and other publications are normally available from the organizations that prepare or distribute the documents. These documents also may be available in or through libraries or other informational services.)

2.3 Order of precedence. In the event of a conflict between the text of this document and the references cited herein, the text of this document takes precedence. Nothing in this document, however, supersedes applicable laws and regulations unless a specific exemption has been obtained.

3. REQUIREMENTS

3.1 First article. When specified (see 6.2), a sample shall be subjected to first article inspection (see 6.4 in accordance with 4.3).

Source: https://assist.dla.mil -- Downloaded: 2026-10-19T22:13Z
Check the source to verify that this is the current version before use.

3.2 Materials. The sodium salts of EDTA shall be white, granular powders. Type I, the tetrasodium salt of EDTA, shall be $Na_4EDTA \cdot 4H_2O$ ($C_{10}H_{20}O_{12}N_2Na_4$). Type II, the trisodium salt of EDTA, shall be $Na_3EDTA \cdot 3H_2O$ ($C_{10}H_{19}O_{11}N_2Na_3$). Type III, the disodium salt of EDTA, shall be $Na_2EDTA \cdot 2H_2O$ ($C_{10}H_{18}O_{10}N_2Na_2$).

3.3 Composition.

3.3.1 Type I. The tetrasodium salt of EDTA shall contain a minimum of 83.2 percent tetrasodium EDTA as active ingredient. The water (H_2O) content shall not exceed 15.8 percent. Other organic and inorganic impurities shall not exceed 1.0 percent of the total. The composition shall be determined (see 4.5).

3.3.2 Type II. The trisodium salt of EDTA shall contain a minimum of 86.2 percent trisodium EDTA as active ingredient. The H_2O content shall not exceed 13.1 percent. Other organic and inorganic impurities shall not exceed 0.7 percent of the total. The composition shall be determined (see 4.5).

3.3.3 Type III. The disodium salt of EDTA shall contain a minimum of 89.3 percent disodium EDTA as active ingredient. The H_2O content shall not exceed 9.7 percent. Other organic and inorganic impurities shall not exceed 1.0 percent of the total. The composition shall be determined (see 4.5).

3.4 Chelation activity. Chelation activity shall be determined by the oxalate method and the potentiometric titration method.

3.4.1 Oxalate method. The chelation activity shall be defined in milligrams (mg) of calcium carbonate per gram of the sample (see 4.5.2.1). Chelation activity shall agree within plus or minus 5 mg. The chelation activity of type I EDTA shall be not less than 219. The chelation activity of type II EDTA shall be not less than 241. The chelation activity of type III EDTA shall be not less than 267.

3.4.2 Potentiometric titration. The chelation activity of each type of EDTA shall be within plus or minus 2.0 percent of the values determined for each type by the oxalate method (see 3.4.1 and 4.5.2.2). Furthermore, for type I only, the volume of standard acid used to titrate to the second inflection point (volume 2) shall be twice the volume used to titrate to the first inflection point (volume 1) within 0.5 milliliter (mL).

3.5 pH value. The pH value shall be determined (see 4.5.3). The pH value shall agree within plus or minus 0.2 pH unit. The pH value for type I EDTA shall be between 10.5 and 11.5. The pH value for type II EDTA shall be between 8.5 and 9.5. The pH value for type III EDTA shall be between 4.5 and 5.5.

3.6 Material safety data sheet (MSDS). The contracting activity shall be provided a material safety data sheet at the time of contract award. The MSDS shall be provided in accordance with the requirements of FED-STD-313. The MSDS shall be included with each shipment of the material covered by this specification (see 6.5).

Source: https://assist.dla.mil -- Downloaded: 2026-10-19T22:13Z
Check the source to verify that this is the current version before use.

4. QUALITY ASSURANCE PROVISIONS

4.1 Responsibility for inspection. Unless otherwise specified in the contract or purchase order, the contractor is responsible for the performance of all inspection requirements (examinations and tests) as specified herein. Except as otherwise specified in the contract or purchase order, the contractor may use his own or any other facilities suitable for the performance of the inspection requirements specified herein, unless disapproved by the Government. The Government reserves the right to perform any of the inspections set forth in the specification where such inspections are deemed necessary to ensure supplies and services conform to prescribed requirements.

4.1.1 Responsibility for compliance. All items must meet all requirements of sections 3 and 5. The inspection set forth in this specification shall become a part of the contractor's overall inspection system or quality program. The absence of any inspection requirements in the specification shall not relieve the contractor of the responsibility of ensuring that all products or supplies submitted to the Government for acceptance comply with all requirements of the contract. Sampling inspection, as part of the manufacturing operations, is an acceptable practice to ascertain conformance to requirements, however, this does not authorize submission of known defective material, either indicated or actual, nor does it commit the Government to accept defective material.

4.2 Classification of inspections. The inspection requirements specified herein are classified as follows:

(a) First article inspection (see 4.3).
(b) Quality conformance inspection (see 4.4).

4.3 First article inspection. First article inspection shall consist of the tests specified in 4.5 (see 6.3).

4.4 Quality conformance inspection. Quality conformance inspection shall consist of the tests of 4.5 (see 6.3).

4.4.1 Lot. A lot shall consist of that amount of material that has been produced as the result of a single manufacturing process. In cases in which it is not practical to define the sampling lot in this manner, the lot shall consist of all material manufactured as one batch and offered for delivery at one time.

4.5 Tests.

4.5.1 Water content. Triplicate tests shall be performed on each sample of approximately 2.5 grams. The specimen shall be transferred into a clean, dry tared weighing bottle (50 by 30 millimeters) so that the sample is evenly spread over the bottom of the bottle. It shall be weighed so the sample weight is determined plus or minus 0.2 mg. The weighing bottle, stopper (ajar for water escape), and the sample shall be placed in an oven set at 165 ± 2 degrees Celsius (°C) for type I EDTA, 110 ± 2°C for type II EDTA, and 140 ± 2°C for type III EDTA. The drying shall be continued for 3 hours after the sample is put into the oven. While still hot, the weighing bottle shall be stoppered and allowed to cool in a desiccator over anhydrous calcium sulfate. The weight of the dry sample shall be determined (plus or minus 0.2 mg), and the percentage of water in the sample calculated as follows:

Source: https://assist.dla.mil -- Downloaded: 202640-19T22:13Z
Check the source to verify that this is the current version before use.

$$\text{Percent of water} = \frac{\text{(weight of original sample minus weight of dried sample) x 100}}{\text{weight of original sample}}$$

Test results on the samples shall agree within plus or minus 2 percent. The EDTA shall not char or change color to yellow or tan during the heating.

4.5.2 Chelation activity. Chelation activity shall be determined by two methods, the oxalate method (see 4.5.2.1), and the potentiometric titration method (see 4.5.2.2). Both of these methods shall be run in triplicate.

4.5.2.1 Oxalate method. For each sample to be tested, three 1-gram portions shall be tested. Titrations shall be conducted at room temperature (25 ± 3°C).

4.5.2.1.1 Preparation of reagents. Unless otherwise specified herein, all reagents shall be ACS reagent grade chemicals. Wherever reagent water is used it shall be ASTM D 1193, type II. The following reagents shall be used in the test.

4.5.2.1.1.1 Ammonium oxalate, saturated solution. Sixty grams of calcium-free ammonium oxalate in 1 liter of hot water and allowed to cool to room temperature.

4.5.2.1.1.2 Sodium hydroxide, 1 mole (M) solution. Forty grams of sodium hydroxide shall be dissolved in 1 liter of water.

4.5.2.1.1.3 Calcium chloride, standard solution. Ten and one one-hundredth grams of ACS reagent grade chelometric standard calcium carbonate shall be added to 300 mL of water. Slowly and cautiously, 18 mL of concentrated hydrochloric acid shall be added to the stirred mixture, and the resulting clear solution shall be boiled to remove carbon dioxide. After cooling to room temperature, concentrated ammonium hydroxide shall be added until the solution is slightly alkaline to litmus and diluted with distilled water to exactly 1 liter in a volumetric flask.

4.5.2.1.2 Procedure. The sample to be tested shall be weighed to 1 gram (plus or minus 0.2 mg), then transferred into a beaker containing a teflon-coated stirring bar. Eighty-five mL of water and 5 mL of saturated ammonium oxalate solution shall be added and the mixture stirred until the granular powder is completely dissolved. The sample shall be titrated with standard calcium chloride solution until the first permanent turbidity is detected. The pH of the solution is checked by a pH meter at this time to assure a minimum pH value of 11.0. Sodium hydroxide, 1 M, shall be added to adjust the pH to 11. If the precipitate dissolves after the pH is adjusted, titration shall be continued until the turbidity is permanent. Chelation activity shall be calculated as follows:

$$\text{Chelation activity} = \frac{\text{(mL } CaCl_2 \text{ solution) x 10}}{\text{gram of sample}} = \text{mg } CaCO_3 \text{ per gram of chelant}$$

4.5.2.2 Potentiometric method. For each sample to be tested, three 1-gram portions shall be tested.

Source: https://assist.dla.mil -- Downloaded: 20260-19T22:13Z
Check the source to verify that this is the current version before use.

4.5.2.2.1 Preparation of reagents. Unless otherwise specified herein, all reagents shall be ACS reagent grade chemicals and the water shall be ASTM D 1193, type II. The following reagents shall be used in the test.

4.5.2.2.1.1 Sodium hydroxide, 0.1 M solution. Four grams of sodium hydroxide shall be dissolved in 1 liter of freshly boiled and cooled water. This sodium hydroxide solution shall be standardized in triplicate with potassium hydrogen phthalate (KHP), $KHC_8H_4O_4$, which has been dried for 2 hours at 120°C and then stored in a desiccator over calcium sulfate. Three 0.8-gram (plus or minus 0.2 mg) portions of KHP shall be weighed, 75 mL of freshly boiled and cooled water, and three drops of phenolphthalein indicator added to each portion. Each of these shall be titrated with the sodium hydroxide until a persistent, permanent pale pink color appears. The volume of sodium hydroxide plus or minus 0.02 mL shall be noted. The concentration of the sodium hydroxide shall be calculated by:

$$\text{Concentration of sodium hydroxide} = \frac{\text{weight of KHP (gram) x 1000}}{\text{204.22 x volume of sodium hydroxide solution (mL)}}$$

The three values shall agree within plus or minus 0.0005 M. The value used shall be the average of the three determinations. Fresh solutions shall be utilized.

4.5.2.2.1.2 Hydrochloric acid, 0.1 M solution. Eight and one-tenth mL concentrated hydrochloric acid shall be dissolved in 1 liter of freshly boiled and cooled distilled water. This hydrochloric acid solution shall be standardized in triplicate with the standardized sodium hydroxide solution (see 4.5.2.2.1.1). Three 30-mL portions of the 0.1 M hydrochloric acid solution shall be measured out noting the volume to plus or minus 0.04 mL. Three drops of phenolphtalein indicator shall be added to each portion and each of these tritrated with the standardized sodium hydroxide solution until a persistent, permanent pale pink color develops. The volume of base used shall be noted plus or minus 0.04 mL. The concentration of hydrochloric acid shall be calculated by:

$$\frac{\text{concentration of sodium hydroxide x volume of sodium hydroxide (mL)}}{\text{volume of hydrochloric acid (mL)}}$$

The three values shall agree within plus or minus 0.0009. The value reported shall be the average of the three determinations.

4.5.2.2.2 Procedure. The sample to be tested shall be weighed to 1 gram (plus or minus 0.2 mg), and transferred into a beaker. A teflon-coated stirring bar and 100 mL of water shall be added and the mixture stirred until solution is complete. The pH value of the stirred solution shall be determined using a pH meter that is equipped with a glass electrode and reference electrode or a suitable combination electrode. The pH meter shall be standardized with both a pH 10 buffer protected from carbon dioxide contamination and a pH 4 buffer. Buffers shall be not older than 3 months, nor show visual changes from the time of preparation. The pH of the stirred solution containing the sample shall be used for the pH value determination specified (see 4.5.3).

Source: https://assist.dla.mil -- Downloaded: 2026-10-19T22:13Z
Check the source to verify that this is the current version before use.

4.5.2.2.2.1 Type I EDTA. Type I EDTA sample solutions shall be titrated using standard 0.1 M hydrochloric acid and a 50-mL buret. The volume of acid needed to reach the first volume and second volume inflection points shall be determined as follows:

(a) In the vicinity of the inflection points, 1-mL increments of acid are added and the pH or millivolt (mV) output of the pH measuring system are recorded;
(b) Sufficient data are accumulated to determine the inflection points by the second derivative method (ACS Reagent Chemicals). Volume 1 and volume 2 shall be interpolated to 0.01 mL;
(c) An automatic titrator also may be used to determine the volumes of volume 1 and volume 2;
(d) The chelating activity is calculated by the following equation:

$$\text{Chelating activity expressed as mg } CaCO_3 \text{ per gram of chelant} = \frac{(\text{volume 2} - \text{volume 1}) \times \text{concentration of HCl} \times 100.09}{\text{weight of sample (gram)}}$$

In addition, volume shall equal volume 2 minus volume 1, within 0.5 mL for type I, only.

4.5.2.2.2.2 Type II EDTA. Type II EDTA shall be tested in the same manner as that used for type I.

4.5.2.2.2.3 Type III EDTA. Type III EDTA sample solutions shall be titrated using fresh standard 0.1 M sodium hydroxide solutions in a 50-mL buret. The volume of base volume needed to reach the inflection point shall be determined as follows:

(a) In the vicinity of the inflection point, 1-mL increments of base are added and the pH or mV output of the pH meter are recorded;
(b) Sufficient data are accumulated to determine the inflection point by the second derivative method (ACS Reagent Chemicals). The volume shall be interpolated to 0.01 mL;
(c) An automatic titrator also may be used to determine the volume;
(d) The chelating activity is calculated by the following equation:

$$\text{Chelating activity expressed as mg } CaCO_3 \text{ per gram of chelant} = \frac{\text{volume} \times \text{concentration of NaOH} \times 100.09}{\text{weight of sample (gram)}}$$

4.5.3 pH value. For each sample of type I, type II, or type III EDTA to be tested (see 4.4.2.2), three 1-gram portions shall be tested in accordance with 4.5.2.2.2 and the pH value recorded.

4.6 Inspection of packaging. Sample packages and packs and the inspection of the preservation, packing and marking for shipment, stowage, and storage shall be in accordance with the requirements of section 5 and the documents specified therein.

Source: https://assist.dla.mil -- Downloaded: 20260-19T22:13Z
Check the source to verify that this is the current version before use.

5. PACKAGING

(The packaging requirements specified herein apply only for direct Government acquisition.)

5.1 General.

5.1.1 Navy fire-retardant requirements.

(a) Lumber and plywood. When specified (see 6.2), all lumber and plywood (including laminated veneer material used in shipping container construction members, blocking, bracing, and reinforcing) shall be fire-retardant treated material conforming to MIL-L-19140 as follows:

Levels A and B - Type II - weather resistant.
Category 1 - general use.
Level C - Type I - non-weather resistant.
Category 1 - general use.

(b) Fiberboard. When specified (see 6.2), fiberboard used in the construction of class-domestic, non-weather resistant fiberboard and cleated fiberboard boxes (including interior packaging forms) shall meet the flamespread and the specific optic density requirements in accordance with PPP-F-320.

5.2 Packaging requirements. The EDTA shall be preserved level A, or commercial, packed level A, B, or commercial as specified (see 6.2), and marked in accordance with PPP-C-2020 and 5.3. Packaging shall include bar coding and applicable packaging acquisition options therein as specified (see 6.2). The EDTA shall be furnished in 25-, 50-, or 100-pound quantities. Preservation for level A items shall be in fiber drums (type IV unit containers) in accordance with PPP-C-2020. Each drum shall be furnished with a flexible, plastic, waterproof, reclosable liner. The plastic liner shall not react chemically with, nor contribute impurities to the materials. Drums shall be palletized in accordance with PPP-C-2020. Shrink-film bonding in lieu of unit load strapping is acceptable.

5.3 Marking. In addition to any special marking required (see 6.2), fiber drums and palletized unit loads shall be marked for shipment in accordance with PPP-C-2020. Unit container markings shall include:

(a) Manufacturer's or contractor's name, or both.
(b) Lot number.
(c) Contract or order number.
(d) Date of manufacture (month and year).
(e) Precautionary labeling.
(f) Shelf life (expiration date of 48 months from date of manufacture: for example, manufactured 1/88, expires 1/92), including the following note:

"NOTE: Mandatory shelf life material. Discard material after expiration date."

Source: https://assist.dla.mil -- Downloaded: 2026-10-19T22:13Z
Check the source to verify that this is the current version before use.

5.3.1 Precautionary labeling. Each container shall be labeled with the following:

"WARNING: CAUSES IRRITATION

Avoid contact with eyes, skin, and clothing. Wash thoroughly after handling.

FIRST AID: In case of contact with eyes, immediately flush eyes with plenty of water for at least 15 minutes. Call a physician. Flush skin with water. (Wash clothing before reuse)."

5.4 Material safety data sheet. A copy of the material safety data sheet shall be attached to the shipping document for each destination (see 3.6).

6. NOTES

(This section contains information of a general or explanatory nature that may be helpful, but is not mandatory.)

6.1 Intended use. The type I EDTA covered by this specification is for cleaning boilers. The type II EDTA covered by this specification is for use in the treatment of boiler feedwater for marine boilers on Naval ships. The type III EDTA is for cleaning boilers.

6.2 Acquisition requirements. Acquisition documents should specify the following:

(a) Title, number, and date of this specification.
(b) Issue of DoDISS to be cited in the solicitation, and if required, the specific issue of individual documents referenced (see 2.1.1 and 2.2).
(c) When first article inspection if required (see 3.1).
(d) When fire-retardant requirements apply (see 5.1.1(a) and (b)).
(e) Level of preservation and packing required (see 5.2).
(f) Bar coding and applicable packaging acquisition options (see 5.2).
(g) Special marking required (see 5.3).

6.3 Data requirements. The following Data Item Descriptions (DIDs) must be listed, as applicable, on the Contract Data Requirements List (DD Form 1423) when this specification is applied on a contract, in order to obtain the data, except where DoD FAR Supplement 27.475-1 exempts the requirement for a DD Form 1423.

Reference paragraph	DID number	DID title	Suggested tailoring
4.3	DI-T-4902	First article inspection report	----
4.4	DI-T-5329	Inspection and test reports	----

Source: https://assist.dla.mil -- Downloaded: 2026-10-19T22:13Z
Check the source to verify that this is the current version before use.

The above DIDs were those cleared as of the date of this specification. The current issue of DoD 5010.12-L, Acquisition Management Systems and Data Requirements Control List (AMSDL), must be researched to ensure that only current, cleared DIDs are cited on the DD Form 1423.

6.4 First article. When first article inspection is required, the contracting officer should provide specific guidance to offerors whether the items should be a preproduction sample, a first article sample, a first production item, a sample selected from the first ___ production items, a standard production item from the contractor's current inventory (see 3.1), and the number of items to be tested as specified in 4.3. The contracting officer should also include specific instructions in acquisition documents regarding arrangements for examinations, approval of first article test results, and disposition of first articles. Invitations for bids should provide that the Government reserves the right to waive the requirement for samples for first article inspection to those bidders offering a product which has been previously acquired or tested by the Government, and that bidders offering such products, who wish to rely on such production or test, must furnish evidence with the bid that prior Government approval is presently appropriate for the pending contract. Bidders should not submit alternate bids unless specifically requested to do so in the solicitation.

6.5 Material safety data sheets (MSDS). Contracting officers must identify those activities requiring copies of MSDSs. Additional required Government information is contained in FED-STD-313. In order to obtain the MSDS, FAR clause 52.223-3 must be in the contract.

6.6 Subject term (key word) listing.

Chelation
Desiccator
Organic and inorganic impurities
Oxalate
Potentiometer titration
White granular powders

6.7 Changes from previous issue. Marginal notations are not used in this revision to identify changes with respect to the previous issue due to the extensiveness of the changes.

Preparing activity:
Navy - SH
(Project 6810-N012)

Source: https://assist.dla.mil -- Downloaded: 2026-10-19T22:13Z
Check the source to verify that this is the current version before use.

(TO DETACH THIS FORM, CUT ALONG THIS LINE.)

STANDARDIZATION DOCUMENT IMPROVEMENT PROPOSAL

(See Instructions – Reverse Side)

1. DOCUMENT NUMBER	2. DOCUMENT TITLE
MIL-T-24494B(SH)	TETRA-, TRI-, AND DISODIUM SALTS OF ETHYLENEDIAMINETETRAACETIC ACID (EDTA) WATER TREATMENT CHEMICALS, BOILER

3a. NAME OF SUBMITTING ORGANIZATION	4. TYPE OF ORGANIZATION *(Mark one)*
	☐ VENDOR
b. ADDRESS *(Street, City, State, ZIP Code)*	☐ USER
	☐ MANUFACTURER
	☐ OTHER *(Specify)*:

5. PROBLEM AREAS

a. Paragraph Number and Wording:

b. Recommended Wording:

c. Reason/Rationale for Recommendation:

6. REMARKS

7a. NAME OF SUBMITTER *(Last, First, MI)* – Optional	b. WORK TELEPHONE NUMBER *(Include Area Code)* – Optional
c. MAILING ADDRESS *(Street, City, State, ZIP Code)* – Optional	8. DATE OF SUBMISSION *(YYMMDD)*

DD FORM 82 MAR 1426 PREVIOUS EDITION IS OBSOLETE.

Source: https://assist.dla.mil -- Downloaded: 202610-19T22:13Z
Check the source to verify that this is the current version before use.

INSTRUCTIONS: In a continuing effort to make our standardization documents better, the DoD provides this form for use in submitting comments and suggestions for improvements. All users of military standardization documents are invited to provide suggestions. This form may be detached, folded along the lines indicated, taped along the loose edge *(DO NOT STAPLE)*, and mailed. In block 5, be as specific as possible about particular problem areas such as wording which required interpretation, was too rigid, restrictive, loose, ambiguous, or was incompatible, and give proposed wording changes which would alleviate the problems. Enter in block 6 any remarks not related to a specific paragraph of the document. If block 7 is filled out, an acknowledgement will be mailed to you within 30 days to let you know that your comments were received and are being considered.

NOTE: This form may not be used to request copies of documents, nor to request waivers, deviations, or clarification of specification requirements on current contracts. Comments submitted on this form do not constitute or imply authorization to waive any portion of the referenced document*(s)* or to amend contractual requirements.

(Fold along this line)

(Fold along this line)

DEPARTMENT OF THE NAVY

COMMANDER
NAVAL SEA SYSTEMS COMMAND (SEA 55Z3)
DEPARTMENT OF THE NAVY
WASHINGTON, DC 20362-5101

OFFICIAL BUSINESS
PENALTY FOR PRIVATE USE $300

BUSINESS REPLY MAIL
FIRST CLASS PERMIT NO. 12503 WASHINGTON D. C.
POSTAGE WILL BE PAID BY THE DEPARTMENT OF THE NAVY

COMMANDER
NAVAL SEA SYSTEMS COMMAND (SEA 55Z3)
DEPARTMENT OF THE NAVY
WASHINGTON, DC 20362-5101

NO POSTAGE
NECESSARY
IF MAILED
IN THE
UNITED STATES

Source: https://assist.dla.mil -- Downloaded: 2026-10-19T22:13Z
Check the source to verify that this is the current version before use.