[INCH-POUND]
A-A-59534
January 12, 2000

COMMERCIAL ITEM DESCRIPTION

RECLAIMER, REFRIGERANT

The General Services Administration has authorized the use of this commercial item description by all federal agencies.

1. SCOPE. This Commercial Item Description (CID) covers the general requirements for a portable refrigerant reclaimer (FR) recovery and recycling center. The FR will be used to recover and recycle refrigerants such as R-12, R-22, R-500 and F-502. The FR is frame mounted with casters, fan cooled electrically driven reciprocating compressor, and has its own oil separator.

2. SALIENT CHARACTRERISTICS.

2.1 Method of operation. The FR shall be capable of recovering and recycling refrigerant simultaneously. Recovery and recycling shall be completed in 10 to 15 minutes as compared to a minimum of 30 minutes using multi-pass systems. Automatic shutdown at the end of the operation shall be provided in order to minimize monitoring of the system. A single air and oil purge valve shall be provided for operation. A digital panel-mounted gauge shall conduct monitoring of the air conditioning system and tank pressure.

2.2 Dimensions and weight. The FR shall be within the following dimensional characteristics and weight limitations:

a. Length: maximum 18 inches

b. Width: maximum 16 inches

c. Height: maximum 45 inches.

d. Weight: maximum 120 pounds.

Beneficial comments, recommendations, additions, deletions, clarifications, etc. and any data which may improve this document should be sent to: The Technology & Industrial Services Division, SA-ALC/TILDD, 485 Quentin Roosevelt Rd., Kelly AFB, TX 78241-6425.

AMSC N/A FSC 4250

Source: https://assist.dla.mil -- Downloaded: 202640-26T10:17Z
Check the source to verify that this is the currentversion before use.

2.3 Multiple refrigerant. The FR shall be capable of recovering and resettling R-12, R-22, R-500 and R-502 using only one unit.

2.4 Tank. The FR shall be provided with a size of tank having the refrigerant capacity 50 pounds. This tank shall meet the Department of Transportation (DOT) specifications.

2.5 Filter(s). The FR filters shall be of the replacable core style for ease of maintainance.

2.6 Liquid level sensor. The FR shall have the ability of determining when the refrigerant tank is at full capacity condition. When detecting this full condition indicator light(s) shall illuminate and the FR shall automatically shutdown.

2.7 Noise. The FR noise level during any operating condition shall be maximum 90 dbA slow scale. This level shall be measured at a maximum three feet from the perimeter of the FR.

2.8 Electrical power requirements. The FR shall be capable of operation from a 110V, 5 amps, 50/60 Hz, and 1 phase source.

2.9 Maintainability. The manufacturer of the FR shall make available parts to provide basic purifier maintenance. Parts requiring routine replacement shall be accessible by maintenance personnel without disassembling the FR.

2.10 Spare parts. Each FR shall be provided with the following minimum of additional components: one 50 lb. refillable tank, five filter cores, and one oil measuring cup. If more than the quantity of these components are required, this quantity shall be identified in 6.1. A storage compartment for the spare parts shall be provided within the FR cabinet.

2.11 Data plate. A corrosion resistant data plate shall be permanently installed on a control panel, or another visible protected location. The following information shall be on the plate:

a. National stock number:

b. Contract number:

c. Serial number:

d. Model number:

e. Manufactured by:

f. Name:

g. Address:

h. Commercial and Government Entity (CAGE) Code:

i. Part Identifying Number (PIN): AA59534

Source: https://assist.dla.mil -- Downloaded: 202610-26T10:17Z
Check the source to verify that this is the currentversion before use.

3. REGULATORY REQUIREMENTS.

3.1 Materials. The offeror/contractor is encouraged to use recovered materials to the maximum extent possible, in accordance with paragraph 23.403 of the Federal Acquisition Regulation (FAR).

3.1.1 Recovered materials. For the purpose of this requirement, recovered materials are those materials that have been collected from solid waste and reprocessed to become a source of raw materials, as distinguished from raw materials. The components, pieces and parts incorporated in the FR may be newly fabricated from recovered materials to the maximum extent practical, provided the FR produced meets all other requirements of this specification. Used, rebuilt or re-manufactured components, pieces and parts shall not be incorporated.

4. QUALITY ASSURANCE PROVISIONS.

4.1 Product Conformance. The products provided shall meet the salient characteristics of this commercial item description, conform to the producer's own drawings, specifications, standards, and quality assurance practices, and be the same product offered for sale in the commercial market. The government reserves the right to require proof of such conformance.

4.2 Market acceptability. The product offered must have been sold to the government or commercial market. The contractor shall furnish the following information:

a. The length of time the product has been on the market

b. The last four contracting sources of the product provided.

c. The number of products provided for each contract.

d. The reliability and performance of the product offered.

4.3 Bid samples. The Government will request bid samples for the FR being considered. The contractor shall furnish continuous maintenance support (parts and labor) during the evaluation timeframe of 14 to 30 days. All FRs evaluations shall be in compliance with this document and FRs not in compliance with the salient characteristics shall be cause of rejection. Bid samples for evaluation shall be shipped to the address identified (see 6.1).

5. PACKAGING. Preservation, packaging, labeling, and marking shall be as specified in the contract or order.

6. NOTES.

6.1 Ordering Data. Procurement documents shall specify the following:

a. CID Title, Number, and Date of this CID

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T10:17Z
Check the source to verify that this is the current version before use.

b. Quantity of spare parts, if additional (see 2.10).

c. Bid Samples review activity address (see 4.3)

d. Packaging requirements (see 5.).

6.2 PIN. The following part identification numbering procedure is for governmnet purpose and does not consitute a requirement for the contractor. This part number is for all items procurred to CID A-A-59534 will be AA59534.

Military Interest:

Custodian:
Air Force - 99
Army - AT
DLA - IS
Navy - AS

Civil Agency
Coordinating Activity:

GSA – FSS

Preparing Activity:
Air Force - 82

Agent :
Air Force - 99

Project 4940-0756

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T10:17Z
Check the source to verify that this is the current version before use.