INCH-POUND
A-A-59534A
February 26, 2019
SUPERSEDING
A-A-59534
January 12, 2000

COMMERCIAL ITEM DESCRIPTION

RECLAIMER, REFRIGERANT

The General Services Administration has authorized the use of this Commercial Item Description (CID) for all federal agencies.

1. SCOPE

1.1 Scope. This CID covers the general requirements for a portable refrigerant reclaimer (FR) recovery and recycling center. The FR will be used to recover and recycle refrigerants such as R-12, R-22, R-500, R-502 or eco-friendly approved replacements. The FR is frame mounted with casters, a fan cooled electrically driven reciprocating compressor, and has its own oil separator.

2. SALIENT CHARACTERISTICS

2.1 Method of operation. The FR shall be cable of recovering and recycling refrigerant simultaneously. Recovery and recycling shall be completed in 10 to 15 minutes as compared to a minimum of 30 minutes using multi-pass systems. Automatic shutdown at the end of the operation shall be provided in order to minimize monitoring of the system. A single air and oil purge valve shall be provided for operation. A digital panel-mounted gauge shall conduct monitoring of the air conditioning system and tank pressure.

2.2 Dimensions and weight. The FR shall be within the following dimensional characteristics and weight limitations:

Length	18 inches maximum.
Width	16 inches maximum
Height	45 inches maximum
Weight	120 pounds maximum

Comments, suggestions, or questions on this document should be addressed to: U.S. AIR FORCE - 404th SCMS/GUEAB - 235 Byron Street, Suite 19A, Robins AFB, GA 31098-1813 or email to SPEC99@us.af.mil . Since contact information can change, you may want to verify the currency of this address information using the ASSIST Online database at https://assist.dla.mil .

AMSC N/A FSC 4250

DISTRIBUTION STATEMENT A. Approved for public release. Distribution is unlimited.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T10:17Z
Check the source to verify that this is the current version before use.

2.3 Multiple refrigerant. The FR shall be capable of recovering and resetting R-12, R-22, R-500, R-502 or those Environmental Protection Agency (EPA) regulated refrigerants meeting the standards specified in Title 40 of the Code of Federal Regulations (40CFR); Appendix A to Subpart F of Part 82, Specification for Refrigerants, using only one unit.

2.4 Tank. The FR shall be provided with a tank size that has a refrigerant capacity of 50 pounds. The tank shall meet the Department of Transportation (DOT) specification 4BA as specified in Title 49 of the Code of Federal Regulations (49CFR); Subpart C of Part 82, Specification for Cylinders.

2.5 Filer(s). The FR filters shall be of the replaceable core style for ease of maintenance.

2.6 Liquid level sensor. The FR shall have the ability of determining when the refrigerant tank is at full capacity condition. When detecting this full condition, indicator light(s) illuminate and the FR shall automatically shut-down.

2.7 Noise. The FR noise level during any operating condition shall be maximum 90 dbA slow scale. This level shall be measured at a maximum three feet from the perimeter of the FR.

2.8 Electrical power requirements. The FR shall be capable of operation from a 110V, 5 amps, 50/60 Hz, and 1 phase source.

2.9 Maintainability. The manufacturer of the FR shall make available parts to provide basic purifier maintenance. Parts requiring routine replacement shall be accessible by maintenance personnel without disassembling the FR.

2.10 Spare parts. Each FR shall be provided with the following minimum of additional components: one 50 lb. refillable tank, five filter cores, and one oil measuring cup. If more than the quantity of these components are required, this quantity shall be identified in 6.3. A storage compartment for the spare parts shall be provided within the FR cabinet. The storage compartment shall hold the spare parts in a secure, damage free manner.

2.11 Data plate. A corrosion resistant data plate shall be permanently installed on a control panel, or another visible protected location. The following information shall be on the plate:

a. National stock number:

b. Contract number:

c. Serial number:

d. Model number:

e. Manufactured by:

f. Name:

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T10:17Z
Check the source to verify that this is the current version before use.

g. Address:

h. Commercial and Government entity (CAGE) code:

i. Part Identifying Number (PIN): (see 6.1)

3. REGULATORY REQUIREMENTS

3.1 Materials. The offer/contractor is encouraged to use recovered materials to the maximum extent possible, in accordance with paragraph 23.403 of the Federal Acquisition Regulation (FAR).

3.1.1 Recovered materials. For the purpose requirement, recovered materials are those materials that have been collected from solid waste and reprocessed to become a source of raw materials, as distinguished from raw materials. The components, pieces and parts incorporated in the FR may be newly fabricated from recovered materials to the maximum extent practical, provided the FR produced meets all other requirements of this CID. Used, rebuilt or remanufactured components, pieces and parts shall not be incorporated.

3.2 Green Procurement Program. Green Procurement Program (GPP) is a mandatory federal acquisition program that focuses on the purchase and use of environmentally preferable products and services. GPP requirements apply to all acquisitions using appropriated funds, including services and new requirements. FAR 23.404(b) applies and states the GPP requires 100% of EPA designated product purchase that are included in the Comprehensive Procurement Guidelines list that contains recovered materials, unless the item cannot be acquired: a) competitively within a reasonable timeframe; b) meet appropriate performance standards, or c) at a reasonable price. The prime contractor is responsible for ensuring that all subcontractors comply with this requirement.

4. PRODUCT CONFORMANCE PROVISIONS

4.1 Product Conformance. The products provided shall meet the salient characteristics of this CID, conform to the producer's own drawings, specifications, standards, and quality assurance practices, and be the same product offered for sale in the commercial marketplace, modified as necessary to comply with the requirements herein. The Government reserves the right to require proof of such conformance.

4.2 Market acceptability. The product offered must have been sold to the government or commercial market. The contractor shall furnish the following information:

a. The length of time the product has been on the market.

b. The last four contracting sources of the product provided.

c. The number of products provided for each contract.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T10:17Z
Check the source to verify that this is the current version before use.

d. The reliability and performance of the product offered.


4.3 Bid samples. The Government will request bid samples for the FR being considered. The contractor shall furnish continuous maintenance support (parts and labor) during the evaluation timeframe of 14 to 30 days to the Procuring Activity. All FR's evaluations shall be in compliance with this document and FR's not in compliance with the salient characteristics shall be cause for rejection.

5. PACKAGING

5.1 Packaging. Preservation, packing, and marking shall be as specified in the contract or order.

6. NOTES

6.1 Part or Identifying Number (PIN). The following part identification numbering procedure is for government purposes and does not constitute a requirement for the contractor. The PIN to be used for items acquired to this CID is created as follows:



6.2 Source of documents.

6.2.1 Code of Federal Regulations (CFR). CFR regulations are available online at https://www.ecfr.gov/ or from the Superintendent of Documents; U.S. Government Printing Office, Washington, DC, 20402.

6.2.2 Federal Acquisition Regulations (FAR). FAR references are available online at https://www.acquisition.gov/ or obtained from the Superintendent of Documents, P.O. Box 371954, Pittsburgh PA 15250-7954.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T10:17Z
Check the source to verify that this is the current version before use.

6.3 Ordering data. Acquisition documents should specify the following:

a. Title, number, and date of this CID.

b. Quantity of spare parts, if additional (see 2.10).

c. Bid samples review activity address (see 4.3).

d. Packaging requirements (see 5.1).

6.4 National Stock Number (NSN). The following is a list of NSNs assigned that correspond to this CID. The list may not be indicative of all possible NSNs associated with this CID.

NSN
4250-01-339-2199
4250-01-411-7240
4250-01-501-5276

6.5 Key words.

Portable refrigerant reclaimer
Purity level
Recovered refrigerant
Recycled refrigerant
Refrigerant reclaimer (FR)

6.6 Changes from previous issue. The margins of this CID are marked with vertical lines to indicate where changes from the previous issue were made. This was done as a convenience only and the Government assumes no liability whatsoever for any inaccuracies in these notations. Bidders and contractors are cautioned to evaluate the requirements of this CID based on the entire content irrespective of the marginal notations and relationship to the previous issue.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T10:17Z
Check the source to verify that this is the current version before use.

Concluding Material:

Custodians:
Army - AT
Navy - AS
Air Force - 84
DLA – GS-3

Reviewer:
DLA - CQ
GSA – FAS

Preparing Activity:
Air Force – 84

Agent:
Air Force – 99
(Project 4250-2018-001)

NOTE: The activities listed above were interested in this document as of the date of this document. Since organizations and responsibilities can change, you should verify the currency of the information above using the ASSIST Online database at https://assist.dla.mil/.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T10:17Z
Check the source to verify that this is the current version before use.