WW-C-571b
JUNE 5, 1962
SUPERSEDING
Fed. Spec. WW–C–571a
September 1, 1954

FEDERAL SPECIFICATION

CONDUIT, METAL, RIGID; AND COUPLING, ELBOW, AND NIPPLE, ELECTRICAL CONDUIT: ENAMELED

This specification was approved by the Commissioner, Federal Supply Service, General Services Administration, for the use of all Federal Agencies.

1. SCOPE AND CLASSIFICATION

1.1 Scope. This specification covers steel electrical conduit, couplings, elbows, and nipples having enameled interior and exterior surfaces.

1.2 Classification.

1.2.1 *Sizes.* Conduit, couplings, elbows, and nipples shall be of the following nominal or trade sizes in inches, as specified (see 6.2):

¼	¾	1-½	3	5
⅜	1	2	3-½	6
½	1-¼	2-½	4	

2. APPLICABLE SPECIFICATIONS, STANDARDS, AND OTHER PUBLICATIONS

2.1 Specifications and standards. The following specifications and standards, of the issues in effect on date of invitation for bids, form a part of this specification:

Federal Specifications:

PPP–B–601—Boxes, Wood, Cleated-Plywood.

PPP–B–621—Boxes, Wood, Nailed and Lock-Corner.

PPP–B–636—Box, Fiberboard.

Federal Standards:

Fed. Std. No. 102—Preservation, Packaging and Packing Levels.

Fed. Std. No. 123—Marking For Domestic Shipment (Civilian Agencies).

(Activities outside the Federal Government may obtain copies of Federal Specifications, Standards, and Handbooks as outlined under General Information in the Index of Federal Specifications, Standards, and Handbooks and at the prices indicated in the Index. The Index, which includes cumulative monthly supplements as issued, is for sale on a subscription basis by the Superintendent of Documents, U. S. Government Printing Office, Washington 25, D. C.

(Single copies of this specification and other product specifications required by activities outside the Federal Government for bidding purposes are available without charge at the General Services Administration Regional Offices in Boston, New York, Washington, D. C., Atlanta, Chicago, Kansas City, Mo., Dallas, Denver, San Francisco, and Auburn, Wash.

(Federal Government activities may obtain copies of Federal Specifications, Standards, and Handbooks and the Index of Federal Specifications, Standards, and Handbooks from established distribution points in their agencies.)

Military Specification:

MIL–P–116—Preservation, Methods of

Military Standards:

MIL–STD–105—Sampling Procedures

FSC 5975

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T12:23Z
Check the source to verify that this is the current version before use.

and Tables for Inspection by Attributes.

MIL-STD-129—Marking for Shipment and Storage.

MIL-STD-163—Steel Mill Products, Preparation for Shipment and Storage.

(Copies of Military Specifications and Standards required by contractors in connection with specific procurement functions should be obtained from the procuring activity or as directed by the contracting officer.)

2.2 Other publications. The following publications form a part of this specification to the extent specified herein. Unless otherwise indicated the issue in effect on date of invitation for bids shall apply:

American Standards Association, Inc. Standard:

C80.2—Rigid Steel Conduit, Enameled.

(Application for copies should be addressed to American Standards Association, Inc., 10 East 40th Street, New York 16, New York).

Underwriters' Laboratories, Inc., Publication:

UL-6—Standard for Rigid Metallic Conduit.

(Application for copies should be addressed to Underwriters' Laboratories, Inc., 161 Sixth Avenue, New York 13, New York; 207 East Ohio Street, Chicago 11, Illinois; or 1655 Scott Blvd., Santa Clara, California.)

3. REQUIREMENTS

3.1 General. All material shall be new, suitable for the purpose intended, and shall be free of any defects that affect the appearance or impair the serviceability of the product.

3.2 Detail. Conduit, couplings, elbows, and nipples furnished under this specification shall conform to American Standards Association Inc., (ASA) Standard C80.2.

3.3 Fire and casualty hazards.

3.3.1 Each bidder shall submit to the contracting agency proof that the items he proposes to supply under this specification conform to the applicable requirements of Underwriters' Laboratories Inc., Standard UL-6 for Rigid Metallic Conduit. The label or listing of the Underwriters' Laboratories, Inc., may be accepted as evidence that the items conform to these requirements.

3.3.2 In lieu of the label or listing, the bidder may submit independent proof satisfactory to the contracting agency that the items conform to the published standards, including methods of test, of Standard UL-6 for Rigid Metallic Conduit.

3.3.3 Compliance with the above preliminary requirements in regard to fire and casualty hazards does not absolve the bidder from complete compliance with the requirements of this specification in order to secure acceptance of his material.

4. SAMPLING, INSPECTION, AND TEST PROCEDURES

4.1 The supplier is responsible for the performance of all inspection requirements as specified herein. Except as otherwise specified, the supplier may utilize his own or any other inspection facilities and services acceptable to the Government. Inspection records of the examination and tests shall be kept complete and available to the Government as specified in the contract or order. The Government reserves the right to perform any of the inspections set forth in the specification where such inspections are deemed necessary to assure that supplies and services conform to prescribed requirements.

4.2 Classification of inspection. Inspection shall be classified as follows:

(*a*) Production inspection of the conduit, couplings, elbows, and nipples.

(*b*) Inspection of preparation for delivery.

4.3 Production inspection.

4.3.1 *Sampling.* Sampling for examination and tests shall be in accordance with MIL-STD-105.

4.3.2 *Examination.* Samples selected in accordance with 4.3.1 shall be examined in

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T12:23Z
Check the source to verify that this is the current version before use.

accordance with ASA C80.2. AQL shall be 4 percent defective.

4.3.3 *Tests.* Samples selected in accordance with 4.3.1 shall be tested in accordance with ASA C80.2. AQL shall be 4 percent defective. Any sample failing to pass one or more tests shall be considered defective.

4.4 Inspection of preparation for delivery. The preservation, packaging, packing, and marking shall be examined to determine compliance with section 5 of this specification.

5. PREPARATION FOR DELIVERY

(The levels of preservation, packaging and packing used are defined in Fed. Std. No. 102).

5.1 Preservation and packaging. Preservation and packaging shall be level A or C, as specified (see 6.2)

5.1.1 *Level A.*

5.1.1.1 *Conduit.* The conduit shall be packaged in accordance with MIL–STD–163, level A.

5.1.1.2 *Couplings, elbows, and nipples.* The couplings, elbows, and nipples shall be preserved and packaged in accordance with MIL–P–116, method III.

5.1.2 *Level C.*

5.1.2.1 *Conduit.* The conduit shall be preserved and packaged in accordance with MIL–STD–163, level C.

5.1.2.2 *Couplings, elbows, and nipples.* The couplings, elbows, and nipples shall be preserved and packaged to afford protection against deterioration and damage.

5.2 Packing. Packing shall be level A, B, or C as specified (see 6.2).

5.2.1 *Level A.*

5.2.1.1 *Conduit.* The conduit shall be packed in accordance with MIL–STD–163, level A.

5.2.1.2 *Couplings, elbows, and nipples.* The couplings, elbows, and nipples of like description shall be packed in close-fitting boxes conforming to PPP–B–621, class 2, style optional; or in boxes conforming to PPP–B–601, overseas type, style optional. The boxes shall be close-fitting and strapping shall be zinc coated. The gross weight of each box shall not exceed 200 pounds.

5.2.2 *Level B.*

5.2.2.1 *Conduit.* The conduit shall be packed as specified in 5.2.1.1.

5.2.2.2 *Couplings, elbows, and nipples.* The couplings, elbows, and nipples of like description shall be packed as specified in 5.2.1.2 except that the boxes shall be domestic type, style, and class, or the fittings shall be packed in boxes conforming to PPP–B–636, type I, class 1, style optional.

5.2.3 *Level C.*

5.2.3.1 *Conduit.* The conduit shall be packed in accordance with MIL–STD–163, level C.

5.2.3.2 *Couplings, elbows, and nipples.* The couplings, elbows, and nipples shall be packed in substantial commercial containers of the type, size, and kind commonly used for the purpose, so constructed as to insure acceptance and safe delivery by common or other carriers, at the lowest rate, to point of delivery called for in the contract or purchase order.

5.3 Marking.

5.3.1 *Civil agencies.* Marking for civil agencies shall be in accordance with Fed. Std. No. 123.

5.3.2 *Military agencies.* Marking for military agencies shall be in accordance with MIL–STD–129.

6. NOTES

6.1 Intended use. The conduit, couplings, elbows, and nipples are intended for use as a raceway for the wires or cables of an electrical system.

6.2 Purchasers should exercise any desired options offered herein, and procurement documents should specify the following:

(*a*) Title, number, and date of this specification.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T12:23Z
Check the source to verify that this is the current version before use.

(*b*) Size of conduit, couplings, elbows, and nipples (see 1.2).
(*c*) Administrative provisions for inspection records (see 4.1).
(*d*) Level of preservation and packaging and level of packing required (see 5.1 and 5.2).
(*e*) Whether civil or military marking is required (see 5.3.1 and 5.3.2).

6.3 Items procured under this specification for military use are to be limited to the variety shown on the applicable military standards for "Bends, Electrical Conduit". Personnel of the military departments are requested to refer to these documents for guidance.

6.4 Transportation description. Transportation description and minimum weights applicable to this commodity are:

Conduit

Rail: Pipe, conduit, steel.
Carload minimum weight 40,000 pounds.

Motor: Pipe, conduit, steel.
Motor volume minimum weight 40,000 pounds.

Couplings

Rail: Conduit couplings, cast iron without attachments.
Carload minimum weight 40,000 pounds.

Motor: Couplings, conduit, cast iron, inside diameter not less than 2 inches without attachments.
Truckload minimum weight (W) 36.6 pounds, (W) subject to Rule 34, National Motor Freight Classification.

Elbows and Nipples

Rail: Conduit elbows and nipples, not otherwise indexed by name, iron, without attachments.
Carload minimum weight 40,000 pounds.

Motor: Conduit elbows and nipples, not otherwise indexed, iron, without attachments.
Motor volume minimum weight 40,000 pounds.

Notice. When Government drawings, specifications, or other data are used for any purpose other than in connection with a definitely related Government procurement operation, the United States Government thereby incurs no responsibility nor any obligation whatsoever; and the fact that the Government may have formulated, furnished, or in any way supplied the said drawings, specifications, or other data is not to be regarded by implication or otherwise as in any manner licensing the holder or any other person or corporation, or conveying any rights or permission to manufacture, use, or sell any patented invention that may in any way be related thereto.

MILITARY INTEREST:
Army—E
Navy—YSMC
Air Force—ROM

Copies of this specification may be purchased for 5 cents each.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T12:23Z
Check the source to verify that this is the current version before use.