WW-C-581
CANCELLATION
August 17, 1984

FEDERAL SPECIFICATION

CONDUIT, METAL, RIGID, AND INTERMEDIATE; AND COUPLING, ELBOW, AND NIPPLE, ELECTRICAL CONDUIT: STEEL, ZINC COATED

This cancellation is approved by the Assistant Administrator, Office of Federal Supply and Services, General Services Administration.

Federal Specification WW-C-581E, dated April 6, 1977, has been superseded as follows:

Class 1. Type A - Underwriters Laboratories Inc., (UL) Standard 6 - Rigid Metal Electrical Conduit.

Class 2. Type A - UL Standard 1242 - Intermediate Metal Conduit.

Classes 1 and 2, Types B, C, and D - UL Standard 514B - Fittings for Conduit and Outlet Boxes.

UL Standards 6, 514B, and 1242 have been adopted for their use by DoD and GSA, FSS.

FSC 5975

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T12:23Z
Check the source to verify that this is the current version before use.