WW-D-1908A
January 9, 1978
SUPERSEDING
Int. Fed. Spec. WW-D-001908 (GSA-FSS)
June 11, 1975 and
Fed. Spec. WW-P-541/8
(In Part) October 12, 1971

FEDERAL SPECIFICATION

DISPENSER, TOILET PAPER, CABINET

This specification was approved by the Commissioner, Federal Supply Service, General Services Administration, for the use of all Federal agencies.

1. SCOPE AND CLASSIFICATION

1.1 Scope. This specification covers the requirements for toilet paper dispenser cabinets.

1.2 Classification.

1.2.1 Types. Toilet paper dispensers furnished under this specification shall be of the following types (see 6.2):

Type I - Folded sheets of tissue.
II - 2 rolls of tissue, vertical mount.
III - 2 rolls of tissue, vertical mount, recessed cabinet.
IV - 3 rolls of tissue, vertical mount.

2. APPLICABLE DOCUMENTS

2.1 The following documents, of the issues in effect on date of invitation for bids or request for proposal, form a part of this specification to the extent specified herein.

Federal Specification:

UU-P-556 - Paper, Toilet Tissue.

Federal Standard:

Fed. Std. No. 123 - Marking for Shipment (Civil Agencies).

(Activities outside the Federal Government may obtain copies of Federal Specifications, Standards, and Handbooks as outlined under General Information in the Index of Federal Specifications and Standards and at the prices indicated in the Index. The Index, which includes cumulative monthly supplements as issued, is for sale on a subscription basis by the Superintendent of Documents, U.S. Government Printing Office, Washington, DC 20402.

(Single copies of this specification and other Federal Specifications required by activities outside the Federal Government for bidding purposes are available without charge from Business Service Centers at the General Services Administration Regional Offices in Boston, New York, Philadelphia, Washington, DC, Atlanta, Chicago, Kansas City, MO, Fort Worth, Houston, Denver, San Francisco, Los Angeles, and Seattle, WA.

(Federal Government activities may obtain copies of Federal Specifications, Standards, and Handbooks and the Index of Federal Specifications and Standards from established distribution points in their agencies.)

FSC 4510

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T12:24Z
Check the source to verify that this is the current version before use.

Military Standard:

MIL-STD-105 - Sampling Procedures and Tables for Inspection by Attributes.

(Copies of Military Specifications and Standards required by contractors in connection with specific procurement functions should be obtained from the procuring activity or as directed by the contracting officer.)

2.2 Other publications. The following documents form a part of this specification to the extent specified herein. Unless a specific issue is identified, the issue in effect on date of invitation for bids or request for proposal shall apply.

National Motor Freight Traffic Association, Inc., Agent:

National Motor Freight Classification.

(Application for copies should be addressed to the American Trucking Associations, Inc., Traffic Department, 1616 P Street, N.W., Washington, DC 20036.)

Uniform Classification Committee, Agent:

Uniform Freight Classification.

(Application for copies should be addressed to the Uniform Classification Committee, Room 1106, 222 South Riverside Plaza, Chicago, IL 60606.)

3. REQUIREMENTS

3.1 Materials. Materials shall conform to the requirements specified herein. Materials not specified shall be of the type and quality recognized by industry for the intended purpose.

3.2 Standard commercial product. Toilet paper dispensers covered by this specification shall, as a minimum, be in accordance with the requirements of this specification and shall be the manufacturer's current standard commercial product.

3.3 Construction.

3.3.1 Lock. Cabinets shall be lock type. The cabinet closure panel shall lock automatically upon closing.

3.3.2 Mounting. Dispensers shall be for vertical mounting.

3.3.3 Fastener holes.

3.3.3.1 Type I dispensers shall have a minimum of (1) 2 holes, (2) 2 slots, or (3) 1 hole and 1 slot in the back. Size of holes and width of slots shall be 3/16 inch minimum.

3.3.3.2 Type II, III, and IV cabinets shall have holes or slots located at each corner. Size of holes and width of slots shall be 3/16 inch minimum.

3.3.4 Type I dispensers. Type I dispenser cabinets shall be of carbon or stainless steel. The cabinet shall hold 800 to 1000 sheets of tissue conforming to type II, double fold, of UU-P-556. The cabinet shall have a bottom dispensing slot and an indicator or slot to disclose the supply. When filled to capacity and less than full capacity, folded tissues shall dispense one at a time (see 4.4.1).

3.3.5 Roller mechanism, types II, III, and IV. The roller mechanism for types II, III, and IV dispensers shall accomodate 1000-single sheet rolls of toilet tissue conforming to type I of UU-P-556. The roller mechanism shall prevent the stored roll(s) of tissue from interfering with the dispensing of the exposed roll of tissue. The mechanism shall be designed to prevent tripping the next roll of tissue until

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T12:24Z
Check the source to verify that this is the current version before use.

the roll being dispensed has 5 percent or less of the roll remaining. The mechanism shall drop the spare roll automatically or have a roll release operating bar or button on the cabinet to trip the mechanism allowing the stored roll or tissue to drop into the dispensing position. The empty roller(s) or mandrel(s) shall not interfere with the proper dispensing of the second roll when it is in the dispensing position. Any movable rollers or mandrels shall remain locked in the cabinet until the cabinet is unlocked. Rollers shall be metallic or plastic. Metal rollers shall have an inorganic corrosion-resistant treatment as required. The roller mechanism shall restrict the roll being dispensed from free spinning (see 4.4.2).

3.3.6 Type II cabinets. Unless otherwise specified (see 6.2), type II cabinets shall be of carbon steel, stainless steel or a combination of carbon or stainless steel and plastic at the manufacturer's option. The cabinet shall house 2 1000-sheet rolls of toilet tissue placed vertically.

3.3.7 Type III. Type III cabinets shall be of carbon steel or stainless steel as specified (see 6.2). Cabinets shall house 2 1000-sheet rolls of toilet tissue placed vertically. The cabinet shall be for recess mounting. Wall flanges shall be so located on the cabinet as to allow a recess depth not greater than 3 inches. The width of wall flanges shall be not less than 5/8 inch.

3.3.8 Type IV cabinet. Type IV cabinets shall be of stainless steel or a combination of stainless steel and plastic. Cabinets of combined stainless steel and plastic shall have stainless steel inserts on the front panel exposing a plastic border. The plastic border shall not be greater than 1/2 inch around edges and openings. The cabinet shall house 3 1000-sheet rolls of toilet tissue.

3.4 Spare roll(s) storage, types II, III, and IV. Dispenser cabinets shall conceal stored roll(s) of toilet paper when viewed in accordance with 4.3.3.

3.5 Furnished items. Each cabinet shall be furnished with plated or stainless steel fasteners for each fastening hole and a lock key.

3.6 Finish.

3.6.1 Carbon steel and plastic.

3.6.1.1 Exterior surfaces. Unless otherwise specified herein, exterior surfaces of the cabinet shall be bright chromium plated. The plating shall be uniform in appearance and shall be free of cracks, blisters and void areas when examined as specified in 4.3.2.

3.6.1.2 Interior surfaces. Interior metallic surfaces shall be chromium plated, bright zinc plated, or baked on enamel at the manufacturer's option. Unless otherwise specified, interior plastic surfaces shall be as molded. When specified (see 6.2), interior plastic surfaces shall be chromium plated.

3.6.2 Stainless steel. Stainless steel surfaces shall be finished in accordance with the manufacturer's current commercial practice.

3.7 Marking. Each dispenser cabinet shall be clearly marked with the manufacturer's readily identifiable name or registered trademark. The method of marking shall be by embossing, stamping, or decalcomania.

3.8 Workmanship. All dispenser cabinets shall be free of cracks dents, sharp corners and edges. All plated surfaces shall be uniform in application and free of visible voids.

4. QUALITY ASSURANCE PROVISIONS

4.1 Responsibility for inspection. Unless otherwise specified in the contract or purchase order, the contractor is responsible for the performance of all inspection requirements as specified herein. Except as otherwise specified in the contract or order, the contractor may use his own or any other facilities suitable for the performance of the inspection requirements specified herein, unless disapproved by the Government.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T12:24Z
Check the source to verify that this is the current version before use.

4.2 Sampling for examination and tests. Select sample size for examination in accordance with level S-4 in MIL-STD-105. Select sample size for tests in accordance with level S-2 in MIL-STD-105.

4.3 Examination and tests.

4.3.1 Examination. Samples selected in accordance with 4.2 shall be examined for defects listed in table I. The Acceptable Quality Levels (AQL's) for defects shall be 2.5 percent defective for major defects and 6.5 percent defective for total defects.

4.3.2 Examination of chromium plating. Examine chromium plating on dispensers with the eyes of the observer 15 to 18 inches from the dispenser. The light source shall be a 100 watt lamp placed a maximum of three feet from the surface being examined. The examination shall be conducted without the use of optical aids except for those required for corrective vision.

4.3.3 Examine types II, III, and IV dispensers for concealment of stored roll(s) of toilet paper in the following manner. Mount cabinet on a vertical surface. With eyes level with top of cabinet, view cabinet at a distance of 10 feet for conformance to 3.4.

TABLE I. Classification of defects, end item

	Major	Minor
Type not as specified	X	
Material not as specified	X	
Cabinets not complete or parts missing except for fasteners.	X	
Keys for dispensers not included.		X
Flange width of recessed cabinets not as specified.	X	
Surface finish not as specified.	X	
Finishes not uniform in appearance.		X
Cracks, blisters, or void areas in chromium plating	X	
Cracks in metal	X	
Marking not as specified		X
Damage or defects affecting function or serviceability	X	
Damage or defects not affecting function or serviceability		X

4.3.4 Test. Test samples selected in accordance with 4.2 as specified in 4.4. The AQL for tests shall be 2.5 percent defective.

4.4 Test methods.

4.4.1 Type I. Fill dispenser and remove 10 tissues in sequence (see 3.3.4).

4.4.2 Types II, III, and IV. Load type II, III, and IV dispensers with 2 rolls of toiles tissue. Remove tissue from the exposed roll and observe for conformance to 3.3.5. For the purpose of this test, the exposed roll need not be a full roll.

4.5 Inspection of preparation for delivery. An inspection shall be made to determine whether the packaging, packing, and marking comply with the requirements in section 5 of this specification. Defects shall be scored in accordance with table II. For examination of interior packaging, the sample unit shall be one shipping container fully prepared for delivery, selected at random, just prior to the closing operations. Sampling shall be in accordance with MIL-STD-105. Defects of closure listed shall be examined on shipping containers fully prepared for delivery. The lot size shall be the number of shipping containers in the end item inspection lot. The inspection level shall be S-2 with an AQL of 4.0 defects per hundred units.

Source: https://assist.dla.mil -- Downloaded: 202640-26T12:24Z
Check the source to verify that this is the currentversion before use.

TABLE II. Classification of preparation for delivery defects.

Example	Defects
Markings	Omitted; incorrect; illegible; improper size, location, sequence or method of application.
Material	Any component missing, damaged or not conforming to the applicable specification or requirements stated herein.
Workmanship	Inadequate application of components such as incomplete closure of container flaps, loose strapping, inadequate stapling, or distortion of container.
Contents	Quantity per container is more or less than required. Gross weight exceeds requirements of the box specification.

5. PREPARATION FOR DELIVERY

5.1 Packaging. Packaging shall be level A or commercial, as specified (see 6.2).

5.1.1 Level A. Each dispenser shall be packaged in a close-fitting paperboard or fiberboard box. The box shall be secured to prevent accidental opening.

5.1.2 Commercial. Each dispenser shall be packaged in accordance with normal commercial practice. The complete package shall be designed to protect the item against damage during shipment, handling and storage.

5.2 Packing. Packing shall be level A or commercial, as specified (see 6.2).

5.2.1 Level A. Six dispensers, packaged as specified in 5.1.1 shall be packed in boxes made from weather resistant fiberboard having a bursting strength of not less than 275 pounds per square inch. The box flaps shall be secured with water resistant adhesive applied to the entire area of contact between the flaps or with 3-inch wide water resistant tape applied to the full length of the center seams and extending over the ends not less than 3 inches. Alternatively, cleated plywood, wirebound, or nailed wood boxes shall be acceptable shipping containers when lined with a waterproof barrier material. The edges of the barrier material shall be sealed with waterproof tape or adhesive.

5.2.2 Commercial. Dispensers, packaged as specified in 5.1.2, shall be packed in fiberboard boxes to insure safe delivery at destination, to provide for safe redistribution by the initial receiving activity and shall be acceptable by common carrier under National Motor Freight Classification or Uniform Freight Classification.

5.3 Unitization. When shipments to Government depots are full car or truckload, the shipping containers shall be unitized for shipment and handling in accordance with normal commercial practice. The unitized load shall not exceed 2,500 pounds in weight, 63 inches in height, 56 inches in length, and 45 inches in width.

5.4 Marking. Packages, shipping containers and unitized loads (when applicable) shall be marked in accordance with Fed. Std. No. 123.

6. NOTES

6.1 Intended use. Toilet tissue dispensers covered by this specification are intended for use other than residential.

6.2 Ordering data. Purchasers should select the preferred options permitted herein, and include the following information in procurement documents:

(a) Title, number, and date of this specification.
(b) Type (see 1.2.1).
(c) Material (see 3.3.6 and 3.3.7).
(d) Chromium plating on interior plastic surfaces (see 3.6.1).
(e) Selection of applicable packaging and packing levels (see 5.1 and 5.2).

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T12:24Z
Check the source to verify that this is the current version before use.

6.3 Specification cross reference:

WW-P-541b Type	WW-P-541/8 Type	WW-P-541/8 Style	WW-D-1908A Type
438	I	J	I
447	I	G	II
447	I	H	IV
448	I	R	III

MILITARY INTERESTS:

Custodian:

Army - ME
Navy - YD
Air Force - 99

Review Activity:

Navy - CG
DSA - CS

Coordinating Activity:

Navy - YD

User Interest:

Navy - MC
Army - CE

Preparing Activity:

GSA-FSS

Orders for this publication are to be placed with General Services Administration, acting as an agent for the Superintendent of Documents. See Section 2 of this specification to obtain extra copies and other documents referenced herein. Price 60 cents each.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T12:24Z
Check the source to verify that this is the current version before use.