INCH-POUND

MIL-P-28501C(YD)
2 January 1992
SUPERSEDING
MIL-P-28501B(YD)
21 August 1986

MILITARY SPECIFICATION

PUMP ASSEMBLIES, DEEP-WELL, ELECTRIC-MOTOR-DRIVEN

This specification is approved for use by the Naval Facilities Engineering Command, Department of the Navy, and is available for use by all Departments and Agencies of the Department of Defense.

1. SCOPE

1.1 Scope. This specification covers two sizes of electric-motor-driven, deep-well, centrifugal, submersible pump assemblies.

1.2 Classification. Pump assemblies covered by this specification are of the following sizes, as specified (see 6.2).

Size 1 - 26 gallons per minutes (gpm) at 500 feet total dynamic head.
Size 2 - 159 gpm at 500 feet total dynamic head.

2. APPLICABLE DOCUMENTS

2.1 Government documents.

2.1.1 Specifications and standards. The following specifications and standards form a part of this document to the extent specified herein. Unless otherwise specified, the issues of these documents are those listed in the issue of the Department of Defense Index of Specifications and Standards (DODISS) and supplement thereto, cited in the solicitation (see 6.2).

Beneficial comments (recommendations, additions, deletions) and any pertinent data which may be of use in improving this document should be addressed to: Commanding Officer (Code 156), Naval Construction Battalion Center, Port Hueneme, CA 93043-5000, by using the self-addressed Standardization Document Improvement Proposal (DD Form 1426) appearing at the end of this document or by letter.

AMSC N/A FSC 4320

DISTRIBUTION STATEMENT A. Approved for public release; distribution is unlimited .

Source: https://assist.dla.mil -- Downloaded: 2026-10-20T13:05Z
Check the source to verify that this is the current version before use.

Source: https://assist.dla.mil -- Downloaded: 2026-10-20T13:05Z
Check the source to verify that this is the current version before use.

SPECIFICATION

MILITARY

MIL-P-710 - Pumps, Deep-Well, Packaging of.

STANDARD

MILITARY

MIL-STD-105 - Sampling Procedures and Tables for Inspection by Attributes.

(Unless otherwise indicated, copies of military specifications and standards are available from the Standardization Documents Order Desk, Bldg. 4D, 700 Robbins Avenue, Philadelphia, PA 19111-5094.)

2.1.2 Other Government publications. The following other Government publications form a part of this document to the extent specified herein. Unless otherwise specified, the issues are those cited in the solicitation.

DEPARTMENT OF LABOR
OCCUPATIONAL SAFETY AND HEALTH ADMINISTRATION (OSHA)

Title 29, CFR, Part 1910.95 - Occupational Noise Exposure.
Title 29, CFR, Part 1910.219 - Mechanical Power-Transmission Apparatus.

(Application for copies should be addressed to the Superintendent of Documents, U.S. Government Printing Office, Washington, DC 20402.)

2.2 Non-Government publications. The following documents form a part of this document to the extent specified herein. Unless otherwise specified, the issues of the documents which are DoD adopted are those listed in the issue of the DODISS cited in the solicitation. Unless otherwise specified, the issues of documents not listed in the DODISS are the issues of the documents which are current on the date of the solicitation (see 6.2).

AMERICAN SOCIETY OF MECHANICAL ENGINEERS (AWE)

ASME B 1.1 - Unified Inch Screw Threads (UN and UNR Thread Form).
ASME B 1.20.1 - Pipe Threads, General Purpose (Inch).
ASME B 1.20.3 - Dryseal Pipe Threads (Inch).

(Application for copies should be addressed to the American Society of Mechanical Engineers, 345 East 47th Street, New York, NY 10017.)

HYDRAULIC INSTITUTE

Hydraulic Institute Standards.

(Application for copies should be addressed to the Hydraulic Institute, 712 Lakewood Center North, 14600 Detroit Ave., Cleveland, OH 44107.)

Source: https://assist.dla.mil -- Downloaded: 2026-10-20T13:05Z
Check the source to verify that this is the current version before use.

NATIONAL ELECTRICAL MANUFACTURERS ASSOCIATION (NEMA)

NEMA ICS 1 - General Standards for Industrial Controls and Systems.
NEMA ICS 2 - Industrial Control Devices, Controllers and Assemblies.
NEMA ICS 6 - Enclosures for Industrial Controls and Systems.
NEMA MG 1 - Motors and Generators.
NEMA WC 3 - Rubber-Insulated Wire and Cable for the Transmission and Distribution of Electrical Energy.

(Application for copies should be addressed to the National Electrical Manufacturers Association, 2101 L Street, N.W., Washington, DC 20037.)

UNDERWRITERS LABORATORIES INC. (UL)

UL 62 - Flexible Cord and Fixture Wire.
UL 486C - Splicing Wire Connectors.

(Application for copies should be addressed to the Underwriters Laboratories Inc. , 333 Pfingsten Road, Northbrook, IL 60062.)

(Non-Government standards and other publications are normally available from the organizations that prepare or distribute the documents. These documents also may be available in or through libraries or other informational services)

2.3 Order of precedence. In the event of a conflict between the text of this document and the references cited herein, the text of this document takes precedence. Nothing in this document, however, supersedes applicable laws and regulations unless a specific exemption has been obtained.

3. REQUIREMENTS

3.1 Description. The pump assembly shall consist essentially of a vertical multistage turbine pumping element, a submersible cable, a submersible electric motor, and all necessary accessories and connectors required for a complete deep-well submersible pump. The specification does not require that column piping or well casing be furnished with the pump assembly.

3.2 First article. When specified in the contract or purchase order, a sample shall be subjected to first article inspection (see 4.2.1 and 6.4).

3.3 Standard commercial product. The pump assembly shall, as a minimum, be in accordance with the requirements of this specification and shall be the manufacturer’s standard commercial product. Additional or better features which are not specifically prohibited by this specification but which are a part of the manufacturer’s standard commercial product, shall be included in the system being furnished. A standard commercial product is a product which has been sold or is being currently offered for sale on the commercial market through advertisements or manufacturer’s catalogs, or brochures, and represents the latest production model.

Source: https://assist.dla.mil - Downloaded: 2026-10-20T13:05Z
Check the source to verify that this is the current version before use.

3.4 Materials. Materials used shall be free from defects which would adversely affect the performance or maintainability of individual components or of the overall assembly. Materials not specified herein shall be of the same quality used for the Intended purpose in commercial practice. Unless otherwise specified herein, all equipment, material, and articles incorporated in the work covered by this specification are to be new and fabricated using materials produced from recovered materials to the maximum extent possible without jeopardizing the intended use. The term “recovered materials” means materials which have been collected or recovered from solid waste and reprocessed to become a source of raw materials, as opposed to virgin raw materials. Unless otherwise specified, none of the above shall be interpreted to mean that the use of used or rebuilt products are allowed under this specification.

3.4.1 Selection of material for pump parts. Unless otherwise specified herein, the selection of materials used in the manufacture of each pump shall be in accordance with the Hydraulic Institute Standards. The manufacturer shall select the materials which shall minimize galvanic corrosion to the greatest extent possible.

3.5 Design and construction. The size 1 pump assembly shall be designed to deliver a minimum of 26 gpm of water against a total dynamic head of 500 feet. The size 2 pump assembly shall be designed to deliver a minimum of 159 gpm of water against a total dynamic head of 500 feet (see 4.5.1.1). The design of the pump and the necessary equipment shall permit, as far as practicable, easy access for maintenance and service, and shall prevent conditions hazardous to personnel or deleterious to equipment. The horsepower (hp) required to drive the pump under any normal operating range as specified herein shall not exceed the nameplate rating of the motor (see 4.5.1.1). All screw and pipe threads shall conform to ASME B 1.1, ASME B 1.20.1, and ASME B 1.20.3, as applicable.

3.5.1 System of measurement. The dimensions used in this specification are not intended to preclude the use of the metric system of measurement in the fabrication and production of the material, individual parts, and finished product, provided form, fit, and function requirements are satisfied.

* 3.5.2 Pumping element, size 1. The size 1 pumping element shall be of the vertical turbine type, consisting of an impeller shaft, a corrosion-resistant intake screen, and a series of individual turbine bowls threaded or bolted together. In lieu of turbine bowl, the pumping elements may include a series of plastic impellers and diffusers housed in a stainless steel or brass casing. The bowls shall be bronze, stainless steel, or close-grained cast iron having smooth-finish surfaces and liquid passages, and shall be designed for use in 6-inch well casings. A bronze, stainless steel, or rubber bearing, or combination of rubber and bronze or stainless steel, protected by seal and sand collars where applicable, shall be provided at each end of the pumping element, The impeller shaft shall be of turned, ground, stainless steel with not less than 12 percent chromium content. The discharge connection and pump shall be designed to withstand a hydrostatic pressure equal to 1.5 times the pump discharge pressure or the total dynamic head, whichever is greater (see 4.5.1.2). Upthrust protection shall be provided in the bowl assembly.

Source: https://assist.dla.mil -- Downloaded: 2026-10-20T13:05Z
Check the source to verify that this is the current version before use.

* 3.5.3 Pumping element, size 2. The size 2 pumping element shall be of the vertical turbine type consisting of an impeller shaft, a stainless steel intake screen, and a series of individual turbine type bowls threaded or bolted together. The bowls shall be bronze or close-grained cast iron having smooth-finish interior surfaces and liquid passages, and shall be designed for use in 6-inch well casing. Impellers shall be statically balanced and securely fastened to the shaft. A bronze bearing, a rubber bearing, Or a combination of the two shall be provided in each bowl stage for each impeller and a main bronze bearing, protected by seals and sand collars, when applicable, shall be provided at each end of the pumping element. The impeller shaft shall be turned, ground, stainless steel with not less than 12 percent chromium content. The discharge connection and pump to motor adapter shall be cast or ductile iron. The pump shall be designed to withstand hydrostatic pressure equal to 1.5 times the pump discharge pressure or the total dynamic head, whichever is greater (see 4.5.1.2). Upthrust protection shall be provided in the bowl assembly.

3.5.4 Shaft coupling. A stainless steel splined or keyed coupling shall connect the pump assembly to the motor to provide a direct drive to the pump.

* 3.5.5 Surface plate. A 6-inch by 1-1/2-inch surface plate shall be furnished with each size 1 pump assembly. Each size 2 pump assembly shall be furnished with a 6-inch by 3-inch surface plate. The surface plate shall be provided with well and cable seals. The seals shall have auxiliary openings of proper size to fit the cable. Discharge flange shall be flanged and rated for the maximum system pressure.

3.6 Electrical requirements.

3.6.1 Motors. Electric motors shall conform to NEMA MG 1. The motor shall be of the submersible type, equipped with heavy-duty thrust bearing rated to operate continuously at a thrust load equal to 90 percent of the maximum thrust that the pump can impose under any head condition. Size 1 and 2 pump electric motors shall have a nameplate rating of 200 volts, alternating current (Vat), 3-phase, 60 Hertz, for operation on a 208 Vac supply. Size 1 pump electric motor shall be a minimum of 5 hp. The minimum hp for size 2 pump motor shall be 30 hp and shall be designed for low voltage starting.

* 3.6.2 Motor controller. Motor controller shall conform to NEMA ICS 1 and NEMA ICS 2. All units shall be equipped with hand off-auto selector switch suitably enclosed. The starter shall be equipped with overload protection in all phases, low voltage motor protection, and shall be furnished with an enclosure in accordance with NEMA ICS 6. Size 1 units shall be equipped with an across-the-line magnetic starter. Size 2 units shall be equipped for low voltage starting. When specified (see 6.2), extra-quick trip ambient compensated overload relays shall be provided.

3.6.3 Cable. Unless otherwise specified (see 6.2), the electrical conductors shall conform to the applicable portions of NEMA WC 3, including the requirements for portable multiple-conductor power cables. All cables and cords shall be of round construction. The cable shall be designed for heavy-duty, hard usage, and shall be resistant to ozone, sunlight, oils and solvents, cracking, salt water, and physical abuse. The cable shall be designed to operate continuously at a cable temperature of 194 degrees Fahrenheit (°F) in a 104°F ambient temperature environment. The voltage rating of all insulated

Source: https://assist.dla.mil -- Downloaded: 2026-10-20T13:05Z
Check the source to verify that this is the current version before use.

conductors in the cable shall be not less than 600 Vat. The cable for size 1 pump assembly shall have No. 4 American Wire Gage (AWG) minimum size conductors. The cable for size 2 pump assembly shall have No. 2 AWG minimum size conductors. All conductors including the grounding conductors shall be made of copper. The outer jacket shall be black in color. The cable shall conform to the applicable requirements of UL 62, type SO, class 27 outer jacket, class 28 conductor insulation, and meet water-resistant requirements. Unless otherwise specified (see 6.2), the motor head cable shall be provided with minimum six foot pigtail, No. 14 AWG for the size 1 pump assembly, and No. 10 AWG for the size 2 pump assembly for field connection. A corrosion-resistant cable guard shall be provided for the full length of the power cable.

3.7 Additional equipment.

3.7.1 Splice kit. A splice kit, containing all material necessary, including water sealant covers for attaching the submersible cable to the motor leads, shall be furnished with each pump assembly. The splice shall conform to UL 486C.

3.7.2 Check valve. A check valve with 1-1/2-inch American Standard taper pipe threads for general use (NPT) shall be furnished with each size 1 pump assembly. If the check valve is an integral part of the pump discharge casing, the threads shall be 1-1/2-inch NPT female on both ends. A check valve with 3-inch NPT threads on both ends shall be furnished with each size 2 pump assembly.

3.8 Safety. All mechanical and electrical parts that are of such nature or so located as to become a hazard to operating or maintenance personnel shall be enclosed or properly guarded. The pump assembly shall comply with the OSHA regulations, Part 1910.95 for noise and Part 1910.219 for guarding.

3.9 Lubrication. Unless otherwise specified (see 6.2), the pump assembly shall be furnished with a permanently lubricated system that withstands a hydrostatic pressure in accordance with the manufacturer’s standard practice. All parts requiring lubrication shall be properly lubricated before delivery.

3.10 Interchangeability. All pump assemblies of the same classification furnished with similar options under a specific contract shall be identical to the extent necessary to insure interchangeability of component parts, assemblies, accessories, and spare parts.

3.11 Identification marking. Identification shall be permanently and legibly marked directly on the pump assembly or on a corrosion-resisting q etal plate securely attached to the pump assembly at the source of manufacture. Identification shall include the manufacturer’s model and serial number, name and trademark to be readily identifiable to the q anufacturer.

3.12 Instruction plates. The pump assembly shall be equipped with instruction plates suitably located, describing any special or important procedures to be followed in operating and servicing the equipment. Plates shall be of a material which will last and remain legible for the life of the equipment. Plates shall be securely affixed to the equipment with nonferrous screws or bolts of not less than 1/8-inch diameter.

Source: https://assist.dla.mil -- Downloaded: 202640-20T13:05Z
Check the source to verify that this is the current version before use.

3.13 Cleaning, treatment, and painting. Surfaces normally painted in good commercial practice shall be cleaned, treated, and painted as specified herein. The color of the finish coat shall be as specified (see 6.2). Surfaces to be painted shall be cleaned and dried to ensure that they are free from contaminants such as oil, grease, welding slag and spatter, loose mill scale, water, dirt, corrosion product, or any other contaminating substances. As soon as practicable after cleaning, and before any corrosion product or other contamination can result, the surfaces shall be prepared or treated to ensure the adhesion of the coating system. The painting shall consist of at least one coat of primer and one finish coat of acrylic-based enamel. The primer shall be applied to a clean, dry surface as soon as practicable after cleaning and treating. Painting shall be with manufacturer's current materials according to manufacturer's current processes and the total dry film thickness shall be not less than 2.5 roils over the entire surface. The paint shall be free from runs, sags , orange peel, or other defects.

3.14 Workmanship.

3.14.1 Bolted connections. Bolt holes shall be accurately punched or drilled and shall have the burrs removed. Washers or lockwashers shall be provided in accordance with good commercial practice, and all bolts, nuts, and screws shall be tight.

3.14.2 Steel fabrication. The steel used in fabrication shall be free from kinks, sharp bends, and other conditions which would be deleterious to the finished product. Manufacturing processes shall not reduce the strength of the steel to a value less than intended by the design. Manufacturing processes shall be done neatly and accurately. All bends shall be made by controlled means to ensure uniformity of size and shape.

3.14.3 Riveted connections. Rivet holes shall be accurately punched or drilled and shall have the burrs removed. Rivets shall be driven with pressure tools and shall completely fill the holes. Rivet heads, when not countersunk or flattened, shall be of approved shape and uniform size for the same diameter of rivet. Rivet heads shall be full, neatly made, concentric with the rivet holes, and in full contact with the surface of the member.

3.14.4 Casting. All castings shall be sound and free from patching, misplaced coring, warping, or any other defect which reduces the casting's ability to perform its intended function.

3.14.5 Welding. Welding procedures shall be in accordance with a nationally recognized welding code. The surface of parts to be welded shall be free from rust, scale, paint, grease, or other foreign matter. Welds shall be of sufficient size and shape to develop the full strength of the parts connected by the welds. Welds shall transmit stress without permanent deformation or failure when the parts connected by the weld are subjected to proof and service loadings. Weld splatter and sharp edges shall be removed.

4. QUALITY ASSURANCE PROVISIONS

4.1 Responsibility for inspection. Unless otherwise specified in the contract or purchase order, the contractor is responsible for the performance of all inspection requirements (examinations and tests) as specified herein.

Source: https://assist.dla.mil -- Downloaded: 2026-10-20T13:05Z
Check the source to verify that this is the current version before use.

Except as otherwise specified in the contract or purchase order, the contractor may use his own or any other facilities suitable for the performance of the inspection requirements specified herein, unless disapproved by the Government. The Government reserves the right to perform any of the inspections set forth In this document where such inspections are deemed necessary to ensure supplies and services conform to prescribed requirements.

4.1.1 Responsibility for compliance. All items shall meet all requirements of sections 3 and 5. The inspection set forth in this document shall become a part of the contractor's overall inspection system or quality program. The absence of any inspection requirements in this document shall not relieve the contractor of the responsibility of ensuring that all products or supplies submitted to the Government for acceptance comply with all requirements of the contract. Sampling inspection, as part of manufacturing operations, is an acceptable practice to ascertain conformance to requirements, however, this does not authorize submission of known defective material, either indicated or actual, nor does it commit the Government to accept defective material.

4.1.2 Component and material inspection . Components and materials shall be inspected in accordance with all the requirements specified herein and in applicable referenced documents.

4.2 Classification of inspections. The inspection requirements specified herein are classified as follows:

a. First article inspection (see 4.2.1).
b. Quality conformance inspection (see 4.2.2).

4.2.1 First article inspection. The first article inspection shall be performed on one complete pump assembly when a first article is required (see 3.2 and 6.2). This inspection shall include the examination of 4.4, the tests of 4.5.1, and when specified (see 6.2), the packaging inspection of 4.6. The first article may be either a first production item or a standard production item from the supplier's current inventory provided the item meets the requirements of the specification and is representative of the design, construction, and manufacturing technique applicable to the remaining items to be furnished under the contract.

4.2.2 Quality conformance inspection. The quality conformance inspection shall include the examination of 4.4, the test of 4.5.2, and the packaging inspection of 4.6. This inspection shall be performed on the samples selected in accordance with 4.3.

4.3 Sampling. Sampling and inspection procedures shall be in accordance with MIL-STD-105. The unit of product shall be one complete pump assembly. All pump assemblies offered for delivery at one time shall be considered a lot for the purpose of inspection. Guidance for inspection level and Acceptable Quality Level (AQL) is provided in 6.5.

4.4 Examination. Each unit shall be examined for compliance with the requirements specified in section 3 of this document. Any redesign or modification of the contractor's standard product to comply with specified requirements, or any necessary redesign or modification following failure to meet specified requirements shall receive particular attention for adequacy and

Source: https://assist.dla.mil -- Downloaded: 2026-10-20T13:05Z
Check the source to verify that this is the current version before use.

suitability. This element of inspection shall encompass all visual examinations and dimensional measurements. Noncompliance with any specified requirement or presence of one or more defects preventing or lessening maximum efficiency shall constitute cause for rejection.

4.5 Tests. Prior to the tests specified herein which require the units be operated, the units shall be serviced with lubricants recommended by the manufacturer for use in the ambient temperature at the test location.

4.5.1 First article tests. Performance tests shall be conducted in accordance with the Centrifugal Pump Section of the Hydraulic Institute Standards. The first article shall receive the tests of 4.5.1.1 and 4.5.1.2. Failure to pass any tests shall constitute cause for rejection.

4.5.1.1 Performance test. The pump assembly shall be tested to determine compliance with the requirements of 3.5. The tests shall be conducted with a sustained pumping liquid level sufficient to prevent vortexing. During the operation, a characteristic capacity-head tune shall be plotted over the complete operating range of the pump.

4.5.1.2 Hydrostatic pressure test. The pump assembly shall be subjected to a hydrostatic test pressure as specified in 3.5.2 and 3.5.3, as applicable, for a period of not less than 5 minutes. Hydrostatic test shall be made using oil or water at the option of the supplier. No leakage shall be evident in the casing or through the casing gasket.

4.5.2 Quality conformance Operational test. The pump assembly shall be operated at induction motor speed to determine the capacity of the pump at a 500 foot discharge head. The operating time shall be that required to obtain the performance characteristics of the pump. Failure of the pump to attain the applicable capacity specified in 3.5, at a 500-foot discharge head, shall constitute failure of this test.

4.6 Packaging inspection. The inspection of the presentation, packing, and marking shall be in accordance with the requirements of section 4 of MIL-P-710. The inspection shall consist of the quality conformance inspection; and, when specified (see 6.2), a preproduction pack shall be furnished for examination and test within the time frame required (see 6.2).

5. PACKAGING

5.1 Preservation, packing and marking. Preservation, packing, and marking shall be in accordance with the requirements of MIL-P-710 with the level of presentation and the level of packing as specified (see 6.2).

6. NOTES

(This section contains information of a general or explanatory nature that may be helpful, but is not mandatory.)

6.1 Intended use. The pump assemblies are intended for use in semi-permanent and permanent 6-inch diameter deep-well, water supply systems.

Source: https://assist.dla.mil -- Downloaded: 2026-10-20T13:05Z
Check the source to verify that this is the current version before use.

* 6.1.1 Selection factors.

a. Fungus resistant varnish conforming to MIL-V-173 should be used to coat electrical components and circuit elements, including terminal and circuit connections, when the unit is to be installed in humid conditions. Components and elements inherently inert to fungi or in hermetically sealed enclosures or current-carrying contact surfaces should not be coated.
b. Electromagnetic interference suppression (EMI), when required, should conform to the EMI suppression requirements and test limits as specified in MIL-STD-461.

6.2 Acquisition requirements. Acquisition documents should specify the following:

a. Title, number, and date of this specification.
b. Size of pump assembly required (see 1.2).
c. Issue of DODISS to be cited in the solicitation, and if required, the specific issue of individual documents referenced (see 2.1.1 and 2.2).
d. When first article is required for inspection and approval (see 3.2 and 4.2.1).
e. When extra-quick trip ambient overload relays are to be furnished (see 3.6.2).
f. When cable and length are to be different (see 3.6.3).
g. When lubrication is to be different (see 3.9).
h. Color of finish coat required (see 3.13).
i. When a preproduction pack inspection is required and the time frame required for submission (see 4.2.1 and 4.6).
j. Level of preservation and level of packing required (see 5.1).

6.3 Data requirements. When this specification is used in an acquisition and data are required to be delivered, the data requirements shall be developed as specified by an approved Data Item Description (DD Form 1664) and delivered in accordance with the approved Contract Data Requirements List (CDRL), incorporated into the contract. When the provisions of DoD Federal Acquisition Regulations (FAR) Supplement, Part 27, Sub-Part 27.475-1 (DD Form 1423) are invoked and the DD Form 1423 is not used, the data should be delivered by the contractor in accordance with the contract or purchase order requirements.

6.4 First article. When a first article inspection is required, the item will be tested and should be a first production item or it may be a standard production item from the contractor's current inventory as specified in 4.2.1. The first article should consist of one unit. The contracting officer should include specific instructions in acquisition documents regarding arrangements for examination, test, and approval of the first article.

* 6.5 Sampling procedures.

* 6.5.1 Sampling for examination. Recommended inspection level is II and AQL is 4.0 (see 4.3).

* 6.5.2 Sampling for tests. Recommended inspection level is S-4 and AQL is 6.5 (see 4.3).

Source: https://assist.dla.mil -- Downloaded: 2026-10-20T13:05Z
Check the source to verify that this is the current version before use.

6.6 Part or identifying number (PIN). The PIN to be used for pump assemblies applied to this specification is created as follows:

	M28501	X
Specification part number		
Size code (see 1.2)		

6.7 Subject term (key word) listing.

Centrifugal pump
Multistage element
Submersible cables
Splice kit
Check valve

6.8 Changes from previous issue. The margins of this specification are marked with an asterisk to indicate where changes (additions, modifications, corrections, deletions) from the previous issue were made. This was done as a convenience only and the Government assumes no liability whatsoever for any inaccuracies in these notations. Bidders and contractors are cautioned to evaluate the requirements of this document based on the entire content irrespective of the marginal notations and relationship to the last previous issue.

Preparing Activity:
Navy - YD

(Project 4320-N338)

Source: https://assist.dla.mil -- Downloaded: 2026-10-20T13:05Z
Check the source to verify that this is the current version before use.

STANDARDIZATION DOCUMENT IMPROVEMENT PROPOSAL

INSTRUCTIONS

1. The preparing activity must complete blocks 1, 2, 3, and 8. In block 1, both the document number and revision letter should be given.
2. The submitter of this form must complete blocks 4, 5, 6, and 7.
3. The preparing activity must provide a reply within 30 days from receipt of the form.

NOTE: This form may not be used to request copies of documents, nor to request waivers, or clarification of requirements on current contracts. Comments submitted on this form do not constitute or imply authorization to waive any portion of the referenced document(s) or to amend contractual requirements.

I RECOMMEND A CHANGE:	1. DOCUMENT NUMBER	2. DOCUMENT DATE (YYMMDD)
	MIL-P-28501C(YD)	920102

3. DOCUMENT TITLE
PUMP ASSEMBLIES, DEEP-WELL, ELECTRIC-MOTOR-DRIVEN

4. NATURE OF CHANGE (Identify paragraph number and include proposed rewrite, if possible. Attach extra sheets as needed.)

5. REASON FOR RECOMMENDATION

6. SUBMITTER

a. NAME (Last, First, Middle Initial)	b. ORGANIZATION	
c. ADDRESS (Include Zip Code)	d. TELEPHONE (Include Area Code) (1) Commercial (2) AUTOVON (If applicable)	7. DATE SUBMITTED (YYMMDD)

8. PREPARING ACTIVITY

a. NAME	b. TELEPHONE (Include Area Code) (1) Commercial	(2) AUTOVON
ANNE L. LYONS	805-982-5761	551-5761
c. ADDRESS (Include Zip Code) COMMANDING OFFICER NAVAL CONSTRUCTION BATTALION CENTER (1564A) PORT HUENEME, CA 93043-5000	IF YOU DO NOT RECEIVE A REPLY WITHIN 45 DAYS, CONTACT: Defense Quality and Standardization Office 5203 Leesburg Pike, Suite 1403, Falls Church, VA 22041-3466 Telephone (703) 756-2340 AUTOVON 289-2340	

Source: https://assist.dla.mil -- Downloaded: 2020-03-26T12:36:40Z
Check the source to verify that this is the current version before use.