MIL-H-12322D
8 December 1978
SUPERSEDING
MIL-H-12322C
27 February 1968

MILITARY SPECIFICATION

HEATERS, WATER, STEAM- HOT-WATER HEATED

This specification is approved for use by all Departments and Agencies of the Department of Defense.

1. SCOPE

1.1 Scope. This specification covers water heaters using steam or high-temperature hot water as the heating medium in a heating coil inclosed in a hot-water storage tank.

1.2 Classification. The heaters shall be of the following classes as specified (see 6.2):

Class 1 - Steam.
Class 2 - High-temperature hot water (350° to 400° F).

2. APPLICABLE DOCUMENTS

2.1 Issues of documents. The following documents of the issue in effect on date of invitation for bids or request for proposal form a part of this specification to the extent specified herein:

SPECIFICATIONS

FEDERAL

GG-P-455	- Plates and Foils, Photographic (Photosensitive Anodized Aluminum).

FSC 4520

Beneficial comments (recommendations, additions, deletions) and any pertinent data which may be of use in improving this document should be addressed to: US Army Mobility Equipment Research and Development Command, ATTN: DRDME-DS, Fort Belvoir, VA 22060 by using the self-addressed Standardization Document Improvement Proposal (DD Form 1426) appearing at the end of this document or by letter.

Source: https://assist.dla.mil -- Downloaded: 2026-10-17T22:42Z
Check the source to verify that this is the current version before use.

MILITARY

MIL-P-116	- Preservation-Packaging, Methods of.
MIL-T-704	- Treatment and Painting of Materiel.
MIL-B-3180	- Boilers and Related Equipment, Packaging of.
MIL-T-12295	- Tanks, Hot-Water Storage.

STANDARDS

MILITARY

MIL-STD-105	- Sampling Procedures and Tables for Inspection by Attributes.
MIL-STD-129	- Marking for Shipment and Storage.
MIL-STD-130	- Identification Marking of US Military Property.
MIL-STD-1188	- Commercial Packaging of Supplies and Equipment.

(Copies of specifications and standards required by contractors in connection with specific procurement functions should be obtained from the procuring activity or as directed by the contracting officer.)

2.2 Other publications. The following documents form a part of this specification to the extent specified herein. Unless otherwise indicated, the issue in effect on date of invitation for bids or request for proposal shall apply.

AMERICAN SOCIETY OF MECHANICAL ENGINEERS

Boiler and Pressure Vessel Code.

Section VIII - Unfired Pressure Vessels.
Section IX - Welding and Brazing Qualifications.

(Application for copies should be addressed to the American Society of Mechanical Engineers, 345 East 47th Street, New York, NY 10017.)

AMERICAN SOCIETY FOR TESTING AND MATERIALS

B75 - Seamless Copper Tube.
B111 - Copper and Copper-Alloy Seamless Condenser Tubes and Ferrule Stock.

Source: https://assist.dla.mil -- Downloaded: 2026-10-17T22:42Z
Check the source to verify that this is the current version before use.

(Application for copies should be addressed to the American Society for Testing and Materials, 1916 Race Street, Philadelphia, PA 19103.)

NATIONAL BUREAU OF STANDARDS

Handbook H28 - Screw-Thread Standards for Federal Services.

(Application for copies should be addressed to the Superintendent of Documents, Government Printing Office, Washington, DC 20402.)

(Technical society and technical association specifications and standards are generally available for reference from libraries. They are also distributed among technical groups and using Federal agencies.)

3. REQUIREMENTS

3.1 Description. The water heater shall consist of a hot-water storage tank incorporating a removable heating element. Each heater shall be complete with all components necessary for full operation.

3.2 Material. Material shall be as specified herein. Materials not specified shall be selected by the contractor and shall conform to all requirements of this specification (see 6.9).

3.3 First article. When specified (see 6.2 and 6.4), the contractor shall furnish a water heater for examination and testing as specified in 4.3 within the time frame specified (see 6.2) to prove, prior to starting production, that his production methods and choice of design detail will produce water heaters that comply with the requirements of this specification (see 6.3). Examination and tests shall be those specified herein.

3.4 Quality conformance. When specified (see 6.2), the contractor shall furnish to the Government one or more water heaters (see 6.2) for testing as specified in 4.4.

3.5 Water storage tanks. The water storage tanks shall conform to MIL-T-12295, type, class, style, size, and capacity as specified (see 6.2), except that Types II, IV, and VI (cement, glass, and copper lined tanks) shall have a minimum diameter of 30 inches. Type II (cement lined) tanks shall be completely assembled before the lining is applied. No welding of the tank shell or ends shall be permitted after the lining is installed. Type IV (glass lined) tanks may be assembled completely before the lining is applied or the lining may be applied to the heads and the shell separately and the two or three pieces welded together after firing, provided this is

Source: https://assist.dla.mil -- Downloaded: 2026-10-17T22:42Z
Check the source to verify that this is the current version before use.

the manufacturer's standard procedure and that precautions are taken to mimimize damage to the glass lining during the welding process. For Type VI (copper lined) tanks the lining may be applied after the complete steel tank has been assembled; or the copper lining may be rolled together with the steel plates prior to assembly. It is permissible to weld the seams in the copper lining inside the tank after the final assembly welding of the steel shell and heads. The welds in the steel shell must be ground smooth on the inside. Unless otherwise specified (see 6.2), tappings, openings, tank supports, and tank fabrication shall conform to MIL-T-12295, except that all cement, glass, and copper lined tanks (Types II, IV, and VI) shall be equipped with an 11 inch x 15 inch minimum size manhole assembly. The manhole and cover shall be constructed in such a manner that only the lining and nonferrous metal shall be in contact with the water. The manhole cover may be made of nonferrous metal or be provided with the same protective lining as the tank, however, cement lined covers shall not be acceptable. For cement lined tanks, the manhole cover may also be made of hot-dipped galvanized steel when specified (see 6.2 and 6.6). For all other types of tanks (Types III, VII, VIII, IX, and X) the manhole covers shall be constructed of the same material as the tank. In addition, all tanks furnished under this specification shall be equipped with a flanged nozzle neck as an integral part for installation of the heating element. The flanged nozzle neck shall be fabricated from a steel flange and a copper-silicon tubular section for cement, glass, and copper lined tanks. For glass lined tanks the nozzle tube may also be manufactured from the same steel as the tank shell provided the tube and flange both are glass lined internally with the same material as the tank. For stainless steel, copper, copper-silicon, nickel-copper, and copper-nickel tanks, the flanged nozzle neck shall be made of the same material as the tank. The flanged nozzle neck shall be fabricated in accordance with the ASME Boiler and Pressure Vessel Code, Section VIII, "Unfired Pressure Vessels." In all types of lined tanks only the lining material and nonferrous material shall be in contact with the service water.

3.6 Heating elements. Heating elements shall consist of U-bend coils, a tube sheet, spacer plate(s) (when applicable) and an element head. The coil shall be of seamless copper or copper alloy tubing and shall be inserted into holes in the tube sheet and secured by expanding the tubing. The tube sheet shall be of copper alloy or other suitable nonferrous metal. The individual coiled tubing shall be arranged in parallel rows without overlapping or interlocking, and shall be held in alinement by one or more spacer plates. Other tubing arrangements such as the "triangular pitch" may be satisfactory provided it is submitted to the contracting officer for approval prior to construction. Tubing wall thickness shall be as shown in Table I. The heating element shall be installed in the tank through the flanged nozzle neck and secured with a gasketed bolted connection.

Source: https://assist.dla.mil -- Downloaded: 20261O-17T22:42Z
Check the source to verify that this is the currentversion before use.

Elements with coils longer than 3 feet shall be provided with one coil support, and elements with coils longer than 8 feet shall be provided with two coil supports. Spacer plates and the coil supports shall be of copper alloy. In Type IV (glass lined) tanks, the coil support(s) may be made of steel provided it is covered with the same glass lining as the tank and fired at the same time.

Table I. Tubing Wall Thickness

Outside diameter (inches)	Nominal thickness (inch)	Birmingham Wire Gage
3/4	0.049	18
1-1/4	0.065	16

Note: 5/8 inch and 1-1/8 inch O.D. size tubing may be used for the heating coils provided the surface area of the tubing is compensated to maintain the specified heating capacity.

3.6.1 Class 1 (steam). The class 1 heater element shall have a working pressure of 150 pounds per square inch gage (psig) with steam at a temperature of 365° F. The heating surface (see 6.2 and 6.8) shall be based on 1 square foot of heating surface to heat 20 gallons or more of water in 1 hour from 40° F to 180° F using steam at atmospheric pressure. Tubing shall be light-drawn copper tubing conforming to ASTM B75. Heating elements shall withstand an internal hydrostatic pressure of 225 psig for not less than 15 seconds without leaking or any evidence of damage.

3.6.2 Class 2, (high temperature hot water). The class 2 heater element shall have a working pressure of 400 psig with water at a temperature of 400° F. The heating surface (see 6.2 and 6.8) shall be based on 1 square foot of heating surface to heat 20 gallons or more of water in 1 hour from 40° F to 180° F using hot water at a temperature of 350° F. Tubing shall conform to ASTM B111, Copper Alloy No. 706 (90-10 copper-nickel). Heating elements shall withstand an internal hydrostatic pressure of 600 psig for not less than 15 seconds without leaking or any evidence of damage.

3.6.3 Element head. The element head for Class 1 heaters shall be of close-grained cast iron or fabricated of steel, and the element head for Class 2 heaters shall be cast steel or fabricated of steel. The head shall be partitioned to separate the supply and return of the heating medium.

Source: https://assist.dla.mil -- Downloaded: 202610-17T22:42Z
Check the source to verify that this is the currentversion before use.

The head shall be equipped with tappings or flanges for the supply, return, air-relief valve and vacuum breaker connections. Unless otherwise specified (see 6.2) the size of the supply and the return connections shall be in accordance with Table II, except that the cross-sectional area shall be not less than the total cross-section area of the tubing carrying the heating medium through the coils. The air-relief valve and vacuum breaker connections shall be 1/2-inch in size. Threads for tappings shall be tapered pipe threads (NPT) in accordance with Handbook H28.

Table II. Supply and return connections

Maximum heating surface (sq ft)	Minimum size tappings or flanges (in)	
	Supply	Return
5	1	3/4
7-1/2	1-1/4	1
12-1/2	1-1/2	1
25	2	1-1/4
40	2-1/2	1-1/2
62-1/2	3	2
100	4	2
175	5	2-1/2
250	6	3

3.6.4 Determination of coil heating surface required. In order to select the proper size heating element required, the following information must be specified in the ordering data (see 6.2):

(a) Gallons per hour (gph) of water to be heated.
(b) Temperature rise in the service water required (usually 100° F; 40° to 140° F).
(c) Steam pressure available, or high-temperature water inlet temperature and flow rate (gpm), as applicable.

Heating surface required shall be based on the nominal ratings shown in 3.6.1 and 3.6.2 and corrected for the prevailing service water temperature rise; steam pressure; or heating water inlet temperature and flow rate, as applicable.

3.7 Gaskets. The element head, tube sheet, and heater assembly connections shall be gasketed. The gaskets shall be of compressed asbestos.

Source: https://assist.dla.mil -- Downloaded: 2026-10-17T22:42Z
Check the source to verify that this is the current version before use.

3.8 Insulation. When specified (see 6.2 and 6.5), the exterior of the heater shall be insulated. Insulation shall consist of not less than 1/2-inch hard-finished asbestos cement covering a 1-1/2-inch mineral wool banket.

3.9 Identification. The manufacturers standard commercial markings shall be acceptable unless otherwise specified. When specified (see 6.2), the heater shall be identified in accordance with MIL-STD-130. The marking shall be applied to the heater on identification plates of material conforming to GG-P-455, Type I, Grade A, Class 1. In addition to identification markings as specified in MIL-STD-130, each plate shall indicate the total square feet of heating surface.

3.10 Treatment and painting. The manufacturer's standard commercial finish including the color shall be acceptable unless otherwise specified. When specified (see 6.2), the portions of the water heater normally painted shall be cleaned, treated, and painted in accordance with MIL-T-704, Type A, except the color for exterior surfaces of the heater shall be as specified (see 6.2).

3.11 Technical publications. Such technical publications as are specified shall be furnished (see 6.2). A normal schedule of maintenance shall be included.

3.12 Workmanship. All parts of the heater including forgings, molded parts, stampings, machined surfaces, and welded parts shall be clean and free from sand, dirt, fins, sprues, scale, flux, and other harmful extraneous material. Welding and flange connections shall be in accordance with the ASME Boiler and Pressure Vessel Code, Section VIII, "Unfired Pressure Vessels."

3.13 Standard product. Except as otherwise specified herein, the water heater shall be the standard product of the manufacturer and shall be identifiable by the manufacturer's model number, figure number, or equivalent designation. The equipment shall be new and unused except to the extent required to perform the tests specified herein.

3.14 Interchangeability. All parts having the same part number shall be functionally and dimensionally interchangeable. Interchangeable parts are defined as two or more like parts possessing such functional and physical characteristics as to be equivalent in performance and durability, and capable of being exchanged one for the other without alteration of the parts themselves or of adjoining parts, except for adjustment, and without selection for fit or performance.

Source: https://assist.dla.mil -- Downloaded: 2026-10-17T22:42Z
Check the source to verify that this is the current version before use.

3.14.1 Threaded parts. All threaded parts shall conform to the National Bureau of Standards Handbook H28.

3.15 Dissimilar metals. Except where specified, there shall be no contact between dissimilar metals which could cause deterioration, galvanic corrosion, seizure, or warpage through differential contraction or expansion. Nonpermissible galvanic couples (dissimilar metals) as defined in MIL-T-704 shall be insulated as specified in MIL-T-704.

3.16 Safety. All exposed parts which are subject to high operating temperatures, are energized electrically, or are subject to damage shall be insulated, fully enclosed or guarded. Protective devices shall not impair the operating functions.

3.17 Maintainability. The water heaters shall operate as specified herein without repair or maintenance other than the contractor's recommended normal scheduled adjustments and servicing, as established by a maintenance schedule prepared and submitted by the contractor prior to test (see 3.11). All major assemblies and installed attachments shall be accessible for maintenance, repair and replacement without removal of other major assembles and installed attachments not normally removed. Cover plates which must be removed for component adjustment shall be equipped with quick-disconnect fastenings. All fasteners shall be of corrosion-resistant material or shall be treated to be corrosion resistant. Maximum use shall be made of interchangeable hardware and fastening devices. Each maintenance, assembly or disassembly operation shall be accomplished by not more than two men using common tools and special tools furnished.

3.18 Fabrication. Metals used in the fabrication of the water heaters shall provide original quality surface finish and shall be free from kinks and sharp bends. The forming of the material shall be done by methods that will not cause damage to the metal. Shearing and chipping shall be done neatly and accurately. Corners shall be square and true, and sharp edges and burrs shall be removed. Flame-cutting may be employed instead of shearing and sawing. Burned surfaces of flame-cut material shall be ground or machined sufficiently to remove ash and cooling checks. Precautions shall be taken to avoid overheating, and heated metals should be allowed to cool slowly. All bends of a major character shall be made with metal dies or fixtures to insure uniformity of size and shape.

3.18.1 Welding. The surfaces of parts being welded shall be free of scale, paint, grease, and other foreign matter. Welds shall transmit stress without permanent deformation or failure when the parts connected

Source: https://assist.dla.mil -- Downloaded: 20261O-17T22:42Z
Check the source to verify that this is the current version before use.

by the welds are subjected to proof and service loading. All welding procedures and welder's qualifications shall be in accordance with Section IX of the ASME Boiler and Pressure Vessel Code.

4. QUALITY ASSURANCE PROVISIONS

4.1 Responsibility for inspection. Unless otherwise specified in the contract, the contractor is responsible for the performance of all inspection requirements as specified herein. Except as otherwise specified in the contract, the contractor may use his own or any other facilities suitable for the performance of the inspection requirements specified herein, unless disapproved by the Government. The Government reserves the right to perform any of the inspections set forth in the specification where such inspections are deemed necessary to assure supplies and services conform to prescribed requirements. The contractor is responsible for insuring that components and materials used are manufactured, examined, and tested in accordance with referenced specifications and standards.

4.2 Classification of inspections. The inspection requirements specified herein are classified as follows:

(a) First article inspection (see 4.3).
(b) Quality conformance inspection (see 4.4).

4.3 First article inspection. The water heater shall be inspected in accordance with the first article inspection requirements of MIL-I-12295 and examined in accordance with 4.5.1. In addition the tank heating element shall be subjected to a hydrostatic test at the test pressures specified in 3.6.1 and 3.6.2. Any evidence of leakage or damage shall constitute failure of this test.

4.4 Quality conformance inspection.

4.4.1 Sampling for examination. Sampling shall be in accordance with MIL-STD-105, Inspection Level S-1.

4.4.2 Examination. Samples selected in accordance with 4.4.1 shall be examined as specified in 4.5.1. Acceptable Quality Level shall be 2.5 percent defective.

4.4.3 Test. Each heating element shall be tested as specified in 4.5.2. Failure to pass the test shall be cause for rejection.

Source: https://assist.dla.mil -- Downloaded: 2026-10-17T22:42Z
Check the source to verify that this is the current version before use.

4.5 Inspection procedure.

4.5.1 Examination. The heaters shall be examined for the following defects:

101. Materials not as specified.
102. Tank not as specified.
103. Components damaged or missing.
104. Flanged nozzle neck of improper material or construction.
105. Heating element head not as specified.
106. Insufficient coil heating surface area.
107. Improper assembly of heating element in tank (bracing and spacing).
108. Improper size supply and return connection(s).
109. Identification plates missing or not as specified.
110. Treatment and painting not as specified.
111. Workmanship not as specified.
112. Lack of ASME label or equivalent evidence.

4.5.2 Hydrostatic test. Subject each tank heating element to the specified hydrostatic pressure (see 3.6.1 and 3.6.2). Any evidence of leakage or damage shall constitute failure of this test.

4.6 Inspection comparison. The Government may select heaters at any time during the contract production period and subject these heaters to the examination and tests specified herein to determine that the quality of the selected heaters is equal to the quality standards established during quality conformance inspection. The inspection will be performed by the Government at a site selected by the Government. Heaters will be selected at random from those which have been accepted by the Government and will not include the previously inspected first article and quality conformance heaters. Failure of any heater may be considered cause for refusal by the Government to continue acceptance of heaters until objective evidence furnished by the contractor reveals that corrective action has been taken to eliminate the condition which caused the rejection.

4.7 Inspection of packaging. Level A or Level B preservation, packing, and marking shall be examined and tested in accordance with the quality assurance provisions of MIL-B-3180. Commercial preservation, packing, and marking shall be examined for conformance to MIL-STD-1188. Level A, Level B, and Commercial shall be examined for conformance to the additional requirement specified herein in 5.1 for Type II tanks.

Source: https://assist.dla.mil -- Downloaded: 2026-10-17T22:42Z
Check the source to verify that this is the current version before use.

5. PACKAGING

5.1 Preservation, packing, and marking. Preservation, packing, and marking shall be Level A, Level B, or Commercial as specified (see 6.2). Level A or Level B shall be in accordance with MIL-B-3180. Commercial shall be in accordance with MIL-STD-1188. In addition, all cement lined tanks (Type II) processed for Level A, Level B, or Commercial shall be shipped and stored sealed with 6 to 12 inches of water in the tank to prevent deterioration of the lining.

6. NOTES

6.1 Intended use. The heaters are intended for use where hot service water requirements are not constant or where a large volume of heated water must be held in storage for sudden heavy demands.

6.2 Ordering data. Procurement documents should specify the following:

(a) Title, number, and date of this specification.
(b) Class required (see 1.2).
(c) When first article is required (see 3.3).
(d) Time frame required for submission of first article (see 3.3).
(e) When quality conformance testing is required (see 3.4).
(f) Type, class, style, size, and capacity of storage tank required in accordance with MIL-T-12295 (see 3.5).
(g) When tappings, openings, tank supports and fabrication other than as specified in MIL-T-12295 is required (see 3.5).
(h) When size of supply and return connections differ from 3.6.3.
(i) When insulation of heater is required (see 3.8 and 6.5).
(j) When treatment and painting shall be in accordance with MIL-T-704 and state color desired (see 3.10).
(k) Technical publications required (see 3.11).
(l) When hot dipped galvanized steel manhole covers are acceptable for cement lined tanks (see 3.5 and 6.6).
(m) Information required to determine area of coil heating surface required (see 3.6.4):

(1) Gallons per hour (gph) of service water to be heated.
(2) Temperature rise required in the service water (lowest water inlet temperature subtracted from maximum outlet temperature).
(3) Steam pressure available; or high-temperature water inlet temperature and flow rate available (as applicable).

Source: https://assist.dla.mil -- Downloaded: 2026-10-17T22:42Z
Check the source to verify that this is the current version before use.

(n) When identification markings must be in accordance with MIL-STD-130 (see 3.9).
(o) Degree of preservation and degree of packing (see 5.1).

6.3 Information. It is important that the ordering data be filled out completely particularly 6.2 (b),(f), and (m). Note that storage tank information required pertains to MIL-T-12295 regarding type of tank (material and lining), working pressure, size, and whether it should be of horizontal or vertical construction. In order to properly prepare the ordering data, it is necessary to obtain a copy of MIL-T-12295. Since these heaters are generally a standard commercial product readily available from many manufacturers, it is advisable from an economic point of view not to impose special military requirements for shipping, marking, and finishing unless absolutely necessary (see 3.9, 3.10, and 5).

6.4 First article test. When first article tests are required, appropriate provisions should be included in the contract to allow the contracting officer to waive completely or in part the first article tests and reduce the bid price accordingly if the successful bidder has previously performed any or all of the first article tests in recent procurements, or if quantities involved are less than 10. When the require that the successful bidder seeking such a waiver submit satisfactory evidence, including test and inspection reports that the tests have been performed successfully in the past and additional information such as the contract identification, the procuring activity, the date, and other pertinent data deemed necessary by the contracting officer. Note that deletion of first article tests does not delete the tests required by Section VIII of the ASME code. Any changes or deviations of production heaters from the approved first article during production will be subject to the approval of the contracting officer. Approval of the first article will not relieve the contractor of his obligation to furnish heaters conforming to this specification.

6.5 Insulation. Water heaters of the type specified here are virtually never shipped pre-insulated from the manufacturer's plant. Almost invariably these heaters are insulated in the field after installation (see 3.8).

6.6 Manhole covers. For cement lined tanks the manhole covers shall preferably be made of nonferrous metals such as bronze, copper-nickel, copper silicon or stainless steel. The hot-dipped galvanized steel manhole cover should not be specified where the water is moderately to severely corrosive (see 3.5).

Source: https://assist.dla.mil -- Downloaded: 202610-17T22:42Z
Check the source to verify that this is the current version before use.

6.7 Cathodic protection. It is important that all single or double coated glass lined (Type IV) storage tanks be provided with cathodic protection as specified in MIL-T-12295. Do not waive this requirement for this type of tank.

6.8 Heating surface shall be defined as the outside surface area of the tubing (see 3.6.1 and 3.6.2).

6.9 Recycled material. It is encouraged that recycled material be used when practical as long as it meets the requirements of the specification (see 3.2).

Custodians:
Army - ME
Navy - YD
Air Force - 99

Preparing activity:
Army - ME

Project 4520-0228

Review activities:
Army - MD, CE
Navy - CG
DLA - CS

Source: https://assist.dla.mil -- Downloaded: 202610-17T22:42Z
Check the source to verify that this is the current version before use.

INSTRUCTIONS: In a continuing effort to make our standardization documents better, the DoD provides this form for use in submitting comments and suggestions for improvements. All users of military standardization documents are invited to provide suggestions. This form may be detached, folded along the lines indicated, taped along the loose edge *(DO NOT STAPLE)*, and mailed. In block 5, be as specific as possible about particular problem areas such as wording which required interpretation, was too rigid, restrictive, loose, ambiguous, or was incompatible, and give proposed wording changes which would alleviate the problems. Enter in block 6 any remarks not related to a specific paragraph of the document. If block 7 is filled out, an acknowledgement will be mailed to you within 30 days to let you know that your comments were received and are being considered.

NOTE: This form may not be used to request copies of documents, nor to request waivers, deviations, or clarification of specification requirements on current contracts. Comments submitted on this form do not constitute or imply authorization to waive any portion of the referenced document*(s)* or to amend contractual requirements.

(Fold along this line)

(Fold along this line)

DEPARTMENT OF THE ARMY

NO POSTAGE NECESSARY IF MAILED IN THE UNITED STATES

OFFICIAL BUSINESS
PENALTY FOR PRIVATE USE $300

BUSINESS REPLY MAIL
FIRST CLASS PERMIT NO 12062 WASHINGTON D C

POSTAGE WILL BE PAID BY THE DEPARTMENT OF THE ARMY

Commander
US Army Mobility Equipment Research & Development
Command
ATTN: DRDME-DS
Fort Belvoir, VA 22060

Source: https://assist.dla.mil -- Downloaded: 2026-10-17T22:42Z
Check the source to verify that this is the current version before use.

(TO DETACH THIS ... CUT ALONG THIS LINE.)

STANDARDIZATION DOCUMENT IMPROVEMENT PROPOSAL

(See Instructions – Reverse Side)

1. DOCUMENT NUMBER	2. DOCUMENT TITLE

3a. NAME OF SUBMITTING ORGANIZATION	4. TYPE OF ORGANIZATION *(Mark one)*
	☐ VENDOR
	☐ USER
b. ADDRESS *(Street, City, State, ZIP Code)*	☐ MANUFACTURER
	☐ OTHER *(Specify)* _____

5. PROBLEM AREAS

a. Paragraph Number and Wording:

b. Recommended Wording

c. Reason/Rationale for Recommendation:

6. REMARKS

7a. NAME OF SUBMITTER *(Last, First, MI)* – Optional	b. WORK TELEPHONE NUMBER *(Include Area Code)* – Optional
c. MAILING ADDRESS *(Street, City, State, ZIP Code)* – Optional	8. DATE OF SUBMISSION *(YYMMDD)*

DD FORM 82 MAR 1426 PREVIOUS EDITION IS OBSOLETE

Source: https://assist.dla.mil -- Downloaded: 2026-10-17T22:42Z
Check the source to verify that this is the current version before use.