COMMERCIAL ITEM DESCRIPTION

VALVE, AIR VENTING, STEAM, THERMOSTATIC

The General Services Administration has authorized the use of this commercial item description.

Salient characteristics:

Mode of operation - automatically frees steam heating system of air.

Rating - maintains radiator having at least 100 square feet of rated surface within 3° F. of inlet steam temperature. (Exception: maintains last radiator section within 20° F. of inlet steam temperature.)

Temperature equilibrium - attained within 50 minutes when supplied with steam at 1/2 psi.

Material - body and base shall be brass.

Finish - body and base exterior shall be either chrome or nickel plated.

Valve pattern - angle configuration.

Pressure - designed for 15 psi maximum steam pressure.

Mounting - mounted on individual steam radiators by 1/8 American Standard taper pipe thread connection.

Valve types

Type	Designation
I	Nonadjustable vent
II	Adjustable vent (adjustable by use of a tool only)

NOTE: Rating and temperature equilibrium characteristics are specified with type I valve at normal fixed vent setting and with type II valve at maximum vent setting.

Certification. The contractor shall certify that the product offered meets the salient characteristics of this description and, that the product conforms to the producer's own drawings, specifications, standards, and quality assurance practices and is the same product offered for sale in the commercial marketplace. The Government reserves the right to require proof of such conformance prior to first delivery and thereafter as may be otherwise provided for under the provisions of the contract.

Recovered materials. The manufacturer shall utilize recovered materials to the maximum extent practicable.

Packaging, packing, and marking. The packaging and packing shall be in accordance with normal commercial practice and shall assure acceptance by common carrier and provide product protection against loss and damage during multiple shipments, handling, and storage. The shipping container shall be in compliance with the National Motor Freight Classification and Uniform Freight Classification. Marking shall be as specified in the contract or order.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T08:06Z
Check the source to verify that this is the current version before use.