MILITARY SPECIFICATION

VALVE, QUICK-CLOSING, FOR FUEL OIL AND AUXILIARY STEAM EMERGENCY SHUTDOWN

This specification is approved for use by the Naval Sea Systems Command and is available for use by all Departments and Agencies of the Department of Defense.

1. SCOPE

1.1 Scope. This specification covers a flanged, one-way, quick-closing valve for fuel oil up to 1000 pounds per square inch (lb/in^2) at ambient temperature, and auxiliary steam service at 600 lb/in^2 and 775°F.

1.2 Classification. Valves shall be classified in accordance with the types and rating (see 1.2.1 and 1.2.2), as specified (see 6.2.1).

1.2.1 Types. Valves shall be of the following types, as specified (see 6.2.1):

Type I - Steel, flanged.
Type II - Bronze, flanged.

1.2.2 Rating. Type I valves shall be class 600, sized 2 inches and less in accordance with ANSI B16.34, and type II valves shall be class 150 in accordance with MIL-F-20042 (see 6.2.1).

2. APPLICABLE DOCUMENTS

2.1 Issues of documents. The following documents, of the issue in effect on date of invitation for bids or request for proposal, form a part of this specification to the extent specified herein.

SPECIFICATIONS

FEDERAL

QQ-C-390 - Copper Alloy Castings (Including Cast Bar).
QQ-C-591 - Copper-Silicon, Copper-Zinc-Silicon, and Copper-Nickel-Silicon Alloys: Rod, Wires, Shapes, Forgings, and Flat Products, (Flat Wire, Strip, Sheet, Bar and Plate).
QQ-N-281 - Nickel-Copper Alloy Bar, Rod, Plate, Sheet, Strip, Wire, Forgings, and Structural and Special Shaped Sections.
QQ-N-286 - Nickel-Copper-Aluminum Alloy, Wrought.
QQ-S-763 - Steel Bars, Wire, Shapes, and Forgings, Corrosion-Resisting.

MILITARY

MIL-V-3 - Valves, Fittings, and Flanges (Except for Systems Indicated Herein); Packaging of.
MIL-R-196 - Repair Parts for Internal Combustion Engines, Packaging of.
MIL-S-901 - Shock Tests, H.I. (High-Impact); Shipboard Machinery, Equipment and Systems, Requirements for.
MIL-B-16541 - Bronze, Valve: Castings.
MIL-R-17131 - Rods and Powders, Welding, Surfacing.
MIL-F-20042 - Flanges, Pipe, Bronze (Silver Brazing).
MIL-G-21032 - Gaskets, Metallic-Asbestos, Spiral Wound.
MIL-B-24480 - Bronze, Nickel-Aluminum Castings, For Seawater Service.
MIL-I-45208 - Inspection System Requirements.

Beneficial comments (recommendations, additions, deletions) and any pertinent data which may be of use in improving this document should be addressed to: Commander, Naval Ship Engineering Center, SEC 6124, Department of the Navy, Washington, DC 20362 by using the self-addressed Standardization Document Improvement Proposal (DD Form 1426) appearing at the end of this document or by letter.

Source: https://assist.dla.mil -- Downloaded: 2026-10-19T23:02Z
Check the source to verify that this is the current version before use.

STANDARDS

MILITARY

MIL-STD-105 - Sampling Procedures and Tables for Inspection by Attributes.
MIL-STD-167-1 - Mechanical Vibrations of Shipboard Equipment (Type I - Environmental and Type II - Internally Excited).
MIL-STD-278 - Fabrication Welding and Inspection; and Casting Inspection and Repair for Machinery, Piping and Pressure Vessels in Ships of the United States Navy.
MIL-STD-798 - Nondestructive Testing, Welding, Quality Control, Material Control and Identification and HI-Shock Test Requirements for Piping System Components for Naval Shipboard Use.

DRAWING

MILITARY

NAVSHIPS 803-1385541 - Valves, Bronze Flanged, Globe, Angle and Cross, Stop and Stop Check, B-135: Steam Service at 100 Psi at 425° Max.

(Copies of specifications, standards, drawings, and publications required by contractors in connection with specific procurement functions should be obtained from the procuring activity or as directed by the contracting officer.)

2.2 Other publications. The following documents form a part of this specification to the extent specified herein. Unless otherwise indicated, the issue in effect on date of invitation for bids or request for proposal shall apply.

AMERICAN NATIONAL STANDARDS INSTITUTE (ANSI)

B1.12 - Class 5 Interference - Fit Thread.
B16.5 - Steel Pipe Flanges, Flanged Valves, and Fittings.
B16.10 - Face-to-Face and End-to-End Dimensions of Ferrous Valves.
B16.34 - Steel Butt - Welding End Valves.
B18.2.1 - Square and Hex Bolts and Screws, Including Askew Head Bolts, Hex Cap Screws, and Lag Screws.
B18.3 - Socket Cap, Shoulder, and Set Screws.

(Application for copies should be addressed to the American National Standards Institute, 1430 Broadway, New York, New York 10018.)

AMERICAN SOCIETY FOR TESTING AND MATERIALS (ASTM)

A105 - Forgings, Carbon Steel, for Piping Components.
A182 - Forged or Rolled Alloy-Steel Pipe Flanges, Forged Fittings, and Valves and Parts for High-Temperature Service.
A193 - Alloy-Steel and Stainless Steel Bolting Materials for High-Temperature Service.
A194 - Carbon and Alloy Steel Nuts for Bolts for High-Pressure and High-Temperature Service.
A479 - Stainless and Heat-Resisting Steel Bars and Shapes for Use in Boilers and Other Pressure Vessels.
A567 - Iron, Cobalt, and Nickel Base Alloy Castings for High Strength at Elevated Temperatures.
A582 - Free-Machining Stainless and Heat-Resisting Steel Bars, Hot-Rolled or Cold-Finished.
B61 - Steam or Valve Bronze Castings.

(Application for copies should be addressed to the American Society for Testing and Materials, 1916 Race Street, Philadelphia, Pennsylvania 19103.)

AMERICAN IRON AND STEEL INSTITUTE (AISI)

Steel Products Manual.

(Application for copies should be addressed to the American Iron and Steel Institute, 1000 16th Street NW, Washington, DC 20036.)

(Technical society and technical association specifications and standards are generally available for reference from libraries. They are also distributed among technical groups and using Federal agencies.)

Source: https://assist.dla.mil -- Downloaded: 2026-10-19T23:02Z
Check the source to verify that this is the current version before use.

3. REQUIREMENTS

3.1 Sample for first article inspection. Prior to beginning production a sample shall be examined and tested as specified in 4.3 (see 6.3).

3.2 Materials. Materials shall be as specified in table I, or where not specified, shall be of the best commercial grade and suitable for the purpose intended. Scrap metal shall be used to the maximum extent practicable in the form of reclaimed materials provided the material is properly recovered. Proper recovery shall be interpreted to mean the smelting of the scrap materials to produce the chemical and physical properties required by the applicable material specification.

TABLE I. Materials.

Part	Material form	Applicable documents	
		Type I valves	Type II valves
Body and bonnet	Forgings and castings	ASTM A105; ASTM A216, grade WCB	ASTM B61; QQ-C-390, alloy 903 or 922; MIL-B-24480 or MIL-B-16541
Gaskets	Spiral wound, metal crush elastomer	MIL-G-21032, type I; metal, commercial	Commercial
Pressure boundary penetration seal	Bellows; plastic, metallic; plastic non-metallic	Commercial	Commercial
Seats, discs or seat and disc facings	Hard-facing, investment cast or bar stock	MIL-R-17131, type MIL-RCoCr-A, or ASTM A567, GR 1	QQ-N-281; QQ-N-286
Stems or pressure boundary penetration rods	Forged or rolled	ASTM A182, GR F6; ASTM A582, type 416; QQ-S-763, class 410; AISI 410 or 416; ASTM A479, type 410	QQ-N-281; QQ-N-286
Studs, cap screws and through-bolts		ASTM A193, grades B7 and B16	QQ-N-281; QQ-N-286; QQ-C-591
Nuts for pressure containment	Heavy semi-finished hexagon; carbon and alloy steel for temperature bolting	ASTM A194, grades 2, 2H and 4	QQ-N-281; QQ-N-286; QQ-N-591

3.3 Design. Design features shall be as specified in 3.3.1 through 3.3.13.2.

3.3.1 The valve shall be capable of being actuated locally and remotely.

3.3.2 The valve shall be actuated by a single acting mechanism.

3.3.3 The valve shall have a maximum closing time of 1 second.

3.3.4 The valve shall have an anti-slamming feature.

3.3.4.1 The anti-slamming feature (see 3.3.4) shall not prevent tight closure of the valve due to contaminants normally found in fuel and steam lines.

Source: https://assist.dla.mil -- Downloaded: 2026-10-19T23:02Z
Check the source to verify that this is the current version before use.

3.3.5 The valve shall be actuated by a distinct positive pull motion. An actuating motion requiring the operator to hold the lever at the tripped position or prior to the tripped position to effect actuation is prohibited.

3.3.6 Valve shall be a design that does not require disconnecting the remote cable to reset the actuating mechanism.

3.3.7 The valve shall be reset open by conventional valve motions, such as lifting of the stem, turning of a handwheel, or pulling of a lever.

3.3.7.1 Where the rotational motion to reset the valve requires initially turning the handwheel clockwise to engage a latch to permit subsequent counterclockwise action to open and reset the valve, the mechanism shall be rugged or protected. This actuating mechanism shall be sufficiently strong so that valves will not be damaged by improper turning of the handwheel by one man without the use of mechanical assistance.

3.3.7.1.1 Where the valve design requires initial counterclockwise rotational motion to reset the valve, the resetting instructions shall be forged or cast into the handwheel, or shall have an instruction plate permanently attached to the valve.

3.3.8 The valve shall have a positive means of preventing any shaft penetrating the pressure boundary from being removed through the boundary during operating conditions.

3.3.9 The valve shall have a position indicator.

3.3.10 Threaded fasteners for pressure containing parts shall be any of the following:

(a) Through-bolts threaded the entire length and fitted with a nut on each end. Threads on the bolts and nuts shall be class 2 fit.
(b) Tap end studs with interference class 5 fit at tap end and a class 2 fit at nut end. Stud engagement length shall be in accordance with ANSI B1.12.
(c) Hex head cap screws in accordance with ANSI B18.2.1 or hexagon socket head cap screws in accordance with ANSI B18.3. The cap screws shall be engaged a minimum of one diameter length of fully formed threads.

3.3.11 Size of handwheel. The valve handwheel shall be sized so that a tangential force of not more than the value specified in table II is required to be exerted on the rim of the handwheel to reset the valve against a differential pressure of 1000 lb/in^2. The valve lever, where used, shall be so sized that the length is equal to the diameter of handwheels in table II, and the force does not exceed the force required for the handwheel.

TABLE II. Maximum allowable tangential force to seat valve based on valve handwheel size.

Handwheel diameter	Tangential force
Inches	Pounds
2 and below	90
3	98
4	106
5	112
6	118
7	121
8	124
9	127
10	130
11	133
12	135
14	138
16	141
18	144
21	147
24	150
27	150
30	150
36	150

Source: https://assist.dla.mil -- Downloaded: 2026-10-19T23:02Z
Check the source to verify that this is the current version before use.

3.3.12 Type I. Additional design features for type I valves shall be as specified in 3.3.12.1 through 3.3.12.3.

3.3.12.1 The valve shall have face-to-face and center-to-face dimensions in accordance with ANSI B16.10, class 600 globe valves. Flanges shall be in accordance with ANSI B16.5, class 600.

3.3.12.2 The body and bonnet or cover materials shall be in accordance with table I.

3.3.12.3 The valve seat and disc seating surfaces shall be hard-faced in accordance with table I.

3.3.13 Type II. Additional design features for a type II valve shall be as specified in 3.3.13.1 and 3.3.13.2.

3.3.13.1 The valve shall have flanges in accordance with MIL-F-20042, class 150. The valve shall have face-to-face and center-to-face dimensions in accordance with Drawing 803-1385541.

3.3.13.2 The body and bonnet or cover materials shall be in accordance with table I.

3.4 Shock. The valve shall withstand the requirements of grade A, class I, type C shock in accordance with MIL-S-901, and MIL-STD-798.

3.5 Vibration. The valve shall withstand the requirements of vibration tests in accordance with MIL-STD-167-1, type I.

3.6 Structural soundness.

3.6.1 A type I valve shall withstand the hydrostatic shell test pressures in accordance with ANSI B16.34.

3.6.2 A type II valve shall withstand hydrostatic shell test pressures of 225 lb/in^2.

3.7 Line pressure. The valve shall be capable of being opened against a line pressure of 1000 lb/in^2 fuel or 600 lb/in^2 steam for type I valves, and 150 lb/in^2 for a type II valve without the aid of an external equalizing bypass.

3.8 Welding. Welding shall be in accordance with MIL-STD-278. Special welding techniques shall not be used unless specifically accepted by the Naval Ship Engineering Center (NAVSEC).

3.9 Threads. Pipe plugs and mating threads or threaded components, where used, shall have straight machined threads.

3.10 Impregnation, where required, shall be in accordance with MIL-STD-278.

3.11 The valve shall be capable of operating for 1,000 cycles minimum without the replacement of parts or adjustments.

3.12 Seat leakage. The valve shall have a maximum initial seat leakage of 10 cubic centimeters per hour (cm^3/h) per inch of nominal size for a valve 1 inch and larger, and 10 cm^3/h total for a valve less than 1 inch in size. The test shall be conducted at 1,000 lb/in^2 for a type I valve and 150 lb/in^2 for a type II valve. The testing medium shall be clean tap water with no additives other than mineral cutting oil or clean hydraulic oil with no suspensions.

3.13 Marking.

3.13.1 Body marking. The valve body shall be marked with a flow direction indicator, the pressure rating, and the manufacturer's name or trademark etched, stamped or cast integral with the body.

3.13.2 Identification plates. The valve shall have an identification plate made of corrosion resistant steel, anodized aluminum or brass. The identification plate shall be permanently fastened to a part of the valve not subjected to the working pressure or to the edge of a flange. The identification plate shall include the following information:

(a) Manufacturer's name or trademark.
(b) Size of valve and rating.

Source: https://assist.dla.mil -- Downloaded: 2026-10-19T23:02Z
Check the source to verify that this is the current version before use.

(c) Body and bonnet or cover composition.
(d) Manufacturer's identification number.
(e) Specification MIL-V-24569.
(f) Allowance parts list number (APL), if known.

3.14 Repair parts and special tools. Installation and maintenance of valves shall be accomplished with standard tools, unmodified in any way. Special tools shall not be required to install or service the valve. Special tools are defined as those tools not listed in the National Supply Catalog (copies of this catalog may be consulted in the office of the Defense Contract Administration Service (DCAS)). Convenience tools may be used.

3.14.1 Repair parts shall be as specified in table III and shall be shipped as onboard repair parts upon receipt of stock numbers from the command or agency concerned.

TABLE III. Repair parts.

Item	Quantities
Packing and gaskets	50 percent of total order but not less than two sets for each size, composition and pressure rating.
Other part	As recommended by manufacturer

3.15 Technical data. The contractor shall prepare the following technical data in accordance with the data ordering documents included in the contract or order (see 6.2.2) and as specified in 3.15.1 through 3.16.

3.15.1 Drawings. The contractor shall prepare drawings in accordance with the data ordering document (see 6.2.2), and shall include the following information:

(a) Accurately scaled sectional assembly which clearly depicts the design and construction of the valve.
(b) Bill of material listing specification, grade, condition, and any other data required to fully identify the properties of the materials proposed.
(c) Details of the seat, disc, and stem assembly and all other replaceable internal trim.
(d) Layout of the pressure-containing envelope (body, bonnet, and bottom cap) giving dimensions which control compression of the spiral-wound gaskets. This is to assure that where remachining is necessary to repair the gasket-sealing surfaces on these parts, that compensating cuts can be accurately made to restore original gasket compression. This layout shall also specify the dimensional limits of such corrective remachining within which function of the valve remains unaffected.
(e) Recommended assembly torques, or equivalent procedures, for making up all joints and threaded assemblies.
(f) Tabulation of required gasket characteristics including all dimensions (with tolerances) and load versus compression characteristics (with tolerances).

3.16 Technical manuals. When required (see 6.2.1), the contractor shall prepare technical manuals in accordance with the data ordering document (see 6.2.2).

Source: https://assist.dla.mil -- Downloaded: 2026-10-19T23:02Z
Check the source to verify that this is the current version before use.

4. QUALITY ASSURANCE PROVISIONS

4.1 Responsibility for inspection. Unless otherwise specified in the contract, the contractor is responsible for the performance of all inspection requirements, as specified herein. Except as otherwise specified in the contract, the contractor may use his own or any other facilities suitable for the performance of the inspection requirements specified herein, unless disapproved by the Government. The Government reserves the right to perform any of the inspections set forth in the specification where such inspections are deemed necessary to assure supplies and services conform to prescribed requirements.

4.1.1 Inspection system. The contractor shall provide and maintain an inspection system acceptable to the Government for supplies and services covered by this specification. The inspection system shall be in accordance with MIL-I-45208 (see 6.2.1).

4.1.2 Pressure containing parts shall be examined to determine conformance with applicable specifications.

4.1.3 The DCAS may accept certification that non-pressure containing parts conform to their applicable material specification providing that such certification contains the actual test, examination or other verifiable data.

4.2 Classification of inspections. The inspection requirements specified herein are classified as follows:

(a) First article inspection (see 4.3).
(b) Quality conformance inspection (see 4.4).

4.3 First article inspection. First article inspection shall consist of the examination specified in 4.5 and the tests specified in 4.6.1 through 4.6.6.

4.4 Sampling for quality conformance inspection.

4.4.1 Lot. Valves of the same composition, pressure rating, size and construction offered for delivery at the same time shall be considered a lot for purposes of sampling.

4.4.2 Sampling for examination of end item. Sampling for the examination specified in 4.5.1 and 4.5.2 shall be conducted in accordance with MIL-STD-105. The acceptance quality levels (AQL), expressed in defects per hundred units (DHU) and the inspection levels shall be as shown in table IV.

TABLE IV. Sampling for examination of end item.

	Inspection levels	AQL's
		Major
Visual examination (see 4.5.1)	II	2.5
Dimensional examination (see 4.5.2)	II	2.5

4.4.3 Tests. Each valve shall be tested as specified in 4.7.

4.5 Examination.

4.5.1 Visual examination. Sample valves shall be visually examined in accordance with table V.

Source: https://assist.dla.mil -- Downloaded: 2026-10-19T23:02Z
Check the source to verify that this is the current version before use.

TABLE V. Classification of defects.

Categories	Defects
Critical	None defined
Major	
	Design and construction
101	Not design specified
102	Not material specified
103	Component missing or damaged
104	Not assembled correctly
	Workmanship
105	Poor assembly
106	Bonnet not properly alined
107	Welding not properly fused or inadequate
108	Poor finish on machining
Minor	
	Identification and marking
201	Improper, missing or illegible

4.5.2 Dimensional examination. Sample valves shall be examined to determine conformance with the dimensional requirements specified herein. Any deviation from the specified tolerances shall constitute a defect. Any dimensional defect for pressure containing parts shall constitute a major defect.

4.6 Tests.

4.6.1 Life cycle. The valve shall be cycled 1,000 times from full open to full closed by tripping. During the test, the mechanisms shall not be adjusted or parts replaced.

4.6.1.1 The valve shall be pressurized each cycle to 1,000 lb/in^2 for type I valves and 150 lb/in^2 for type II valves.

4.6.2 Shock. The valve shall be shock tested to assure compliance with the requirements specified in 3.4.

4.6.3 Vibration. The valve shall be vibration tested to assure compliance with the requirements specified in 3.5.

4.6.4 Shell test. The valve shall be subjected to pressures specified in 3.6.1 and 3.6.2 for a duration of 1 minute minimum. The fluid temperature shall not exceed 100°F. Any weeping, leakage, or permanent deformation shall be cause for rejection. The valve shall be open and shall not be back-seated. Slight leakage past the packing of stuffing boxes shall not be cause for rejection.

4.6.5 Seat tests (tightness). The valve shall be pressurized from the side tending to close the valve. The valve shall be examined for seat tightness. Test pressure shall be 1,000 lb/in^2 for type I valves and 150 lb/in^2 for type II valves. The testing medium shall be clean tap water with no additive other than mineral cutting oil at temperatures not more than 100°F. Duration of test shall be 1 minute (minimum). There shall be no visible signs of leakage. Should there be any visible leakage, this test shall be continued for the length of time required to accurately determine the rate of leakage. Leakage shall not exceed 10 cm^3/h per inch of nominal pipe size. For valves less than 1 inch in size the leakage rate shall be not more than 10 cm^3/h.

4.6.6 Upon completion of the cyclic tests, the valve shall be repressurized in accordance with 4.6.4 to assure continued integrity of the assembly and shall be seat tightness tested in accordance with 4.6.5 to determine the change in leakage rate during testing.

4.7 Production tests. Each valve shall be shell tested in accordance with 4.6.4 and seat tested in accordance with 4.6.5.

Source: https://assist.dla.mil -- Downloaded: 2026-10-19T23:02Z
Check the source to verify that this is the current version before use.

4.8 Inspection of preparation for delivery requirements. Sample packs and the inspection of packaging, packing and marking for shipment and storage shall be in accordance with the requirements of section 5 and the documents specified therein.

5. PREPARATION FOR DELIVERY

(The preparation for delivery requirements specified herein apply only for direct Government procurements. For the extent of applicability of the preparation for delivery requirements of referenced documents listed in section 2, see 6.4.)

5.1 Preservation-packaging, packing and marking. Valves shall be individually preserved-packaged level A or C, packed level A, B or C as specified (see 6.2.1) and marked in accordance with MIL-V-3.

5.2 Repair parts. Unless otherwise specified (see 6.2.1), repair parts shall be preserved-packaged, packed and marked in accordance with the levels of MIL-R-196 as applicable for the intended use and destination as follows:

	Levels	
	Preservation-packaging	Packing
Onboard (accompanying valves)	A	C
Stock	A	B
Immediate use	C	C

Unless otherwise specified (see 6.2.1), repair parts shall be packed separately and shipped concurrently with the valve(s).

5.3 Cushioning, dunnage and wrapping materials.

5.3.1 Level A preservation-packaging and levels A and B packing. Use of all types of loose-fill materials for packaging and packing applications such as cushioning, filler or dunnage is prohibited for materials destined for shipboard installation/stowage.

5.3.2 Level C preservation-packaging and packing. When loose fill type materials are used for packaging and packing applications such as cushioning, filler and dunnage, all containers (unit, intermediate and shipping) shall be marked or labelled with the following information:

"CAUTION

Contents cushioned etc., with loose-fill material. Not to be taken aboard ship. Remove and discard loose-fill material before shipboard stowage. If required, recushion with cellulosic material, bound fiber, fiberboard or transparent flexible cellular material."

5.3.3 Cushioning, filler, dunnage and wrapping materials selected, whenever available, shall exhibit improved performance for resistance to fire.

6. NOTES

6.1 Intended use. Valves covered by this specification are intended for steam and oil service.

6.2 Ordering data.

6.2.1 Procurement requirements. Procurement documents should specify the following:

(a) Title, number and date of this specification.
(b) Type, class, and size of valve required (see 1.2, 1.2.1, and 1.2.2).
(c) Quantity required.
(d) Service conditions.
(e) When technical manuals are required (see 3.16).
(f) Quality assurance requirements (see 4.1.1).
(g) Method of preservation, packaging, and packing required (see 5.1 and 5.2).
(h) Levels other than specified (see 5.2).

Source: https://assist.dla.mil -- Downloaded: 2026-10-19T23:02Z
Check the source to verify that this is the current version before use.

6.2.2 Data requirements. When this specification is used in a procurement which invokes the provision of the "Requirements for Data" of the Armed Services Procurement Regulations (ASPR), the data identified below, which are required to be developed by the contractor, as specified on an approved Data Item Description (DD Form 1664), and which are required to be delivered to the Government, should be selected and specified on the approved Contract Data Requirement List (DD Form 1423) and incorporated in the contract. When the provisions of the "Requirements for Data" of the ASPR are not invoked in a procurement, the data required to be developed by the contractor and required to be delivered to the Government should be selected from the list below and specified in the contract.

Paragraph	Data requirements	Applicable DID	Option
3.15.1	Drawings, engineering and associated lists	DI-E-7031	Level 2 (production prototype and limited production) Design activity designation-contractor Design number - contractor
3.16	Manual, technical, standard	DI-M-2044	Type I of MIL-M-15071

(Copies of data item descriptions required by the contractors in connection with specific procurement functions should be obtained from the procuring activity or as directed by the contracting officer. Unless otherwise indicated, the issue on date of invitation for bids or request for proposal shall apply.)

6.2.2.1 The data requirements of 6.2.2 and any task in section 3, 4, or 5 of the specification required to be performed to meet a data requirement may be waived by the procuring/purchasing activity upon certification by the offeror that identical data were submitted by the offeror and accepted by the Government under a previous contract for identical item procured to this specification. This does not apply to specific data which may be required for each procurement regardless of whether an identical item has been supplied previously (for example, test reports).

6.2.2.2 Where the Government has limited rights in the data shown on the drawings, as determined by the contractual provisions regarding rights in technical data, the drawings may be marked with a legend. If used, the "Limited Rights Legend" of ASPR should be used.

6.3 First article inspection. Invitations for bids should provide that the Government reserves the right to waive the requirement for samples for first article inspection as to those bidders offering a product which has been previously procured or tested by the Government, and that bidders offering such products, who wish to rely on such production or test, must furnish evidence with the bid that prior Government approval is presently appropriate for the pending procurement.

6.4 Sub-contracted material and parts. The preparation for delivery requirements of referenced documents listed in section 2 do not apply when material and parts are procured by the contractor for incorporation into the equipment and lose their separate identity when the equipment is shipped.

Preparing activity:
Navy - SH
(Project 4820-N376)

Source: https://assist.dla.mil -- Downloaded: 2026-10-19T23:02Z
Check the source to verify that this is the current version before use.

STANDARDIZATION DOCUMENT IMPROVEMENT PROPOSAL

OMB Approval
No. 22-R255

INSTRUCTIONS: The purpose of this form is to solicit beneficial comments which will help achieve procurement of suitable products at reasonable cost and minimum delay, or will otherwise enhance use of the document. DoD contractors, government activities, or manufacturers/ vendors who are prospective suppliers of the product are invited to submit comments to the government. *Fold on lines on reverse side,* staple in corner, and send to preparing activity. Comments submitted on this form do not constitute or imply authorization to waive any portion of the referenced document(s) or to amend contractual requirements. Attach any pertinent data which may be of use in improving this document. If there are additional papers, attach to form and place both in an envelope addressed to preparing activity.

DOCUMENT IDENTIFIER AND TITLE: MIL-V-24569

NAME OF ORGANIZATION AND ADDRESS

CONTRACT NUMBER

MATERIAL PROCURED UNDER A

☐ DIRECT GOVERNMENT CONTRACT ☐ SUBCONTRACT

1. HAS ANY PART OF THE DOCUMENT CREATED PROBLEMS OR REQUIRED INTERPRETATION IN PROCUREMENT USE?
   A. GIVE PARAGRAPH NUMBER AND WORDING.

   B. RECOMMENDATIONS FOR CORRECTING THE DEFICIENCIES

2. COMMENTS ON ANY DOCUMENT REQUIREMENT CONSIDERED TOO RIGID

3. IS THE DOCUMENT RESTRICTIVE?
   ☐ YES ☐ NO *(If "Yes", in what way?)*

4. REMARKS

SUBMITTED BY *(Printed or typed name and address - Optional)*

TELEPHONE NO.

DATE

DD FORM 1 JAN 72 1426 REPLACES EDITION OF 1 JAN 66 WHICH MAY BE USED S/N 0102-014-1802

Source: https://assist.dla.mil -- Downloaded: 2026-10-19T23:02Z
Check the source to verify that this is the current version before use.