MILITARY SPECIFICATION

RELAY, ALTERNATING CURRENT, POWER-SENSING

This specification is approved for use by the Naval Sea Systems Command and is available for use by all Departments and Agencies of the Department of Defense.

1. SCOPE

1.1 This specification covers alternating current (a.c.), power-sensing relays (see 6.4.1) using electromagnetic devices or solid state circuitry, or a combination of both, for use on Naval ships (see 6.1).

2. APPLICABLE DOCUMENTS

2.1 Issues of documents. The following documents, of the issue in effect on date of invitation for bids or request for proposal, form a part of the specification to the extent specified herein.

SPECIFICATIONS

MILITARY

MIL-I-631 - Insulation, Electrical, Synthetic-Resin Composition, Nonrigid.
MIL-S-901 - Shock Tests H.I. (High Impact) Shipboard Machinery, Equipment and Systems, Requirements for.
MIL-E-917 - Electrical Power Equipment, Basic Requirements for (Naval Shipboard Use).
MIL-E-2036 - Enclosures for Electric and Electronic Equipment, Naval Shipboard.
MIL-C-2212 - Controllers, Electric Motor, A.C. or D.C. and Associated Switching Devices, Naval Shipboard.
MIL-E-17555 - Electronic and Electrical Equipment, Accessories, and Repair Parts; Packaging and Packing of.
MIL-R-19523 - Relays, Control, Naval Shipboard.

STANDARDS

MILITARY

MIL-STD-167-1 - Mechanical Vibrations of Shipboard Equipment (Type I - Environmental and Type II - Internally Excited).
MIL-STD-454 - Standard General Requirements for Electronic Equipment.
MIL-STD-740 - Airborne and Structureborne Noise Measurements and Acceptance Criteria of Shipboard Equipment.
MIL-STD-1399, Section 103 - Interface Standard for Shipboard Systems-Electric Power, Alternating Current.

PUBLICATIONS

MILITARY

NAVSEA 0969-LP-019-7000 - Electronic Test Equipment Application Guide.

(Copies of specifications, standards, drawings, and publications required by contractors in connection with specific procurement functions should be obtained from the procuring activity or as directed by the contracting officer.)

2.2 Other publications. The following document forms a part of this specification to the extent specified herein. Unless otherwise indicated, the issue in effect on date of invitation for bids or request for proposal shall apply.

Beneficial comments (recommendations, additions, deletions) and any pertinent data which may be of use in improving this document should be addressed to: Commander, Naval Ship Engineering Center, SEC 6124, Department of the Navy, Washington, DC 20362 by using the self-addressed Standardization Document Improvement Proposal (DD Form 1426) appearing at the end of this document or by letter.

FSC 5945

Source: https://assist.dla.mil -- Downloaded: 2026-10-19T23:00Z
Check the source to verify that this is the current version before use.

NATIONAL ELECTRICAL MANUFACTURERS ASSOCIATION (NEMA)
ICS - Industrial Controls and Systems.

(Application for copies should be addressed to the National Electrical Manufacturers Association, 155 East 44th Street, New York, NY 10017.)

(Technical society and technical association specifications and standards are generally available for reference from libraries. They are also distributed among technical groups and using Federal agencies.)

3. REQUIREMENTS

3.1 Sample for first article inspection. Prior to beginning production a sample power-sensing relay (hereinafter referred to as relay) shall be examined and tested as specified in 4.3 (see 6.3).

3.2 General requirements. Relay shall be in accordance with the requirements of MIL-E-917, except the following paragraphs, in addition to the requirements specified herein. (Whenever a requirement of MIL-E-917 conflicts with a requirement of this specification, the requirement of this specification shall govern.) The following requirements of MIL-E-917 are not applicable unless required by the procurement document:

(a) Piping systems.
(b) Equipment cooled by forced air.
(c) Equipment cooled by water.

3.2.1 Characteristics. Relay shall have the following characteristics, as specified (see 6.2.1):

(a) Relay shall sense real power from a 3-phase, 3-wire, 60 hertz (Hz) circuit and change contact position when preset actuation conditions are met.
(b) Power input to the relay shall consist of the voltage output of potential transformers providing 115 volt, 3-phase signal for the relay voltage coils and current signals from two current transformers, one in phase AB and one in phase CA for the current coils of the relay or as otherwise specified (see 6.2.1).
(c) Relay shall have two normally open and two normally closed contacts (see 6.4.2) with a contact rating of 10 amperes at 450 volts, 60 Hz. The contacts shall be electrically insulated from each other and from the relay input (see 3.2.8).
(d) Relay shall operate in an electric power system with characteristics of type I, 60 Hz power as defined by MIL-STD-1399, section 103. Relay shall not be damaged nor shall have false operations caused by transients or other characteristics of a type I power system as defined in MIL-STD-1399, section 103. Momentary short circuit power may be applied to the relay sensing circuit if a fault occurs.
(e) Power level to actuate the relay shall be adjustable in 5 percent increments (or less) or continuously adjustable between 80 and 150 percent of rated power. Adjustment markings shall be provided to approximate the adjustment setting. Relay shall reset to the normal condition when power to the relay is reduced to 75 ± 5 percent of the set trip point. The trip and reset values shall not vary more than 5 percent of the set value (average of ten operating cycles). Calibration shall be at 40°C ambient temperature. Operating point shall not change more than 3 percent of set value for each 10°C change in ambient temperature between 10°C and 70°C.
(f) Relay shall be provided with adjustable time delay to occur after power reaches the actuating level. The time delay shall be adjustable from zero (no intentional delay) time delay to 20 second time delay in increments of 1 second or less.

Source: https://assist.dla.mil -- Downloaded: 202610-19T23:00Z
Check the source to verify that this is the current version before use.

3.2.2 Temperature rise (see 6.4.3). Temperature rise shall not exceed the values shown in table I.

TABLE I. Maximum permissible temperature based on an ambient temperature of 65°C.

Name of part	Temperature rise °C
Bolted connections and terminal studs:	
Not silver plated	35
Silver plated	50
Shunt coils:	
Class B insulation 1/	55
Class F insulation 1/	75
Class H insulation 1/	100
Class N insulation 1/	115
Contacts:	
Solid	55
Solid silver faced	65
Capacitors - air within 1/2 inch of case	20
Semiconductors:	
Calculated peak junction temperature rise for discrete devices	T_m 2/ -90
Integrated circuit devices	T_m 2/ -115

1/ Measured by resistance method.

2/ Rated maximum operating junction temperature of the particular devices.

3.2.3 Ambient temperature (see 6.4.4). Unless otherwise specified (see 6.2.1), relay shall be designed for an ambient temperature of 65°C.

3.2.4 Endurance. The current interrupting portion of the relay (contacts) shall have a minimum life of 25,000 operations at rated conditions. In addition the current interruption portion of the relay shall be capable of 100 operations interrupting 150 percent rated current. Relay shall withstand the endurance operations defined in 4.7.3 without failure.

3.2.5 Vibration. Relay shall meet the requirements for type I of MIL-STD-167-1, except as specified in 4.7.4.

3.2.6 Shock. Relay shall withstand the shock test specified in 4.7.5.

3.2.7 Inclination. Relay shall operate satisfactorily under inclined conditions defined in MIL-E-917.

3.2.8 Insulation resistance. Insulation resistance between input circuits and output circuits, between different output circuits and between input, output circuits and ground shall be not less than 10 megohms when corrected to 25°C and measured by a 500 volt insulation resistance tester.

3.2.9 Dielectric withstanding voltage. Relay shall conform to the dielectric requirements specified in NEMA Standard ICS, section 1-109.05.

3.2.10 Duty. Relay shall be designed for continuous duty.

3.2.11 Wiring. Permanent internal wiring and connection shall be in accordance with MIL-E-917.

3.2.11.1 External cable connections. A terminal block shall be provided for all external connections to the relay.

3.2.12 Mounting. Components of the relay shall be mounted on a panel as a complete unit including connection block for connection to external circuits. Provisions shall be made for mounting the panel in the structure or panel of a switchboard.

3.2.13 Connection diagram. Each relay shall include a connection diagram identifying input and output connections and their characteristics.

Source: https://assist.dla.mil -- Downloaded: 20261O-19T23:00Z
Check the source to verify that this is the current version before use.

3.2.14 Power factor. Relay shall operate on input power levels within the limits specified in 3.2.1 (e) at lagging power factors from 0.6 to 1.00.

3.3 Detail requirements.

3.3.1 Electro-mechanical relays, when used, shall conform to MIL-C-2212 or category A or B, class I of MIL-R-19523.

3.3.2 Enclosures. Relay will normally be provided without an enclosure. When an enclosure is required, the type of enclosure shall be as specified (see 6.2.1) and the enclosure shall be in accordance with MIL-E-2036.

3.4 Noise. When specified (see 6.2.1), relays for low noise applications shall meet the requirements for type 3, grade C equipment of MIL-STD-740.

3.5 Safety. Electrical safety shall be in accordance with requirement 1 of MIL-STD-454.

3.6 Painting. Parts not fabricated of a corrosion-resisting material or having a corrosion-resistant treatment as defined in MIL-E-917 shall be painted as specified in MIL-E-917. Touching-up shall be permitted for marks or scratches due to assembly, testing, or other handling.

3.7 Identification plates. Each relay shall be provided with an identification plate containing the manufacturer's name, catalog number, National stock number (NSN) if specified (see 6.2.1), voltage and current input, and contact rating and characteristics. The preferred location is on the front of the panel, however, the identification plate shall be visible from the front of the relay without moving any components.

3.7.1 Identification plates shall be not less than 0.020-inch in thickness, and shall be brass, corrosion-resistant steel, or anodized aluminum, marked by etching, engraving, stamping, or photo-process. Etching, engraving, or stamping shall be not less than 0.003-inch deep. Identification plates shall be securely fastened to the relay. Where metal fasteners in accordance with MIL-E-917 are not used, adhesive-backed metal (not less than 0.010-inch in thickness) or plastic film, type G, as specified in MIL-I-631, may be used.

3.8 Repair parts. Each item of repair parts shall be suitable for direct replacement of the originally installed part in the power sensing relay. The operation of the relay in which such repair parts are installed shall be equal to the original. The word "set" as applied to any particular item in the list of repair parts shall mean the total number of such parts incorporated in the construction of one power sensing relay. Where a repair part as specified is not readily replaceable, a complete subassembly shall be furnished as a repair part. When required, the contractor shall furnish repair parts, as specified (see 6.2.1).

3.9 Technical data. The contractor shall prepare technical data in accordance with the data ordering documents included in the contract or order (see 6.2.2) and as specified in 3.9.1 and 3.9.2.

3.9.1 Drawings. In addition to the drawing content required by the data ordering document (see 6.2.2), the following features shall be included:

(a) List of material, listing the enclosure and all parts. Each item shall be identified by the catalog number assigned by the company responsible for the design of the item. Navy standard items shall be identified by the drawing number or NSN.
(b) Outline of the front and top views of the relay giving dimensions and basic construction details such as location of parts, mounting panels, main mounting brackets, and main structural features. Dimensions shall include overall size, location, and size of mounting holes, location of terminal block, etc.
(c) Connection and schematic diagrams of the circuit, including connections to associated devices. The rating of fuses shall be indicated.
(d) Description of operation of the relay.
(e) Description of adjustments which may be made on the equipment, such as the range of time and power.
(f) List of components including type, rating, identification (manufacturer and catalog or part number).
(g) List of exceptions to this specification.
(h) Descriptive data of the relay including rating, catalog number, type of enclosure (if provided).

Source: https://assist.dla.mil -- Downloaded: 20260-19T23:00Z
Check the source to verify that this is the current version before use.

(i) Weight of the complete relay.
(j) List of repair parts with piece numbers for each item, the name of each item, the quantity of each item recommended for one set of repair parts, and the manufacturer's identification for the item.

3.9.2 Technical manuals. In addition to the general requirements covered by the data ordering documents (see 6.2.2), the unique features specified in 3.9.2.1 and 3.9.2.2 shall be included.

3.9.2.1 Disassembly of the relay as illustrated in the technical manual shall not be required during validation.

3.9.2.2 Technical manual inserts. Technical manual inserts shall be furnished with each equipment unless technical manuals are being furnished. Inserts shall consist of the following minimum data:

(a) Installation and operation drawings complete with mounting dimensions, outline dimensions, schematic, and wiring information, as applicable.
(b) A list of items requiring preventative maintenance, type of maintenance required, frequency, and method of maintenance.
(c) List of tools and test equipment required for each maintenance action.
(d) Safety precautions to be observed during maintenance.
(e) List of repair parts for the equipment complete with part numbers and NSN's (if known).

4. QUALITY ASSURANCE PROVISIONS

4.1 Responsibility for inspection. Unless otherwise specified in the contract, the contractor is responsible for the performance of all inspection requirements as specified herein. Except as otherwise specified in the contract, the contractor may use his own or any other facilities suitable for the performance of the inspection requirements specified herein, unless disapproved by the Government. The Government reserves the right to perform any of the inspections set forth in the specification where such inspections are deemed necessary to assure supplies and services conform to prescribed requirements.

4.1.1 Inspection system. The contractor shall provide and maintain an inspection system in accordance with the data ordering document included in the contract or order (see 6.2.2).

4.2 Classification of inspections. The inspection requirements specified herein are classified as follows:

(a) First article inspection (see 4.3).
(b) Quality conformance inspection (see 4.5).

4.3 First article inspection. First article inspection shall consist of the examination and tests specified in table II. A set of drawings shall be furnished prior to conducting the first article inspection.

TABLE II. First article inspection.

Examination and tests	Requirement paragraph	Inspection paragraph
Examination	--	4.6
Calibration	3.2.1	4.7.1
Temperature rise	3.2.2	4.7.2
Endurance	3.2.4	4.7.3
Vibration	3.2.5	4.7.4
Shock	3.2.6	4.7.5
General operation	3.2.1	4.7.6
Inclination	3.2.7	4.7.7
Insulation resistance	3.2.8	4.7.8
Dielectric withstanding voltage	3.2.9	4.7.9
Noise (when required)	3.4	4.7.10

4.4 Order of tests. The general operation, insulation resistance, and dielectric tests shall precede and follow shock and vibration tests; the endurance test shall precede the shock test; otherwise, the order of tests shall be at the contractor's option.

Source: https://assist.dla.mil -- Downloaded: 20261O-19T23:00Z
Check the source to verify that this is the current version before use.

4.5 Quality conformance inspection.

4.5.1 Routine inspection. Each production relay shall be subjected to the routine inspection specified in table III.

4.5.2 Comparison inspection. A sample production relay shall be selected every 3 years and subjected to the comparison inspection specified in table III. Comparison inspection shall be required after any change in design which affects the performance requirements. The Naval Ship Engineering Center (NAVSEC) shall be notified of any change in design or material so a determination may be made on the extent of any verification inspection.

TABLE III. Quality conformance inspection.

Examination and tests	Routine inspection	Comparison inspection	Requirement paragraph	Inspection paragraph
Examination	X	X	--	4.6
Temperature rise	--	X	3.2.2	4.7.2
Shock	--	X	3.2.6	4.7.5
General operation	X	X	3.2.1	4.7.6
Insulation resistance	X	X	3.2.8	4.7.8
Dielectric withstanding voltage	X	X	3.2.9	4.7.9
Noise (when required)	X	--	3.4	4.7.10

4.6 Examination. Relay shall be examined to determine conformance with the following:

(a) Materials are in accordance with MIL-E-917 (see 3.2.1).
(b) Materials used agree with material list shown on drawings.
(c) Components are in accordance with requirements of this specification and the drawings.
(d) Mounting dimensions, arrangement of parts, and cable connection terminal block conform to those shown on the drawing.
(e) Parts requiring frequent replacement or service adjustment are easily accessible.
(f) Creepage and clearance distances specified in MIL-E-917 are maintained.
(g) Overall dimensions and weight conform to those shown on the drawing.
(h) Identification plates are inscribed and located as required (see 3.7).

4.7 Test procedures.

4.7.1 Calibration. Relay shall be tested to determine if calibration meets the requirements of 3.2.1 (e). Tests shall be made at the 80 percent setting, 115 percent setting, and 150 percent setting. The test at each point shall be repeated ten times with a record kept of each trip value and each reset value.

4.7.2 Temperature rise. Test methods to be employed and the precautions to be observed in conducting temperature rise tests shall be in accordance with NEMA Standard ICS, section 1-109.04, and the following:

(a) Tests shall be conducted under conditions equivalent to normal operating conditions at rated current, rated voltage, frequency and 110 percent rated current on the current coil and rated current in the normally closed contacts to determine conformance to the rises specified in 3.2.2.
(b) Tests shall be conducted with relay in its enclosure if enclosure is provided as part of the relay.
(c) The ambient temperature in the testing area shall not vary more than 10°C during the tests.

4.7.3 Endurance. Relay shall be tested to determine conformance with 3.2.4. The endurance test shall be performed for 8 hours per day with the relay in the de-energized condition for 16 hours per day. Endurance test operating cycle shall be at least 10 operating cycles per minute except that the 150 percent rated current operations shall be performed at one operation per minute 5 seconds on and 55 seconds off. The 150 percent rated current test shall be made at rated voltage and frequency. A.c. relay contacts shall be tested using 0.5 power factor, inductive load. The endurance test shall be performed by cycling the power to the relay voltage and current coils between 50 percent tripping power level and 110 percent tripping power level. The following tests shall be conducted at the end of the endurance test:

(a) Insulation resistance (see 4.7.8).

Source: https://assist.dla.mil -- Downloaded: 20260-19T23:00Z
Check the source to verify that this is the current version before use.

(b) Coil resistances.
(c) Pickup and drop out power.
(d) General operation (see 4.7.6).

4.7.4 Vibration. Relay shall be tested in accordance with MIL-STD-167-1, type I, except vibration frequency shall be from 4 to 33 Hz. Relays which will be exposed to vibration frequencies above 33 Hz shall be vibrated at frequencies through 50 Hz (see 6.2.1). Any mechanical damage, contact chatter, or electrical malfunction shall constitute a failure.

4.7.5 Shock. Relay shall be tested in accordance with MIL-S-901, grade A, class I, type C lightweight equipment and the following:

(a) Closed contacts shall not open and open contacts shall not close. Contact bounce is not permitted.
(b) Calibration of the relay shall not change more than 2 percent during the shock sequence.
(c) The relay when sensing 85 percent of rated power and set for 110 percent actuation, zero time delay, shall not actuate under the shock tests.

4.7.5.1 Method of mounting. Relay shall be mounted on standard mounting fixture 6E of MIL-S-901.

4.7.5.2 Definition of failure. The following are definitions of failure to comply with the shock tests:

(a) Breakage, crackage, or appreciable distortion of any part, including mounting holes and bolts.
(b) Failure to pass any of the routine tests as modified by 4.7.9.1.
(c) Change in calibration of the relay by more than 2 percent.
(d) Actuation of the relay i.e., change of position of contacts, closing of normally open contacts or opening of normally closed contacts for any time duration. The contact monitoring equipment shall be capable of detecting contact closing or opening of 0.001 second.

4.7.5.3 Monitoring of contacts. Contacts shall be monitored during shock to determine if open contacts close or closed contacts open. Monitoring equipment shall be capable of detecting a change in position of 1 millisecond duration. At the contractor's option, the contacts may be monitored separately or the open contacts may be wired in parallel and the closed contacts may be wired in series and monitored as a unit.

4.7.6 General operation. General operation test shall include all tests necessary to ascertain that the required operating features function properly. In particular, operation shall be checked at the lower end of the adjustment range, at the upper end, and at one value near the center of the adjustable range.

4.7.7 Inclination. Relay containing mechanically moving components shall be tested to determine conformance with the 15, 45, and 60 degrees inclined operation requirements of MIL-E-917.

4.7.8 Insulation resistance. Measuring instrument used shall have a full scale reading not exceeding 200 megohms and an open circuit voltage of 500 volts direct current (d.c.) plus or minus 10 percent. Measurements shall be made between the voltage and current coils and between the power coils and each set of contacts.

4.7.9 Dielectric withstanding voltage. Dielectric test shall be conducted to determine conformance with the requirements specified in 3.2.9. The test shall be conducted upon the completely assembled relay after completion of all other tests except shock test.

4.7.9.1 Post shock dielectric. Dielectric test shall be repeated with 65 percent test voltage.

4.7.10 Noise. When required, noise tests shall be conducted to determine conformance with the requirements specified in 3.4. Relay shall be tested while carrying normal voltage and 85 percent of rated current. The outline of the noise test facilities to be employed for structureborne noise shall be furnished with the bids.

Source: https://assist.dla.mil -- Downloaded: 202640-19T23:00Z
Check the source to verify that this is the currentversion before use.

4.8 Test equipment. Equipment shall be so designed as to be capable of being maintained, aligned, calibrated, and repaired with the aid of the following test equipment:

(a) Voltmeter of appropriate range.
(b) Ammeter of appropriate range.
(c) Ohmmeter of appropriate range.
(d) Wattmeter of appropriate range.

4.8.1 Contractors desiring to utilize test equipment other than as specified in 4.8 shall submit to NAVSEC with justification, the necessity for using such test equipment, prior to the start of manufacture of the equipment. Test equipment required for maintenance not specified in 4.8, or in NAVSEA 0969-LP-019-7000, shall be furnished by the contractor with the relay.

4.9 Test report. The contractor shall prepare a first article test report in accordance with the data ordering document included in the contract or order (see 6.2.2), and shall include the following:

(a) The pertinent measurements involved with each test, not just general statements that the equipment passed. For example, show actual weight in pounds on weight test.

4.10 Inspection of preparation for delivery. The preservation-packaging, packing, and marking shall be inspected for compliance with section 5 of this document.

5. PREPARATION FOR DELIVERY

(The preparation for delivery requirements specified herein apply only for direct Government procurements. For the extent of applicability of the preparation for delivery requirements of referenced documents listed in section 2, see 6.5.)

5.1 Preservation-packaging, packing, and marking. Relays and repair parts shall be preserved-packaged level A or C, packed level A, B, or C as specified (see 6.2.1), and marked in accordance with MIL-E-17555.

6. NOTES

6.1 Intended use. Relays covered by this specification are intended for use in generator switchboards, control centers, or other power distribution points to monitor power loads and to initiate tripping of selected circuit breakers, contactors, or other disconnecting devices, thereby disconnecting low priority electrical loads from the power source when overloading occurs or is imminent, thus providing for continuity of power to essential loads.

6.2 Ordering data.

6.2.1 Procurement requirements. Procurement documents should specify the following:

(a) Title, number, and date of this specification.
(b) Power relay characteristics:
    (1) Voltage coil rating (see 3.2.1 (b)).
    (2) Current coil rating for the application (see 3.2.1 (b)).
    (3) The expected power factor of the system to which the relay will be used.
(c) Ambient temperature, if above 65°C (see 3.2.3).
(d) Type of enclosure, if required (see 3.3.2).
(e) Low noise relay, if required (see 3.4).
(f) Requirements for inclusion of NSN on identification plate, if required and the NSN to be used (see 3.7).
(g) Repair parts, if required (see 3.8).
(h) Maximum vibration frequency, if above 33 Hz (see 4.7.4).
(i) Levels of preservation-packaging, packing, and marking required (see 5.1).

6.2.2 Data requirements. When this specification is used in a procurement which invokes the provision of the "Requirements for Data" of the Armed Services Procurement Regulations (ASPR), the data identified below, which are required to be developed by the contractor, as specified on an approved Data Item Description (DD Form 1664), and which are required to be delivered to the Government, should be selected and specified on the approved Contract Data Requirement List (DD Form 1423) and incorporated in the contract. When the provisions of

Source: https://assist.dla.mil -- Downloaded: 202610-19T23:00Z
Check the source to verify that this is the current version before use.

the "Requirements for Data" of the ASPR are not invoked in a procurement, the data required to be developed by the contractor and required to be delivered to the Government should be selected from the list below and specified in the contract.

Paragraph	Data requirements	Applicable DID	Option
3.9.1	Drawings, engineering and associated lists, level 3 (production)	DI-E-7015	Design activity designation - Contractor Design activity drawing number - Contractor Delivery of hard copy - Procuring activity
3.9.2	Technical manuals, preliminary	DI-M-2043	Type I of MIL-M-15071
3.9.2	Technical manual quality assurance data	DI-M-2051	Option a
4.1.1	Inspection system program plan	DI-R-4803	------
4.9	First article inspection report	UDI-T-23450	------

(Copies of data item descriptions required by the contractors in connection with specific procurement functions should be obtained from the procuring activity or as directed by the contracting officer. Unless otherwise indicated, the issue in effect on date of invitation for bids or request for proposal shall apply.)

6.2.2.1 The data requirements of 6.2.2 and any task in section 3, 4, or 5 of this specification required to be performed to meet a data requirement may be waived by the procuring/purchasing activity upon certification by the offeror that identical data were submitted by the offeror and accepted by the Government under a previous contract for identical item procured to this specification. This does not apply to specific data which may be required for each procurement regardless of whether an identical item has been supplied previously (for example, test reports).

6.3 First article inspection. Invitations for bids should provide that the Government reserves the right to waive the requirement for samples for first article inspection as to those bidders offering a product which has been previously procured or tested by the Government, and that bidders offering such products, who wish to rely on such production or test, must furnish evidence with the bid that prior Government approval is presently appropriate for the pending procurement.

6.4 Definitions. The definitions specified in 6.4.1 through 6.4.4 apply to terms used in this specification.

6.4.1 Power-sensing relay. A power-sensing relay is a device which monitors power flow in an electric circuit and responds in a predetermined manner to power levels to close and open control circuits. The relay may contain electromagnetic devices or solid state circuitry or a combination of both.

6.4.2 Contacts, normally open (NO) and normally closed (NC). Normally open and normally closed signify the position taken by contacts before the device is activated by preset power levels for a preset time period.

6.4.3 Temperature rise. Temperature rise refers to the increase in temperature above ambient, measured in °C, that will be reached by a device during its normal operation.

6.4.4 Ambient temperature. Ambient temperature is the temperature of the medium surrounding the relay.

6.5 Sub-contracted material and parts. The preparation for delivery requirements of referenced documents listed in section 2 do not apply when material and parts are procured by the contractor for incorporation into the equipment and lose their separate identity when the equipment is shipped.

Preparing activity:
Navy - SH
(Project 5945-N344)

Source: https://assist.dla.mil -- Downloaded: 202640-19T23:00Z
Check the source to verify that this is the currenversion before use.

STANDARDIZATION DOCUMENT IMPROVEMENT PROPOSAL

OMB Approval
No. 22-R255

INSTRUCTIONS: The purpose of this form is to solicit beneficial comments which will help achieve procurement of suitable products at reasonable cost and minimum delay, or will otherwise enhance use of the document. DoD contractors, government activities, or manufacturers/vendors who are prospective suppliers of the product are invited to submit comments to the government. Fold on lines on reverse side, staple in corner and send to preparing activity. Comments submitted on this form do not constitute or imply authorization to waive any portion of the referenced document(s) or to amend contractual requirements. Attach any pertinent data which may be of use in improving this document. If there are additional papers, attach to form and place both in an envelope addressed to preparing activity.

DOCUMENT IDENTIFIER AND TITLE

NAME OF ORGANIZATION AND ADDRESS

CONTRACT NUMBER

MATERIAL PROCURED UNDER A

☐ DIRECT GOVERNMENT CONTRACT ☐ SUBCONTRACT

1. HAS ANY PART OF THE DOCUMENT CREATED PROBLEMS OR REQUIRED INTERPRETATION IN PROCUREMENT USE?

A. GIVE PARAGRAPH NUMBER AND WORDING.

B. RECOMMENDATIONS FOR CORRECTING THE DEFICIENCIES

2. COMMENTS ON ANY DOCUMENT REQUIREMENT CONSIDERED TOO RIGID

3. IS THE DOCUMENT RESTRICTIVE?

☐ YES ☐ NO *(If "Yes", in what way?)*

4. REMARKS

SUBMITTED BY *(Printed or typed name and address - Optional)*

TELEPHONE NO.

DATE

DD FORM 1 JAN 72 1426 REPLACES EDITION OF 1 JAN 66 WHICH MAY BE USED

S/N 0102-014-1802

Source: https://assist.dla.mil -- Downloaded: 202610-19T23:00Z
Check the source to verify that this is the current version before use.