RR-W-375A
January 21, 1971
SUPERSEDING
Fed.Spec. RR-W-375
March 3, 1961

FEDERAL SPECIFICATION

WIRE FABRIC, STEEL, WELDED (FOR REINFORCING CONCRETE)

This specification was approved by the Commissioner, Federal Supply Service, General Services Administration, for the use of all Federal agencies.

1. SCOPE AND CLASSIFICATION

1.1 Scope. This specification covers welded wire fabric to be used for the reinforcement of concrete.

1.2 Classification.

1.2.1 Size and mesh. Size of wire and meshes shall be as specified (see 6.2).

2. APPLICABLE DOCUMENTS

2.1 The following documents of the issue in effect on date of invitation for bids or request for proposal form a part of this specification to the extent specified herein.

Federal Standard:

Fed. Std. No. 123 - Marking for Domestic Shipment (Civil Agencies).

(Activities outside the Federal Government may obtain copies of Federal Specifications, Standards, and Handbooks as outlined under General Information in the Index of Federal Specifications, Standards, and Handbooks and at the prices indicated in the Index. The Index, which includes cumulative monthly supplements as issued, is for sale on a subscription basis by the Superintendent of Documents, U.S. Government Printing Office, Washington, D.C. 20402.

FSC 5335

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T12:09Z
Check the source to verify that this is the current version before use.

(Single copies of this specification and other Federal Specifications required by activities outside the Federal Government for bidding purposes are available without charge from Business Service Centers at the General Services Administration Regional Offices in Boston, New York, Washington, D.C., Atlanta, Chicago, Kansas City, Mo., Fort Worth, Denver, San Francisco, Los Angeles and Seattle, Washington.

(Federal Government activities may obtain copies of Federal Specifications, Standards, and Handbooks and the Index of Federal Specifications, Standards, and Handbooks from established distribution points in their agencies.)

Military Standards:

MIL-STD-105 - Sampling Procedures and Tables for Inspection by Attributes.
MIL-STD-129 - Marking for Shipment and Storage.
MIL-STD-163 - Preparation of Steel Products for Domestic Shipment (Storage and Overseas Shipment).

(Copies of Military Specifications and Standards required by the contractors in connection with specific procurement functions should be obtained from the procuring activity or as directed by the contracting officer.)

2.2 Other publications. The following documents form a part of this specification to the extent specified herein. Unless a specific issue is identified, the issue in effect on date of invitation for bids or request for proposal shall apply.

American Society for Testing and Materials (ASTM) Standards:

A82 - Cold-Drawn Steel Wire for Concrete Reinforcement.
A185 - Welded Steel Wire Fabric for Concrete Reinforcement.

(Application for copies should be addressed to the American Society for Testing and Materials, 1916 Race Street, Philadelphia, Pennsylvania 19103.)

National Motor Freight Traffic Association, Inc., Agent:

National Motor Freight Classification.

(Application for copies should be addressed to the National Motor Freight Traffic Association, Inc., Agent, 1616 P Street, N.W., Washington, DC 20036.)

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T12:09Z
Check the source to verify that this is the current version before use.

Uniform Classification Committee, Agent:

Uniform Freight Classification.

(Application for copies should be addressed to the Uniform Classification Committee, Tariff Publishing Officer, Room 202 Union Station, 516 W. Jackson Blvd., Chicago, Illinois 60606.)

(Technical society and technical association specifications and standards are generally available for reference from libraries. They are also distributed among technical groups and using Federal agencies.)

3. REQUIREMENTS

3.1 Description. As used herein, the term, welded wire fabric, designates a material composed of cold-drawn steel wires fabricated into a sheet or a roll (or so-called "mesh") by electric welding. The finished material shall consist of a series of longitudinal and transverse wires arranged substantially at right angles to each other and welded together at all points of intersection.

3.2 Material. The wire used in the manufacture of welded wire fabric shall conform to the requirements of ASTM A82.

3.3 Gages, spacings, and dimensions. Gages, spacings, arrangements of wires, and dimensions of units in flat sheet form or rolls shall conform to the requirements as specified (see 6.2).

3.4 Mechanical properties. Mechanical properties of the wire, such as tensile strength, weld shear strength, and bending properties shall conform to the requirements specified in ASTM A185.

3.5 Dimensions and tolerances. Permissible variations in wire diameter, width of fabric, wire spacing, and over-all dimensions shall conform to the tolerances indicated in ASTM A185.

3.6 Workmanship.

3.6.1 Wire assembly. The wires shall be assembled by automatic operating machines or by other suitable mechanical means which will assure accurate spacing and alinement of all members of the finished fabric.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T12:09Z
Check the source to verify that this is the current version before use.

3.6.2 Points of intersection. Longitudinal and transverse members shall be securely connected at every intersection by a process of electric welding within the tolerances established in ASTM A185.

3.6.3 Openings. The fabricated product shall result in a strong, serviceable mesh-type fabric having substantially square or rectangular openings. The product shall be fabricated and finished in such a manner as to prevent injurious defects, and shall conform to the requirements of this specification.

4. QUALITY ASSURANCE PROVISIONS

4.1 Responsibility for inspection. Unless otherwise specified in the contract or purchase order, the supplier is responsible for the performance of all inspection requirements as specified herein. Except as otherwise specified, the supplier may utilize his own facilities or any commercial laboratory acceptable to the Government. The Government reserves the right to perform any of the inspections set forth in the specification where such inspections are deemed necessary to assure that supplies and services conform to prescribed requirements.

4.2 Inspection lot. All wire fabric not exceeding 300,000 square feet, of the same size, and characteristics, offered to the Government at one time, shall be considered a lot for the purpose of inspection. Quantities greater than 300,000 square feet shall be divided into a lot of 300,000 square feet and the remaining fraction shall be considered a second lot.

4.3 Unit of product. A unit of product shall either be one flat sheet of wire fabric or one roll of wire fabric.

4.4 Sampling.

4.4.1 Sampling for examination. Unless otherwise specified (see 6.2), a random sample of unit products shall be selected from each lot in accordance with MIL-STD-105 at inspection level S-2. In terms of defects per 100 units, the acceptable quality levels shall be 2.5 for major defects.

4.4.2 Sampling for test. Unless otherwise specified (see 6.2), from one unit product, selected at random from the lot, sufficient wire fabric shall be cut across the width of the sheet or roll to insure performance of the test specified in 4.6.1. The sample shall be large enough to contain a minimum of four welds, excluding salvage.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T12:09Z
Check the source to verify that this is the current version before use.

4.5 Examination. Each sample unit shall be examined to verify compliance with this specification. Examination shall be conducted as specified in table I.

TABLE I. Classification of defects

Categories	Defects	Requirement Paragraph
Major		
101	Size and mesh not as specified.	1.2.1
102	Dimensions not within tolerances.	3.5
103	Workmanship not as specified.	3.6
104	Welded joints broken in excess of 1 percent.	3.6.2

4.6 Mechanical properties tests.

4.6.1 Tensile, bend, and weld shear test. Samples selected in accordance with 4.4.2 shall be tested for tensile, bend, and weld shear properties in accordance with ASTM A82 and ASTM A185 to determine if the requirements of 3.4 have been met.

4.6.2 Inspection of preparation for delivery. The preservation, packaging, packing, and marking of the wire shall be examined to determine compliance with the requirements of Section 5 of this specification.

5. PREPARATION FOR DELIVERY

5.1 Packing. Packing shall be level A, or C as specified (see 6.2).

5.1.1 Level A. The wire fabric shall be packed in accordance with the applicable level A requirements of MIL-STD-163.

5.1.2 Level C. The complete equipment shall be packed in a manner which will insure arrival at destination in satisfactory condition and be acceptable to the carrier at lowest rates. Packing shall comply with Uniform Freight Classification rules or National Motor Freight Classification rules.

5.2 Marking (see 6.2). In addition to any special marking required by the contract or order, each roll or bundle shall be marked in accordance with Fed. Std. No. 123 or MIL-STD-129 as applicable.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T12:09Z
Check the source to verify that this is the current version before use.

6. NOTES

6.1 Intended use. Welded wire fabric covered by this specification is intended to be used in the reinforcement of concrete construction such as concrete slabs, precast concrete pipe, highways, and retaining walls.

6.2 Ordering data. Purchasers should select the preferred options offered herein and include the following information in the procurement documents:

a. Title, number, and date of this specification.

b. Size and mesh of wire fabric (see 1.2.1).

c. If fabric is to be furnished in flat sheets or in rolls and the width and length required (see 3.3).

d. When sampling plan is different (see 4.4.1 and 4.4.2).

e. Level of preservation and packaging and level of packing required (see 5.1 and 5.2).

f. Method of marking required (see 5.2).

MILITARY CUSTODIANS:

Army - ME
Navy - YD
Air Force - 82

User activities:

Army - CE
Navy - MC

Preparing activity:

Navy - YD

CIVIL AGENCY INTEREST:

GSA- FSS

Orders for this publication are to be placed with General Services Administration, acting as an agent for the Superintendent of Documents. See Section 2 of this specification to obtain copies and other documents referenced herein. Price 10 cents each.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T12:09Z
Check the source to verify that this is the current version before use.

SPECIFICATION ANALYSIS SHEET

Form Approved
Budget Bureau No. 22-R255

INSTRUCTIONS: This sheet is to be filled out by personnel, either Government or contractor, involved in the use of the specification in procurement of products for ultimate use by the Department of Defense. This sheet is provided for obtaining information on the use of this specification which will insure that suitable products can be procured with a minimum amount of delay and at the least cost. Comments and the return of this form will be appreciated. Fold on lines on reverse side, staple in corner, and send to preparing activity. Comments and suggestions submitted on this form do not constitute or imply authorization to waive any portion of the referenced document(s) or serve to amend contractual requirements.

SPECIFICATION
RR-W-375A Wire Fabric, Steel, Welded (For Reinforced Concrete)

ORGANIZATION

CITY AND STATE

CONTRACT NUMBER

MATERIAL PROCURED UNDER A
☐ DIRECT GOVERNMENT CONTRACT ☐ SUBCONTRACT

1. HAS ANY PART OF THE SPECIFICATION CREATED PROBLEMS OR REQUIRED INTERPRETATION IN PROCUREMENT USE?
   A. GIVE PARAGRAPH NUMBER AND WORDING.

   B. RECOMMENDATIONS FOR CORRECTING THE DEFICIENCIES

2. COMMENTS ON ANY SPECIFICATION REQUIREMENT CONSIDERED TOO RIGID

3. IS THE SPECIFICATION RESTRICTIVE?
   ☐ YES ☐ NO *(If "yes", in what way?)*

4. REMARKS *(Attach any pertinent data which may be of use in improving this specification. If there are additional papers, attach to form and place both in an envelope addressed to preparing activity)*

SUBMITTED BY *(Printed or typed name and activity - Optional)*

DATE

DD FORM 1 JAN 66 1426

REPLACES EDITION OF 1 OCT 64 WHICH MAY BE USED.

S/N-0102-014-1801 C-25254

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T12:09Z
Check the source to verify that this is the current version before use.