W-L-101/22B

November 18, 1977

SUPERSEDING
W-L-101/22A-T
December 15, 1969

FEDERAL SPECIFICATION SHEET

LAMP, INCANDESCENT

40 WATT, 120 VOLTS, A-19 BULB INSIDE FROSTED MEDIUM SCREW BASE

This specification sheet was approved by the Commissioner, Federal Supply Service, General Services Administration, for the use of all Federal agencies.

(This specification sheet forms a part of the latest issue of Federal Specification W-L-101.)

REQUIREMENTS

TABLE I

Watts		Test Volts	Lumens per Watt			Average Life (hours)
Initial	Tol. %		Initial	Initial Tol.	At 70% of Life	
40	± 3	120	10.80	-4	10.10	1500

Dimensions not in accordance with ANSI C78.100 shall be considered a defect.

FSC 6240

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T11:22Z
Check the source to verify that this is the current version before use.

CIVIL AGENCY COORDINATING ACTIVITIES:
GSA-FSS
Commerce - NBS

PREPARING ACTIVITY:
GSA-FSS

MILITARY INTEREST:
Custodian
Navy - SH
Air Force - 85

Orders for this publication are to be placed with General Services Administration as an agent for the Superintendent of Documents. See Section 2 of this specification to obtain extra copies and other documents referenced herein. Priced cents each.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T11:22Z
Check the source to verify that this is the current version before use.