A-A-50799
February 16, 1982

COMMERCIAL ITEM DESCRIPTION

CHARGER/ANALYZER FOR VENTED CELL NICKEL-CADMIUM BATTERIES

The General Services Administration has authorized the use of this commercial item description.

Scope. This commercial item description covers general purpose self contained, pulse type battery charger and analyzer designed to charge 11, 19, 20 & 22 cell, 6 to 52 ampere hour (Ah), nickel-cadmium batteries.

Salient characteristics:

1. Dimensions: The overall dimensions of the charger/analyzer shall be no more than 24 inches high, 24 inches wide and 24 inches long.

2. Weight: The weight of the complete unit shall not exceed 150 pounds.

3. Requirements:

   a. Continuous indication capability of state of charge above 90% full capacity.

   b. Automatic programmable charge-discharge-recharge cycle in a maximum of 200 minute time span for low impedance batteries and 260 minutes maximum for high impedance batteries.

   c. Selectable Pass/Fail levels displayed by indicators to include ampere hour capacity, and battery quality.

   d. Voltage, current, battery quality and charge mode digital display capability.

   e. Charging cycles will be accomplished by pulse type charging method.

   f. Provide an automatically adjustable negative pulse that does not require operator action after initial set-up.

   g. The charger and analyzer sections shall have separate programmable timers.

   h. Operate from 208/230 Vac, single phase, 50/60 Hertz commercial power source with a maximum of 23 amperes current draw.

   i. While charging, the battery temperature, measured by a thermometer in the electrolyte of the centermost cell, shall not increase more than 15°F (9.4°C) over temperature prior to charge cycle. This applies to a battery which is at room temperature prior to starting charge.

4. Finish: All surfaces of cabinet shall be finished with paint or [illegible] resistant

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T08:47Z
Check the source to verify that this is the current version before use.

5. Marking: The supplier shall provide and install a corrosion-resistant metal nameplate in a visible and safe location on the charger cabinet exterior which shall contain, as a minimum the following information:

   a. Nomenclature/Name

   b. Name of Manufacturer

   c. Model

   d. Serial Number

   e. Year of Manufacture

   f. Part Number

   g. Input (Volts)

   h. Input (Amperes)

   i. Input Frequency (Hertz)

6. Instructions: Brief instructions for operating the charger/analyzer shall be permanently mounted on or near the control panel. The instructions and/or diagrams shall be protected against elements that will affect their legibility.

7. Workmanship: The unit, including all parts and accessories, shall be fabricated and finished in a thoroughly workmanlike manner. Particular attention shall be given to freedom from blemishes, defects, burrs and sharp edges; accuracy of dimensions, radii of fillets and markings of parts and assemblies; thoroughness of soldering, welding, brazing, painting, wiring and riveting; alignment of parts and tightness of assembly screws and bolts.

Certification. The contractor shall certify that the offered meets the salient characteristics of the description and conforms to the producers' own drawings, specifications, standards and quality assurance practices and is the same as the product offered for sale in the commercial marketplace. The Government reserves the right to require proof of such conformance prior to first delivery and thereafter as may be otherwise provided for under the provisions of the contract. The product furnished must have been offered for sale to commercial market for not less than twelve months.

Intended use:

   a. The charger/analyzer covered by this commercial item description is intended to provide a reliable, efficient and fast charging and analyzing capability in servicing a wide range of NICAD batteries by AF Base Maintenance Battery Shops.

   b. It will also provide these activities a charger/analyzer that is fully portable for use in the performance of their mobile functional tasks.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T08:47Z
Check the source to verify that this is the current version before use.

Packaging, packing and marking. The packaging and packing shall be in accordance with normal commercial practice and shall assure acceptance by common carrier and provide product protection against loss and damage during multiple shipments, handling, and storage. The shipping container shall be in compliance with the National Motor Freight Classification and Uniform Freight Classification. Marking shall be as specified in the contract or order.

Known acceptable product. The following product is known to meet the requirements of this commercial item description.

MFR	Christie Electric Corp
Model	RF80H
NSN	6130-01-108-5668

Custodians:

Army
Navy
Air Force 99

Preparing Activity

Air Force 99
(Project 6130-F224)

Source: https://assist.dla.mil -- Downloaded: 202610-26T08:47Z
Check the source to verify that this is the current version before use.

Table I - Meter ranges.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T08:47Z
Check the source to verify that this is the current version before use.