MIL-G-52889/3
INTERIM AMENDMENT 1(ME)
16 August 1985

MILITARY SPECIFICATION

GENERATOR SETS, DIESEL ENGINE DRIVEN, 10 KW, 400 HERTZ;

TACTICAL, UTILITY

This interim amendment is approved for use within the US Army Belvoir Research and Development Center, Department of the Army, with MIL-G-52889/3, dated 1 July 81.

PAGE 2

8., line 6, delete "The circuit interrupter shall open within 0.03 seconds" and substitute "The circuit interrupter shall open within 0.05 seconds".

Custodians:
Army - ME

Preparing activity:
Army - ME

Project 6115-A499

FSC 6115

DISTRIBUTION STATEMENT A. Approved for public release; distribution is unlimited.

☆U.S. GOVERNMENT PRINTING OFFICE: 1985 — 505-033/23888

Source: https://assist.dla.mil -- Downloaded: 2026-10-22T21:39Z
Check the source to verify that this is the current version before use.