W-B-811b
AMENDMENT—2
February 14, 1964
SUPERSEDING
Int. Amendment—1
July 18, 1962

FEDERAL SPECIFICATION

BUSWAY SYSTEM, POWER, ELECTRICAL, 600 VOLTS

This amendment, which forms a part of Federal Specification W-B-811, dated June 13, 1962, was approved by the Commissioner Federal Supply Service, General Services Administration, for the use of all Federal agencies.

Page 1, paragraph 1.2.1, delete:

Styles:

Style A—With ventilated enclosures.
Style B—With unventilated enclosures"

Page 2, after paragraph 3.3.3 add new paragraph 3.4, as follows:

3.4 Enclosure. The enclosure shall protect the busway from mechanical damage. Unless otherwise specified (see 6.1), enclosures may be ventilated or unventilated, at the option of the manufacturer.

Page 3, paragraph 6.1, lines 7 and 8. Delete and substitute:

"(*b*) Type and class of system (see 1.2.1)."

Page 3, paragraph 6.1, add at end of paragraph:

"(*f*) Ventilated or unventilated enclosures, if either is specifically required for the application being made (see 3.4)."

Page 4, paragraph 6.3. Transportation description. Delete and substitute:

6.4 Transportation description. Transportation descriptions and minimum weights applicable to this commodity are:

Rail:

Bus bar system, consisting of housings containing bus bars and insulators, with or without tapping connectors or trolleys.
Carload minimum weight 30,000 pounds, subject to Rule 34, Uniform Freight Classification.

Motor:

Bus bar system, consisting of housings containing bus bars, insulators, with or without tapping connectors or trolleys.
Truckload minimum weight 30,000 pounds, subject to Rule 115, National Motor Freight Classification.

Page 4, after paragraph 6.2 add new paragraph 6.3, as follows:

6.3 Building designers and engineers should give adequate consideration to the relative importance of the type of busway enclosure included in their plans, particularly where local building codes are involved. Where there is no definite need for specifying ventilated enclosures over unventilated enclosures, or vice versa, the contractor should be permitted to supply either.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T11:33Z
Check the source to verify that this is the current version before use.

MILITARY INTERESTS

Review Interest:

Mobility Command (MO).
Bureau of Yards and Docks (Y&D)
Rome Air Materiel Area (ROAMA)
Defense Electronics Supply Center (ES)

User Interest: None

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T11:33Z
Check the source to verify that this is the current version before use.