INTERIM AMENDMENT

TO

FEDERAL SPECIFICATION

LIGHT SET, GENERAL ILLUMINATION
(EMERGENCY OR AUXILLIARY)

This interim amendment was developed by the General Services Administration, Federal Supply Service, Washington, DC 20406, based upon currently available technical information. It is recommended that Federal agencies use it in procurement and forward recommendations for changes to the preparing activity at the address shown above.

The General Services Administration has authorized the use of this interim amendment as a valid exception to Federal Specification W-L-305D, dated May 12, 1976.

PAGE 1

Paragraph 1.2, under "Class III" include the additional battery style immediately after the existing style B and C batteries as follows:

"Style G - Equipped with non-refillable lead-acid (gel) type battery".

PAGE 4

Paragraphs 3.6.1.1, 3.6.1.2, and 3.6.1.3, delete the last sentence in each of these paragraphs without replacement.

PAGE 5

Paragraph 3.6.2.1, delete in its entirety and replace with the following:

"3.6.2.1 Style B. The type I, class III, style B batteries shall be the same as the type I, class I, style D batteries specified in 3.6.1.1 except that the type I, class III, style B batteries shall provide the performance required of class III units per paragraph 3.10 of this specification."

Paragraph 3.6.2.2, delete in its entirety and replace with the following:

"3.6.2.2 styles C and G. The type I, class III, style C batteries shall be the same as the type I, class I, style E batteries specified in 3.6.1.2 except that the type I, class III, style C batteries shall provide the performance required of class III units per paragraph 3.10 of this specification. The type I, class III, style G batteries shall be the same as the type I, class I, style F batteries specified in 3.6.1.3 except that the type I, class III, style G batteries shall provide the performance required of class III units per paragraph 3.10 of this specification".

Paragraph 3.6.2.3, delete in its entirety and replace with the following:

"3.6.2.3 Charger. The charger for style B, C, and G shall be as specified in 3.6.1.4 except that charger shall recharge the batteries to a charged state within 16 hours after continuous discharge of 4 hours through the connected lamp load."

Paragraph 3.8.1, delete the words "and class II" from paragraph title.

FSC 6230

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T11:25Z
Check the source to verify that this is the current version before use.

PAGE 5 (con't)

Paragraph 3.9.1, last sentence, delete in its entirety and replace with the following:

"If an on-off switch is provided, such switch shall not be accessible from outside of housing."

Paragraph 3.10, next to last sentence delete in its entirety and replace with the following:

"Class III, styles B, C, and G shall be capable of being recharged within 16 hours immediately after the 4 hour discharge period."

PAGE 7

Paragraph 4.3, seventh line, change the wording "lack or required" to "lack of required."

Paragraph 4.5, subparagraph (b), delete in its entirety and replace with: "(b) Tests (see 4.7.1 and 4.8.1)".

Paragraph 4.7.1, first sentence, delete in its entirety and replace with the following:

"The performacne of the class I, styles D, E, and F and class III, styles B, C, and G unit equipment shall be tested in accordance with UL 924, paragraph 29.7."

PAGES 9 and 10

Section 5, "PREPRATION FOR DELIVERY", delete in its entirety and replace with the following:

"5. PREPARATION FOR DELIVERY

5.1 Preservation and packaging. Preservation and packaging shall be level A, or commercial as specified (see 6.2).

5.1.1 Level A.

5.1.1.1 Class I, light set without battery. Each class I, light set without battery shall be packaged in a close-fitting box conforming to PPP-B-636, class weather-resistant. Die-cut fiberboard blocking and bracing shall be used as necessary to prevent movement and damage during shipment and storage. The fiberboard material shall conform to PPP-F-320, class-domestic. The box shall be closed and water-proof sealed in accordance with the appendix to PPP-B-636.

5.1.1.2 Class III, light sets. Each class III light set without battery shall be preserved and packaged in accordance with method IA-15 of MIL-P-116.

5.1.2 Commercial. The light set and applicable battery shall be packaged to insure protection during shipment and safe delivery at destination. The batteries shall be packaged separately.

5.2 Packing. Packing shall be level A, or commercial, as specified (see 6.2).

5.2.1 Level A.

5.2.1.1 Class I and III, light set without batteries. Unit packages as specified in 5.1 of class I and III light sets of like description, in quantities as specified (see 6.2), shall be packed in a close-fitting box conforming to PPP-B-601, overseas type; PPP-B-621, class 2; PPP-B-636, class weather-resistant, or to PPP-B-640, class 2. The box shall be closed and strapped in accordance with the appendix to the applicable box specification. The gross weight shall not exceed 200 pounds.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T11:25Z
Check the source to verify that this is the current version before use.

PAGES 9 and 10 (con't)

5.2.1.2 Charged battery with electrolyte. The charged battery with electrolyte shall be packed in a close-fitting box conforming to PPP-B-636, class domestic. The battery shall have a top frame made of fiberboard. Die cut fiberboard blocking and bracing shall be used as necessary to prevent movement. The box shall be closed and sealed in accordance with method 2 of the appendix to PPP-B-636.

5.2.1.3 Class I and III, light sets. Each light set and applicable batteries packaged as specified herein shall be shipped as one complete set.

5.2.2 Commercial. The light sets and applicable batteries packed as specified in 5.1 shall be packed to comply with the National Motor Freight Classification Rules or the Uniform Freight Classification Rules and shall be shipped as complete sets.

5.3 Marking. Marking shall be in accordance with 5.3.1 or 5.3.2 as specified (see 6.2).

5.3.1 Civil agencies. Marking shall be in accordance with Fed. Std. No. 123.

5.3.2 Military agencies. Marking shall be in accordance with MIL-STD-129."

PAGE 11

Paragraph 6.2, subparagraph "(j)", delete the reference to "5.2.2.1".

GSA DC 77-7539

Source: https://assist.dla.mil -- Downloaded: 202610-26T11:25Z
Check the source to verify that this is the current version before use.