INCH-POUND

A-A-55435
9 June 1994

COMMERCIAL ITEM DESCRIPTION

SUPPLEMENTAL SOLAR LIGHTING SYSTEM (NON-ELECTRIC); WITH ACTIVE SUN TRACKING COLLECTORS AND REFLECTIVE LIGHT WAVEGUIDES

The General Services Administration has authorized the use of this Commercial Item Description.

ABSTRACT

Intended use. This supplemental solar lighting system (herein after referred to as "the system") is used to bring natural (full spectrum) sunlight into building interiors via an active solar collector with distribution through reflective light guides and diffusing lenses. The purpose is to reduce electrical lighting requirements and provide interior illumination with enhanced "daylight" characteristics.

SALIENT CHARACTERISTICS

Design and construction. The system shall consist of the following major components: (1) Roof mounted Solar light collector with electrical sun tracking drive which directs sunlight into the reflective light guide; (2) Photo-electric sensor(s) which controls the sun tracking drive to automatically and continuously position the light collector toward the sun during the period from one hour after sunrise until one hour before sunset (local time). The sun tracking drive shall be accurate to within $\pm$1.5 degrees relative to the sun's diurnal motion and adjustable for the solar ecliptic at the latitude of installation; (3) Roof skylight system having minimum dimensions of 48 inches by 48 inches, including associated curbing, flashing, and glazing. Exterior glazing shall be architectural grade, wire reinforced safety glass;

Beneficial comments (recommendations, additions, deletions, clarifications) and any data which may improve this document should be sent to: Defense General Supply Center (DGSC), ATTN: DGSC-SSA, 8000 Jefferson Davis Highway, Richmond, VA 23297-5678.

AMSC N/A FSC 6260

DISTRIBUTION STATEMENT A. Approved for public release; distribution is unlimited.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T09:46Z
Check the source to verify that this is the current version before use.

Design and construction (continued). (4) Reflective light guides and all finishing materials and hardware to connect the skylight with the interior diffusing panels/lenses for a roof-top to ceiling distance of 25 feet minimum (unless otherwise specified in the contract); (5) Stylized interior light diffusing panels/lenses including finishing trim and all associated hardware; (6) Installation instructions.

Other general requirements. The system electrical components shall be approved by Underwriters Laboratories and display the UL Seal of Approval. The sunlight conducting system shall be designed to prevent a focused sunlight "hot spot" at any point within the reflective lightguide system. Weather protection shall be provided for all exterior components as follows: (1) Components shall be designed to operate in prevailing winds gusting to 60 miles per hour (mph) and when specified in the contract shall be designed to withstand (without damage) wind and wind gusts to 90 mph (weathervaning is permissible at wind velocities greater than 75 mph). When specified in the contract, solar light collectors and electrical sun tracking drives shall be protected from damage due to accumulation of ice from sleet, freezing rain, and snow.

REGULATORY REQUIREMENTS.

Recycled materials. The offeror/contractor is encouraged to use recovered materials in accordance with Public Law 94-580 to the maximum extent practicable. Recycled and reclaimed materials shall consist of previously used material which has been reprocessed to become a source of new raw material. Under no circumstances shall the contractor submit to the Government for acceptance reconditioned or rebuilt components as a part of the equipment described herein.

Hazardous materials. Class I ozone depleting chemicals (ODCs) shall not be used in any manufacturing process associated with the supplemental solar lighting system, nor shall class I ODCs be included in any component part of the system. Insulating materials containing asbestos shall not be used.

QUALITY ASSURANCE

Certification. The contractor shall certify that the product offered meets the salient characteristics of the description and conforms to the producer's own drawings, specifications, standards, and quality assurance practices, and is the same as the product offered for sale in the commercial marketplace.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T09:46Z
Check the source to verify that this is the current version before use.

Certification(continued). When specific quality assurance provisions are specified for any commercial characteristic the contractor shall furnish data resulting from inspection(s) conducted in accordance with the specific quality assurance provisions. The Government reserves the right to require proof of such conformance prior to first delivery and thereafter as provided under the terms of the contract.

Warranty. All component parts shall be warranted to be free from defects in materials and workmanship for a period of one year from the date of installation. The manufacturer shall provide a warranty registration card for owners/end users to register the start-up date of the system.

PACKAGING, PACKING, AND PALLETIZATION

Packaging. Packaging, packing, and palletization shall be in accordance with ASTM D 3951, unless otherwise specified in the contract.

NOTES

Ordering Data.

a. Title, number, and date of this document.
b. Weather protection levels required.
c. Packing and packaging required.
d. Dimensions if different from basic 48 by 48 inch size.

Metric products. Products manufactured to metric dimensions shall be considered on an equal basis with those manufactured using inch-pound units, provided they fall within specified tolerances using conversion tables contained in the latest revision of Federal Standard Number 376, and all other requirements of this Commercial Item Description are met. If a product is manufactured to metric dimensions and those dimensions exceed the tolerances specified in the inch-pound units, a request should be made to the contracting officer to determine if the product is acceptable.

Applicable documents.

Government documents. Copies of referenced government documents are available from:

Standardization Documents Order Desk
700 Robbins Avenue
Building 4, Section D
Philadelphia, PA 19111-5094

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T09:46Z
Check the source to verify that this is the current version before use.

Applicable documents (continued).

Non-Government-publications. Copies of referenced non-Government publications are available from the following sources:

ASTM - ASTM
1916 Race Street
Philadelphia, PA 19103

UL - Underwriters Laboratories, Inc.
333 Pfingsten Road
Northbrook, IL 60062-2096

MILITARY INTERESTS:

Custodians
Air Force - 99
Army - GL
Navy - YD

Review activities
Army - CE, ME
Navy - YD
Air Force - 99

CIVIL AGENCY COORDINATING ACTIVITY:

GSA - FSS

PREPARING ACTIVITY:

DLA - GS

(Project 6260-1064)

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T09:46Z
Check the source to verify that this is the current version before use.