MIL-F-5003C(ME)
AMENDMENT 2
24 May 1977
SUPERSEDING
AMENDMENT 1
2 April 1976

MILITARY SPECIFICATION

FLOODLIGHT SET, ELECTRIC, TRIPOD-MOUNTED,

FOUR 150-WATT PROJECTOR LAMPS

This amendment forms a part of Military Specification MIL-F-5003C, dated 18 October 1973.

PAGE 1

2.1, under SPECIFICATIONS, FEDERAL, add:

"QQ-S-781 - Strapping, Steel, and Seals."

PAGE 2

2.1, under STANDARDS, add:

"FEDERAL

FED. STD. No. 356 - Commercial Packaging of Supplies and Equipment."

PAGES 2 AND 3

2.2, under Other publications, delete in their entirety all reference to: "NATIONAL MOTOR FREIGHT TRAFFIC ASSOCIATION, INC., AGENT" and "UNIFORM CLASSIFICATION COMMITTEE, AGENT".

PAGE 3

2.2, under Other publications, add:

"AMERICAN NATIONAL STANDARDS INSTITUTE, INC. (ANSI)

C73 - ANSI Standard on Plugs and Receptacles, C73 Series.

(Application for copies should be addressed to the American National Standards Institute, Inc., 1430 Broadway, New York, NY 10018.)"

FSC 6230

Source: https://assist.dla.mil -- Downloaded: 2026-10-17T04:00Z
Check the source to verify that this is the current version before use.

PAGE 4

3.5, line 4, after "W-C-596" delete the period and add: "or ANSI Standard C73 as specified."

* 3.6, delete and substitute:

"3.6 Lamp-head assembly. The lamp-head assembly (see Figure 1), shall be provided with a positive means to lock the assembly to the mast. The lamp-head housing cover shall be removable to provide access to the switch and wiring. All electrical wiring shall be insulated from the metal components of the housing. The electrical cable shall be 3-conductor, No. 18 A.W.G., light-duty 12-1/2 feet plus 1/2 minus 0 feet long and terminated at one end with a 3-prong, polarized, twist-lock molded connector plug for connecting to the electrical connector box. The third connector shall be grounded to the noncurrent carrying metal portion of the lamp-head assembly. The electrical switch for turning the lamps on and off shall be a flush-mounted, weatherproof type."

3.7.2, line 1, between "tubing" and "shall" insert: "made of other than corrosion-resistant metal"; line 3, between "tubing" and "shall" insert: "made of other than corrosion-resistant metal".

* 3.7.3, delete and substitute:

"3.7.3 Crossarms. The crossarms shall be constructed to allow selective elevating and clamping of the arm along the lower section of the mast, and the arms shall be held in place by the same type of clamp that is used on the telescoping sections. Crossarms shall be fabricated to permit folding downward and parallel to the main tube for shipment and locking in place during use. One swivel lampholder shall be mounted on each crossarm. Each lampholder shall be equipped with 10 feet plus 1/2 minus 0 feet of 3-conductor, No. 18 A.W.G., light duty, electrical cable terminated at one end with a 3-prong polarized, twist-lock molded connector plug for connecting to the electrical connector box. The third connector shall be grounded to the noncurrent carrying metal portion of the lamphead assembly."

PAGE 5

* 3.10, delete and substitute:

"3.10 Electrical connector box. The electrical connector box shall be a weatherproof type containing six weatherproof outlets and three weatherproof switches. One switch shall control the two lamphead outlets. The second switch shall control the two crossarm light outlets and the third switch shall control the two outlets for the extension lights. The outlet shall be a 2-pole, 3-wire locking, grounding type in accordance with ANSI

Source: https://assist.dla.mil -- Downloaded: 2026-10-17T04:00Z
Check the source to verify that this is the current version before use.

C73 or W-C-596 and shall match the plugs of the lamphead, crossarm, and extension lights respectively. The outlets and switches shall be labeled indicating which lights they control. The outlets shall be spaced sufficiently permitting all six outlets to be used simultaneously. The connector box shall be provided with 100 feet plus 1/2 minus 0 feet of No. 12 medium-duty, 3-conductor electrical cable terminated at one end with a polarized, heavy-duty, outdoor-service-type connector plug having two parallel contacts and one ground connector contact. The third connector shall be grounded to the mast."

* 3.11, delete and substitute:

"3.11 Extension light. One portable extension light equipped with 50 feet of No. 18 medium-duty, 3-conductor electrical cable of the type specified in 3.5 shall be furnished. The portable extension shall be in accordance with W-L-661, Type III, Class 2. The cable shall be terminated at one end with a 2-pole, 3-wire locking grounding molded connector plug in accordance with ANSI C73 or W-C-506."

PAGE 6

* 3.13, delete and substitute:

"3.13 Treatment and painting. Treatment and painting of the lamp assembly shall conform to MIL-T-704.

3.13.1 Externally-exposed surfaces. After installation, circuit elements and wiring shall be treated as specified in MIL-T-152 with a varnish conforming to MIL-V-173 composition as specified in 3.13.3. The externally-exposed surfaces of the lamp assembly shall be cleaned, treated, and painted in accordance with MIL-T-704, except that the finish color shall be as specified (see 6.2). The carrying case shall be treated and painted in accordance with MIL-C-12044. The words 'carrying case' shall be painted in accordance with MIL-T-704, except that finish color shall be as specified (see 6.2)."

* Add 3.13.2:

"3.13.2 Unpainted surfaces. The sliding portions of the lamp assembly and the glass section of the floodlight housing shall be cleaned and treated, but shall not be painted.

* 3.13.3, delete and substitute:

"3.13.3 Composition. Composition I shall be used unless Composition II must be used in order to comply with local air pollution regulations in the application of the varnish. When Composition II is used, the contractor

Source: https://assist.dla.mil -- Downloaded: 2026-10-17T04:00Z
Check the source to verify that this is the current version before use.

shall provide evidence to the Government that the use of Composition II is required, and shall certify that the Composition II material complies with Rule 66 - Air Pollution Control District, County of Los Angeles, CA."

PAGE 7

4.2(c), delete and substitute:

"(c) Inspection of packaging (see 4.7)."

PAGE 10

4.7, delete and substitute:

"4.7 Inspection of packaging."

4.7.1.3, Defect No. 109, delete and substitute: "109. Strapping not as specified for Level A."; Defect No. 110, after "incomplete" add: "for Levels A or B, or Commercial."

5., delete and substitute: "PACKAGING"

5.1, delete "Level A, B or C" and substitute "Level A or B, or Commercial,".

5.1.1, line 3, after "Overseas Type" add: "Grade B"; line 5, delete "Strapping shall be zinc coated." and substitute "Strapping shall conform to QQ-S-781, Class 1, Type I or IV, size as applicable. Unless otherwise specified (see 6.2), strapping shall be Finish B; when specified (see 6.2), strapping shall be Finish A."

5.1.3, line 1, delete "Level C." and substitute "Commercial."; delete lines 3 through 7 and substitute: "in accordance with FED. STD. No. 356."

PAGE 11

5.2, delete and substitute:

"5.2 Marking.

5.2.1 Military packaging. Marking shall be in accordance with MIL-STD-129.

5.2.2 Commercial packaging. Marking shall be in accordance with FED. STD. No. 356."

6.2(d), delete "level of packing" and substitute "degree of packing".

Source: https://assist.dla.mil -- Downloaded: 2026-10-17T04:00Z
Check the source to verify that this is the current version before use.

After 6.2(d), add:

"(e) When other than Finish B strapping is required (see 5.1.1)."

The margins of this amendment are marked with an asterisk to indicate where changes (additions, modifications, corrections, deletions) from the previous amendment were made. This was done as a convenience only and the Government assumes no liability whatsoever for any inaccuracies in these notations. Bidders and contractors are cautioned to evaluate the requirements of this document based on the entire content irrespective of the marginal notations and relationship to the last previous amendment.

Custodian:
Army - ME

Preparing activity:
Army - ME

Review activities:
Army - MD
DLS - GS

Project 6230-A235

User activities:
Army - EL, SM

☆U.S. GOVERNMENT PRINTING OFFICE: 1977-703-020/3429

Source: https://assist.dla.mil -- Downloaded: 2026-10-17T04:00Z
Check the source to verify that this is the current version before use.