MIL-F-51228(MU)
AMENDMENT 1
12 June 1987

MILITARY SPECIFICATION

FAN, VANEAXIAL, 300 CFM, 400 CYCLE, 416 VOLTS, 0.7 H.P.

This amendment forms a part of MIL-F-51228(MU), dated 20 October 1967, and is approved for use within the Chemical Research, Development and Engineering Center[1/], Department of the Army and is available for use by all Departments and Agencies of the Department of Defense.

PAGE 1

2.1: Delete "D136-14-302" and its title.

PAGE 2

2.2: Add the following:

"AIR MOVING AND CONDITIONING ASSOCIATION

AMCA Standard 210 - Laboratory Methods of Testing Fans for Rating.

(Application for copies should be addressed to the Air Movement and Control Association, 30 West University Drive, Arlington Heights, IL 60004.)"

PAGE 5

4.3.4: Delete "using Edgewood Arsenal Filter Unit Air Flow Tester, Q31 (D136-14-302)" and substitute "in accordance with AMCA Standard 210".

Custodian:

Army - EA

Preparing activity:

Army - EA

(Project No. 4240-A920)

1/Beneficial comments (recommendations, additions, deletions) and any pertinent data which may be of use in improving this document should be addressed to: Commander, U.S. Army Chemical Research, Development and Engineering Center, ATTN: SMCCR-SPT-S, Aberdeen Proving Ground, MD 21010-5423 by letter.

DISTRIBUTION STATEMENT A. Approved for public release; distribution is unlimited.

Source: https://assist.dla.mil -- Downloaded: 2026-10-22T20:53Z
Check the source to verify that this is the current version before use.