MIL-D-28594A
20 October 1982
SUPERSEDING
MIL-D-28594
10 November 1970

MILITARY SPECIFICATION

DEHUMIDIFIER, ROTARY, DRY-DESICCANT TYPE, AUTOMATIC, CONTINUOUS DUTY

This specification is approved for use by all Departments and Agencies of the Department of Defense.

1. SCOPE

1.1 Scope. This specification covers the requirements for dry desiccant, noncycling, rotary dehumidifiers.

1.2 Classification. The dehumidifier shall be equipped with one of the following types of reactivation heaters, as specified (see 6.2.1):

Type I - Electric.
Type II - Gas.
Type III - Steam.

2. APPLICABLE DOCUMENTS

2.1 Government documents.

2.1.1 Specifications and standards. Unless otherwise specified, the following specifications and standards of the issue listed in that issue of the Department of Defense Index of Specifications and Standards (DODISS) specified in the solicitation, form a part of this specification to the extent specified herein.

SPECIFICATIONS

FEDERAL

TT-P-664 - Primer Coating, Synthetic, Rust-Inhibiting, Lacquer-Resisting.
PPP-B-601 - Boxes, Wood, Cleated-Plywood.
PPP-B-621 - Boxes, Wood, Nailed and Lock-Corner.
PPP-B-636 - Box, Shipping, Fiberboard.
PPP-P-40 - Packaging and Packing of Hand Tools.

Beneficial comments (recommendations, additions, deletions) and any pertinent data which may be of use in improving this document should be addressed to: Commanding Officer (Code 156), Naval Construction Battalion Center, Port Hueneme, CA 93043, by using the self-addressed Standardization Document Improvement Proposal (DD Form 1426) appearing at the end of this document or by letter.

FSC 4440

Source: https://assist.dla.mil -- Downloaded: 2026-10-20T13:21Z
Check the source to verify that this is the current version before use.

MILITARY

MIL-C-104 - Crates, Wood: Lumber and Plywood Sheathed, Nailed and Bolted.
MIL-P-116 - Preservation, Methods of.
MIL-B-121 - Barrier Material, Greaseproofed, Waterproofed, Flexible.
MIL-V-173 - Varnish, Moisture-and-Fungus Resistant (For Treatment of Communications, Electronic, and Associated Equipment).
MIL-E-16298 - Electric Machines Having Rotating Parts and Associated Repair Parts: Packaging of.
MIL-E-17555 - Electronic and Electrical Equipment, Accessories, and Repair Parts: Packaging and Packing of.
MIL-B-22191 - Barrier Materials, Transparent, Flexible, Heat Sealable.
MIL-H-22577 - Heating Elements, Electrical: Cartridge, Strip and Tubular Type.
MIL-B-26195 - Boxes, Wood-Cleated, Skidded, Load-Bearing Base.
MIL-P-46093 - Primer Coating, Synthetic (For Brake Drums).
MIL-C-52950 - Crates, Wood, Open and Covered.

STANDARDS

FEDERAL

FED-STD-H28 - Screw-Thread Standards for Federal Services.

MILITARY

MIL-STD-129 - Marking for Shipment and Storage.
MIL-STD-461 - Electromagnetic Emission and Susceptability Requirements for the Control of Electromagnetic Interference.
MIL-STD-462 - Electromagnetic Interference Characteristics, Measurement of.
MIL-STD-1186 - Cushioning, Anchoring, Bracing, Blocking and Waterproofing: with Appropriate Test Methods.

(Copies of specifications and standards required by manufacturers in connection with specific acquisition functions should be obtained from the contracting activity or as directed by the contracting officer.)

2.2 Other publications. The following documents form a part of this specification to the extent specified herein. The issues of the documents which are indicated as DOD adopted shall be the issue listed in the current DODISS and the supplement thereto, if applicable.

AMERICAN NATIONAL STANDARDS INSTITUTE, INC. (ANSI)

C37.13 - Low-Voltage AC Power Circuit Breakers Used in Enclosures.

(Application for copies should be addressed to the American National Standards Institute, Inc., 1430 Broadway, New York, NY 10018.)

Source: https://assist.dla.mil -- Downloaded: 2026-10-20T13:21Z
Check the source to verify that this is the current version before use.

NATIONAL ELECTRICAL MANUFACTURERS ASSOCIATION (NEMA)

MG1 - Standard for Motors and Generators.

(Application for copies should be addressed to the National Electrical Manufacturers Association, 2101 L Street, N.W., Washington, DC 20037.)

NATIONAL FIRE PROTECTION ASSOCIATION (NFPA)

No. 70 - National Electrical Code.

(Application for copies should be addressed to the National Fire Protection Association, 470 Atlantic Avenue, Boston, MA 02210.)

SOCIETY OF AUTOMOTIVE ENGINEERS, INC. (SAE)

SAE Standard.

(Application for copies should be addressed to the Society of Automotive Engineers, Inc., 400 Commonwealth Drive, Warrendale, PA 15096.)

(Industry association specifications and standards are generally available for reference from libraries. They are also distributed among technical groups and using Federal agencies.)

2.3 Order of precedence. In the event of a conflict between the text of this specification and the references cited herein, the text of this specification shall take precedence.

3. REQUIREMENTS

3.1 First article. When specified (see 6.2.1), the contractor shall furnish a dehumidifier for first article inspection and approval (see 4.2.1 and 6.3).

3.2 Standard commercial product. The dehumidifier shall, as a minimum, be in accordance with the requirements of this specification and shall be the manufacturer's standard commercial product. Additional or better features which are not specifically prohibited by this specification but which are a part of the manufacturer's standard commercial product shall be included in the assemblies being furnished. A standard commercial product is a product which has been sold or is being currently offered for sale on the commercial market through advertisements, manufacturer's catalogs, or brochures, and represents the latest production model.

3.3 Materials. Materials used shall be free from defects which would adversely affect the performance or maintainability of individual components or of the overall assembly. Materials not specified herein shall be of the same quality used for the intended purpose in commercial practice. Unless otherwise specified herein, all equipment, material, and articles incorporated in the work covered by this specification are to be new and fabricated using materials produced from recovered materials to the maximum extent possible without jeopardizing the intended use. The term "recovered materials" means materials which have be collected or recovered from solid waste and reprocessed to become a source of raw materials, as opposed to virgin raw materials.

Source: https://assist.dla.mil -- Downloaded: 2026-10-20T13:21Z
Check the source to verify that this is the current version before use.

None of the preceding shall be interpreted to mean that the use of used or rebuilt products are allowed under this specification unless otherwise specified.

3.4 Design. The dehumidifier shall be a rotary, dry-desiccant type that automatically reactivates the desiccant, provides continuous operation, and is noncycling. It shall remove not less than 500 pounds (lb) of water per day when the entering air has a relative humidity of 35 percent and a dry-bulb temperature of 70° Fahrenheit (F). The unit shall not contain a coolant. Humid air shall be continuously drawn into the unit, passed through the dry-desiccant, and then discharged into the space being dehumidified. Each unit, including all components, shall be mounted on a common base and shall be equipped with a lifting eye at each of the four upper corners, or with four structural members suitable for the attachment of hoisting slings. It shall conform to the applicable safety requirements specified herein. Parts so located as to be hazardous to operating personnel, and all rotating or reciprocating parts shall be fully enclosed or properly guarded. Protection to personnel shall be provided in accordance with NFPA No. 70. Screw-threads and pipe-threads shall conform to the requirements of FED-STD-H28.

3.5 Performance

3.5.1 Capacity. The dehumidifier shall remove water under any ambient temperature between 0°F and 120°F at the rate indicated in table I (see 4.4.1).

TABLE I. Water removal rate.

Entering air conditions		
Dry bulb degrees F	Relative humidity percent	Minimum water removal rate, lb/24 hours
70	35	500
55	35	296
40	35	164
30	35	114

3.5.2 Energy consumption. The reactivation energy required to remove each pound of water from the space being dehumidified shall not exceed the values indicated in table II (see 4.4.2). Total energy shall consist of the energy necessary to operate the heater, and when used on gas burners, the pre-mix blower as well as other required auxiliary components. Energy required to operate the reactivation blower shall not exceed 1.0 kilowatt.

TABLE II. Reactivation energy.

Entering air conditions		Energy per pound of water removed maximum		
		Type I	Type II	Type III
Dry bulb degrees F	Relative humidity percent	Electric kWh	Gas Btu/h	Steam lb/h at 100 psig
70	35	0.9	4000	3.5
40	35	2.2	7300	6.3

Source: https://assist.dla.mil -- Downloaded: 2026-10-20T13:21Z
Check the source to verify that this is the current version before use.

3.6 Construction. The dehumidifier shall consist of a desiccant bed or contactor, a conditioned air fan and motor, a reactivation air fan and motor, a reactivation heater, air filters, and a drive system. They shall be mounted in an enclosed metal cabinet provided with air passages, air seals, safety devices, controls, and thermal insulation. The dehumidifier shall be furnished complete for installation, and when connected to the required power source shall produce dry air of constant psychrometric quality for a given inlet air condition.

3.6.1 Cabinet. The cabinet enclosure shall be constructed of steel or aluminum. The frame or chassis shall be rigid, and of adequate strength to support and maintain alinement of the assembled parts. Removable panels shall be provided to permit access for removal of the descissant bed or contactor, air seals, and heater. Fans and motors shall be installed within the cabinet or mounted externally. The removable panels on each dehumidifier shall be interchangeable. Separate openings shall be provided for access to the air filters. Gaskets shall provide weathertight seals at all access openings.

3.6.1.1 Airflow connections. Airflow connections shall be provided for a conditioned air inlet, a conditioned air outlet, a reactivation air inlet, and a reactivation air outlet. The inlets and outlets shall have smooth, flat surfaces for flanged duct connections. The dehumidifier shall be furnished with gasketed blank flanges at the air connection openings.

3.6.1.2 Air passage connections. Connections in all air passages shall be welded or attached by bolted flanges and shall be airtight. Flanged connections shall have gaskets of a material capable of withstanding an intermittent temperature of 392°F. The flanges on inlet and outlet connections shall be constructed to minimize strain transmission from external ducts to internal components of the dehumidifier. The manufacturer shall provide adequate means to drain any condensate that may collect in the reactivation air outlet passage.

3.6.2 Desiccant bed or contactor. The desiccant bed shall contain a granular desiccant. The desiccant contactor shall contain a nongranular desiccant. The desiccant shall have adequate capacity to meet the performance requirements of 3.5.1. Free liquid shall not result during the adsorption cycle, and the desiccant shall be adequate for repeated reactivation. There shall be no measurable carryover of desiccant from the bed or contactor to the conditioned air outlet at maximum inlet airflow and design dewpoint. Airflow shall be equally distributed over the entire cross-sectional area of the bed or contactor. The bed or contactor shall be so supported as to prevent self-grinding, settling, erosion, and attrition due to air friction, thermal stresses, or other conditions encountered during normal operation. The static pressure loss at design velocity through the desiccant bed or contactor shall be not greater than 2.0 inches of water. The bed or contactor shall not be capable of producing flammable or noxious gases at temperatures up to 392°F. If subjected to a temperature of 392°F, the bed or contactor shall operate at maximum efficiency when the air returns to normal design operating temperatures.

3.6.2.1 Granular desiccant bed. The desiccant bed shall consist of a granular desiccant contained in corrosion resistant or cadmium-plated, perforated metal. The metal shall have adequate strength to support the desiccant bed without deformation. The perforations shall be of a size that prevents loss of

Source: https://assist.dla.mil -- Downloaded: 20260-20T13:21Z
Check the source to verify that this is the current version before use.

the granular desiccant. Adequate means shall be provided to replace the desiccant without disassembly of the dehumidifier. The desiccant bed shall have adequate capacity to insure a full bed in the active zone.

3.6.2.2 Nongranular desiccant contactor. The contactor shall consist of a nongranular, fixed-desiccant impregnated structure. The desiccant shall be uniformly dispersed throughout the contactor.

3.6.2.3 Drive system. The desiccant bed or contactor shall be driven by an adjustable system consisting of a V-belt, a chain, or a combination V-belt and chain. Belt tension shall be controlled by positive action belt adjustment or shall be automatically maintained. The drive shall provide consistent performance. Lubrication, when required, shall be in accordance with 3.7.2.

3.6.2.4 Airstreams. The reactivation airstream shall flow through the desiccant bed or contactor in a counter direction to the conditioned airstream for automatic cleaning of the desiccant. The reactivation airstream shall pass directly from the heater to the desiccant structure. Dehumidifiers shall be equipped with airflow gages and reactivation and process air circuits.

3.6.3 Air Seals. Air seals shall be provided to prevent leakage between the conditioned air and reactivation air circuits, and to prevent air from bypassing the desiccant bed or contactor. The seals shall not crack, harden, or deteriorate when subjected to normal operating temperatures. Seals shall be long wearing, and shall not cause damage to the desiccant bed or contactor. The seals shall be adjustable or self-adjusting, easily removable, and provide convenient access to facilitate inspection of components.

3.6.4. Air filters. All air shall be filtered before it enters the desiccant bed or contactor in the conditioned air circuit and prior to entering the heater in the reactivation air circuit. The filter shall be the dry, cleanable type, and shall be rigidly constructed. The filter shall consist mainly of a nonferrous or mineral substance which acts as a media. The filter shall have high arrestance effeciency, high dirt holding capacity, and be cleanable. The filters shall be readily accessible to permit cleaning and replacement.

3.6.5 Thermal insulation. Exposed dehumidifier surfaces having a temperature of 130°F or higher during any service condition shall be insulated to protect personnel, and to prevent heat transfer to surroundings and from any component when the transfer of heat is detrimental to operation of the component or the system. Surfaces subject to condensation shall be insulated to prevent dripping or runoff of moisture when the dehumidifier is operated at rated capacity. The insulation shall be a glass fiber blanket, or a sheet or formed insulation of foamed closed-cell plastic. Plastic insulation shall not be used when surfaces to be insulated have a temperature of 200°F or higher. The insulation shall be impervious to water vapor, smooth, and scuff-resistant. Loose insulation applied to outside surfaces or installed within air passages shall be protected by aluminum foil or a jacket of sheet aluminum or galvanized steel.

3.6.6 Reactivation heaters. The desiccant shall be reactivated by electric, gas, or steam heaters as required (see 1.2). The heating surface shall be installed in the reactivation inlet air passage leading to the desiccant bed or contactor. During normal operation, surface temperatures of electric

Source: https://assist.dla.mil -- Downloaded: 202610-20T13:21Z
Check the source to verify that this is the current version before use.

heaters shall not exceed 900°F. A manual reset, limit switch shall stop operation of gas or electric heaters if the reactivation air temperature exceeds 325°F. An airflow sensing device shall be provided to assure that the required amount of air is supplied for operation of the gas heater. With an adequate airflow, operation of the sensing device shall be automatic causing a gas valve to become energized and the heater to reactivate the desiccant. No concentration of excessive heat shall result as a consequence of inadequate heating element design.

3.6.6.1 Type I (electric) heaters. Type I heaters shall be suitable for forced air heating. Unless otherwise specified (see 6.2.1), heaters shall operate on a nominal 208-volt, 3-phase, 60-Hertz (Hz) alternating current (ac) system. Electrical junctions shall be secured in a manner to prevent an increase in resistance and thereby cause the temperature at a junction to exceed the normal operating temperature of the heating element. The heater shall be capable of withstanding an intermittent temperature 25 percent above normal operating temperatures. The electric energy required to operate heaters and fan motors shall not exceed 20 kilowatts. Heaters shall be installed to permit inspection, servicing, and replacement without disassembly of the dehumidifier.

3.6.6.2 Type II (gas) heaters. Type II heaters shall be direct or indirect gas-fired. The reactivation airstream shall be heated without resulting in excessive heating of the body or casing of the dehumidifier or of the desiccant. Controls for gas heaters shall be provided. Unless otherwise specified (see 6.2.1), the controls shall include a lubricated plug shut-off cock, gas pressure regulator, motorized gas valve, firing rate cock, pilot cock, pilot regulator, pilot gas solenoid, spark-ignited pilot with ignition transformer, electronic main flame supervision, thermal limit switch (see 3.6.6), and airflow sensing device (see 3.6.6). The total energy required to operate the heater, and the burner fan, if provided, shall not exceed 83,000 British thermal units per hour. The burner shall be installed to facilitate inspection, servicing, and replacement without disassembly of the reactivation air duct or the dehumidifier.

3.6.6.3 Type III (steam) heaters. Type III heaters shall have nonfreeze, distributor tube type steam coils with headers and threaded ends for connection to steam supply and condensate return. The coil section shall be enclosed in a galvanized steel or aluminum casing. The total energy required to operate the heater shall not exceed 73 lb of steam per hour at 100 pounds per square inch gage. The coils shall be installed to facilitate inspection, servicing, and replacement without
disassembly of the dehumidifier.

3.6.7 Fans. The conditioned air fan and the reactivation air fan shall be the centrifugal type. The fans shall be direct driven, statically and dynamically balanced. Fan housings shall have smooth, curved inlets. Fan wheels and housings shall be steel or aluminum. Fans shall rotate at a speed of 3,450 revolutions per minute. The conditioned air fan and the reactivation air fan shall have the capacity to overcome the internal resistances of the dehumidifier and to produce not less than 0.5 inch static water pressure at each air outlet. The fan wheel shall be the multi-blade type, smooth, free from projecting bolts, nuts, and other projections that may catch dirt or lint and cause noisy operation. The conditioned air fan shall remove humid air

Source: https://assist.dla.mil -- Downloaded: 202610-20T13:21Z
Check the source to verify that this is the current version before use.

from the space to be dehumidified and circulate the air through the desiccant bed or contactor. The reactivation air fan shall circulate outside air through the desiccant in an opposing direction to the flow of conditioned air. Adequate clearance shall be provided between stationary and moving components.

3.6.8 Electrical requirements. Each dehumidifier shall be furnished complete with conditioned air and reactivation air fan motors, necessary controls, and wiring.

3.6.8.1 Motors, motor starters, and motor overload protective devices. Motors shall be the squirrel cage induction, polyphase type, having class B insulation, dripproof enclosure, be of adequate size for continuous operation without overheating, and rated and constructed in accordance with NEMA MG1. Motors shall be ballbearing, provided with a motor starter, thermal overload protection of the manual reset type, and under-voltage protection. The overload relay contacts shall be wired in series in order to stop operation of the dehumidifier when either motor becomes overloaded. The motor starters and overload protection devices shall be housed in a dripproof master control box. Powerlines shall have flexible connections to eliminate vibration transmission. Unless otherwise specified (see 6.2.1), electric motors shall operate on a nominal 208-volt, 3-phase, 60-Hz, ac system. The continuous horsepower rating of each motor shall be adequate to assure optimum performance and maximum efficiency.

3.6.8.2 Controls. With the exception of a humidity controller and a circuit breaker, each dehumidifier shall be equipped with integrally mounted controls. A selector switch having three points of electrical contact for automatic, manual, and off positions shall be mounted in an easily accessible location on the control box. The switch shall normally be set for automatic control. The dehumidifier shall automatically start and stop operating in response to the remote humudity controller. When the switch is set for manual operation, the humidity controller shall be shunted, thereby providing continuous operation of the dehumidifier. The controls shall operate on a nominal 110-volt, single-phase, 60-H, ac system. The control box shall be sheet steel, and shall contain a hinged door. An instruction booklet for operation of the controls shall be provided (see 3.11). A pocket receptacle shall be provided on the inside of the door to accommodate the instruction booklet.

3.6.8.3 Electrical wiring and components. The equipment shall be completely wired for operation, requiring only connection to the electrical source of supply. Adequate provision shall be made to ground the equipment. Wiring and electrical components, such as controllers and switches, shall conform to the applicable requirements of NFPA No. 70. All wire shall be color-coded, and suitably identified at all terminals and junctions. A wiring diagram shall be furnished with each unit. Unless otherwise specified (see 6.2.1), electrical components shall be designed for operation on a nominal 208-volt, 3-phase, 60-Hz, ac system.

3.6.8.4 Circuit breaker. Each dehumidifier shall be provided with a 3-pole, quick-make, quick-break circuit breaker in accordance with the applicable requirements of ANSI C37.13. The circuit breaker shall be separately mounted in a dripproof enclosure adjacent to the control box.

Source: https://assist.dla.mil -- Downloaded: 2026l0-20T13:21Z
Check the source to verify that this is the currentversion before use.

3.6.8.5 Hour meter. When specified (see 6.2.1), the dehumidifier shall be equipped with an hour meter. The meter shall register the total operating time. The hour meter shall include a 110-volt synchronous motor connected through adequate gearing to a counter that registers at least 9,999 hours of operating time.

3.6.8.6 Fungus resistance. When specified (see 6.2.1), electrical components and circuit elements, including terminal and circuit connections, shall be coated with varnish conforming to MIL-V-173, except that:

a. Components and elements inherently inert to fungi or in hermetically sealed enclosures need not be coated.
b. Current-carrying contact surfaces, such as relay contact points, shall not be coated.

3.6.8.7 Electromagnetic interference control. When specified (see 6.2.1), the equipment shall conform to the electromagnetic interference control requirements and test limits for class IIB equipment as specified in MIL-STD-461 when tested in accordance with 4.5.

3.6.9 Lifting attachments. All dehumidifier units covered by this specification shall be equipped with a lifting device. The lifting device shall be designed and located to permit the units to be lifted in the normal travel position. Each lifting device shall be designed to withstand a loading equal to 2-1/2 times the normal static load imposed when the dehumidifier is suspended in a stationary position.

3.7 Maintainability. The dehumidifier shall be designed to facilitate maintenance and servicing of components in the field.

3.7.1 Interchangeability. All units of the same classification furnished with similar options under a specific contract shall be identical to the extent necessary to insure interchangeability of component parts, assemblies, accessories, and spare parts.

3.7.2 Lubrication. Unless otherwise specified (see 6.2.1), means for lubrication shall be in accordance with the manufacturer's standard practice. The lubricating points shall be easily visible and accessible. All parts requiring lubrication shall be lubricated as specified in section 5. Hydraulic lubrication fittings shall be in accordance with SAE J534. Where use of high pressure lubricating equipment, 1,000 pounds per square inch or higher, will damage grease seals or other parts, a suitable warning shall be affixed to the equipment in a conspicuous location. Pressure lubrication shall not be used for motor bearings. A lubrication chart (metal or decal) shall be affixed to each machine, to indicate all points requiring lubrication, the grade of lubricant required, and the time interval for accomplishing lubrication. Although initially serviced with standard commercial lubricants, the units shall be capable of operating efficiently and satisfactorily without deleterious effects with standard military lubricants (see 6.4).

3.8 Treatment and painting. Unless otherwise specified (see 6.2.1), the dehumidifier shall be treated and painted in accordance with the manufacturer's standard practice. All surfaces of the dehumidifier other than corrosion-resisting steel shall be protected against corrosion and present a neat appearance.

Source: https://assist.dla.mil -- Downloaded: 20260-20T13:21Z
Check the source to verify that this is the current version before use.

3.9 Identification marking. Identification shall be permanently and legibly marked directly on the dehumidifier or on a corrosion resisting metal plate securely attached to the dehumidifier at the source of manufacture. Identification shall include the manufacturer's model and serial number, name, and trademark to be readily identifiable to the manufacturer.

3.10 Instruction plates. The dehumidifier shall be equipped with instruction plates suitably located, describing any special or important procedures to be followed in operating and servicing the equipment. Plates shall be of a material which will last and remain legible for the life of the equipment, and shall be securely affixed thereto with nonferrous screws or bolts of not less than 0.125-inch diameter.

3.11 Technical publications. The contractor shall furnish a publication that will include the following information as applicable to the dehumidifier units supplied under this specification.

a. Operator's manual.
b. Lubrication chart.
c. List of lubricants (see 6.4).
d. Parts manual.
e. Maintenance, service, and repair manual.
f. Wiring diagram.

The use of approved commercial manuals or modified commercial manuals is acceptable. Any additional supplemental data, either technical or administrative, shall be furnished when specified (see 6.2.1).

3.12 Spare parts. When specified (see 6.2.1), spare parts shall be furnished and shipped with each unit. The spare parts required and the quantity thereof shall be as specified in the contract, or, when applicable, shall be determined in accordance with the provisioning procedures of the contract.

3.13 Workmanship. The dehumidifiers shall be made and finished with a degree of uniformity and a grade of workmanship practicable in a well-equipped factory. They shall be free of incomplete welds, cracks, sharp edges, burrs, or other defects that could impair their operation or serviceability.

4. QUALITY ASSURANCE PROVISIONS

4.1 Responsibility for inspection. Unless otherwise specified in the contract or purchase order, the contractor is responsible for the performance of all inspection requirements as specified herein. Except as otherwise specified in the contract or purchase order, the contractor may use his own or any other facilities suitable for the performance of the inspection requirements specified herein, unless disapproved by the Government. The Government reserves the right to perform any of the inspections set forth in the specification where such inspections are deemed necessary to assure supplies and services conform to prescribed requirements.

4.1.1 Component and material inspection. Components and materials shall be inspected in accordance with all the requirements specified herein and in applicable referenced documents.

Source: https://assist.dla.mil -- Downloaded: 20260-20T13:21Z
Check the source to verify that this is the current version before use.

4.2 Classification of inspections. The inspection requirements specified herein are classified as follows:

a. First article inspection (see 4.2.1).
b. Quality conformance inspection (see 4.2.2).

4.2.1 First article inspection. The first article inspection shall be performed on one assembly when a first article sample is required (see 3.1 and 6.2.1). This inspection shall include the examination of 4.3 and the tests of 4.4. When electromagnetic interference control is specified (see 3.6.8.7 and 6.2.1), the test of 4.5, including all required reports shall be provided. The first article may be either a first production item or a standard production item from the supplier's current inventory provided the assembly meets the requirements of the specification and is representative of the design, construction, and manufacturing technique applicable to the remaining assemblies to be furnished under the contract.

4.2.2 Quality conformance inspection. The quality conformance inspection shall include the examination of 4.3, the tests of 4.4, and the packaging inspection of 4.6. This inspection shall be performed on each unit.

4.3 Examination. Each dehumidifier shall be examined for compliance with the requirements specified in section 3 of this specification. Any redesign or modification of the contractor's standard product to comply with specified requirements, or any necessary redesign or modification following failure to meet specified requirements shall receive particular attention for adequacy and suitability. The element of inspection shall encompass all visual examinations and dimensional measurements. Noncompliance with any specified requirements or presence of one or more defects preventing or lessening maximum efficiency shall constitute cause for rejection.

4.4 Tests.

4.4.1 Capacity test. The unit shall be tested to verify compliance with the capacity requirements of 3.5.1. The test shall be performed with reactivation air and conditioned air at each test condition listed in table I. The dehumidifier shall be located in a space having a constant temperature. The temperature may be within the range of 75°F to 85°F. The dehumidifier shall be operated until equilibrium has been established. Equilibrium shall be con- sidered established when the total moisture entering the system is within ±5 percent of the total moisture exiting the system. Provision shall be made to measure and record inlet and outlet temperature and humidity, power input, rate of airflow, total airflow pressure at the outlets, temperature or air leaving the heater, and other necessary data. The data shall be obtained at 15 minute intervals for a minimum period of 1 hour after the test area has reached test conditions. Failure to meet the capacity requirements shall constitute cause for rejection.

4.4.2 Energy consumption test. The unit shall be tested to verify compliance with the energy consumption requirements of 3.5.2. The tests shall be conducted at each condition listed in table II. Failure to meet the energy consumption requirements shall constitute cause for rejection.

Source: https://assist.dla.mil -- Downloaded: 2026-10-20T13:21Z
Check the source to verify that this is the current version before use.

4.4.3 Operational tests. Each unit shall be operated to determine that the dehumidifier, safety devices, and controls are adequately constructed. The safety devices and controls shall be checked to insure proper performance. The insulation resistance and the dielectric strength shall be measured to determine that personnel are not unduly exposed to hazardous conditions. The unit shall be operated continuously for 24 hours at a temperature within the range of 65°F to 85°F. If not in service during the test, the heaters shall be connected and the unit operated for 2 hours. Evidence of faulty construction, overheating of any parts, hazards to personnel, unsatisfactory operation of control equipment including thermal switches, relays, and other safety devices, or deficiency in capacity shall constitute cause for rejection.

4.4.4 Air leakage test. The air leakage test shall be performed on each unit tested in 4.4.3 before the unit has cooled. The test shall be performed both with the desiccant bed or contactor in a stationary position and in motion. With the conditioned air outlet blocked, a measured quantity of air shall flow through a gas flowmeter to the conditioned air inlet. The test may be performed by the introduction of air through the reactivation air inlet while the reactivation air outlet is blocked. The static pressure differential between the conditioned air and the reactivation air circuits shall be not less than 1.0 inch of water. The rate of leakage shall not exceed 3 percent of the rated conditioned airflow.

4.4.5 Dielectric strength test. The dehumidifier and accessory equipment, with the exception of motors, shall withstand for a period of 1 minute, without breakdown, a minimum dielectric test voltage of 1,000 volts plus twice the rated voltage. All motors shall be tested to meet the applicable NEMA dielectric strength requirements for the specific type and rating. The frequency of the test voltage shall be not less than 60-Hz.

4.4.6 Electric heater tests. The insulation resistance test and the dielectric strength test shall be performed in accordance with MIL-H-22577.

4.4.7 Lifting devices test. The static load as specified in 3.6.9 shall be applied to the attachment when mounted on its structural member. Weld failure or deformation of the attachment or structural member shall constitute cause for rejection.

4.5 Electromagnetic interference control tests. When electromagnetic interference control is specified (see 3.6.8.7 and 6.2.1), a dehumidifier shall be tested by the supplier in accordance with test methods CE03, CE05, RE01, RE02, and RE04 of MIL-STD-462. The unit to be tested may be a standard production item, from the supplier's current inventory or a first production item provid- ing the unit meets the requirements of this specification and is representa- tive of the design, construction, and manufacturing techniques applicable to the remaining units to be furnished under the contract or purchase order. The supplier shall furnish the contracting officer, for approval, the interference control plan, the EMI/EMC test plan, and the test report required in MIL-STD-461. Upon approval of the test report by the contracting officer and provided all other requirements of the specification are met, the unit tested shall be used as a model for all production units.

Source: https://assist.dla.mil -- Downloaded: 20260-20T13:21Z
Check the source to verify that this is the current version before use.

4.6 Packaging inspection. The preservation, packing, and marking of the item shall be inspected to verify conformance to the requirements of section 5.

5. PACKAGING

5.1 Preservation. Preservation shall be level A or commercial as specified (see 6.2.1).

5.1.1 Level A.

5.1.1.1 Methods of preservation. Cleaning processes, drying procedures, preservatives, and methods of preservation are listed in MIL-P-116, and shall conform to the requirements of MIL-P-116 and any applicable specifications.

5.1.1.2 Disassembly. Disassembly shall be the minimum necessary to protect parts subject to damage or loss, and to accomplish reduction in cube. Removed bolts, nuts, pins, screws and washers shall be reinstalled in mating parts and secured to prevent their loss.

5.1.1.3 Matchmarking. Parts removed and mating parts on the equipment and attachments shall be matchmarked to facilitate reassembly. Parts and accessories removed, and mating parts on the equipment, shall be identified with weatherproof tags attached to mating parts and locations. Markings shall be applied to the tags with a waterproof material.

5.1.1.4 Cleaning and drying. Prior to the application of preservative compounds or paint, surfaces shall be cleaned by process C-1 and dried by any applicable procedure of MIL-P-116.

5.1.1.5 Unprotected surfaces. Unprotected exterior metal surfaces requiring the application of a contact preservative in accordance with MIL-P-116 and not specifically provided for herein shall be preserved as follows:

5.1.1.5.1 Unfinished (not machined) surfaces. Unfinished exterior metal surfaces shall be coated with type P-1 preservative.

5.1.1.5.2 Machined surfaces. Exposed machined surfaces shall be coated with type P-6 or P-11 preservative and wrapped or covered, as applicable, with barrier material conforming to MIL-B-121, type I, grade A, class 2, or MIL-B-22191, type II. The material shall be secured in place with waterproof tape.

5.1.1.6 Electrical motors. Preserve level A by the alternate method of MIL-E-16298.

5.1.1.7 Electrical equipment. Electrical equipment shall be preserved and packaged in accordance with the level A requirements of MIL-E-17555.

5.1.1.8 Drive system.

5.1.1.8.1 Drive Chains.

Source: https://assist.dla.mil -- Downloaded: 202640-20T13:21Z
Check the source to verify that this is the currentversion before use.

5.1.1.8.1.1 Exposed drive chains. Exposed drive chains shall be coated with enough type P-3, P-9, or P-21 preservative to insure penetration of the preservative to the inner surface of the rollers, pins, and bushings. After the excess preservative has drained, the entire chain and the unpainted surfaces of the sprocket shall be coated with type P-1 preservative.

5.1.1.8.1.2 Enclosed chains. Enclosed chains and chain housings shall be preserved by filling the housing to the operating level with the approved lubricant required for operation.

5.1.1.8.2 Drive belts and pulleys. Drive belts shall be removed or released from tension. Removed belts shall be preserved method IC-1 or IC-3. Unpainted faces shall be coated with primer conforming to TT-P-664 or MIL-P-46093.

5.1.1.9 Desiccant. Desiccant shall be preserved method IA with the selection of the submethod at the option of the contractor.

5.1.1.10 Lubrication. All parts requiring lubrication and not specifically provided for herein shall be lubricated in accordance with the contractor's standard practice.

5.1.1.11 Tools and repair parts. Tools and repair parts shall be preserved and packaged in accordance with the level A requirements of PPP-P-40, or when items are not specifically covered by PPP-P-40, an applicable submethod of preservation of MIL-P-116 shall be used.

5.1.1.12 Technical publications. Technical publications for each piece of equipment shall be preserved method IC-1 or IC-3.

5.1.1.13 Consolidation. Loose components, tools, repair parts, and publications shall be consolidated in boxes conforming to PPP-B-636, class weather-resistant.

5.2 Packing. Packing shall be level A, B, or commercial as specified (see 6.2.1).

5.2.1 Level A. The complete unit shall be packed in a box conforming to PPP-B-601, military overseas type; PPP-B-621, class 2; MIL-B-26195, type II with plywood superstructure, or a crate conforming to MIL-C-104, type II, style A. The gross weight shall determine the container selected. Contents shall be cushioned, blocked, braced, and anchored in accordance with MIL-STD-1186. Contents packed in PPP-B-621 boxes and class 1, MIL-C-104 crates shall be shrouded in accordance with MIL-STD-1186.

5.2.2 Level B. The complete unit shall be packed in a box conforming to PPP-B-601, domestic type; PPP-B-621, class 1; or a crate conforming to MIL-C-52950. Contents shall be cushioned, blocked, braced, and anchored in accordance with MIL-STD-1186. Contents packed in MIL-C-52950 crates shall be shrouded in accordance with the appendix to the crate specification or MIL-STD-1186.

Source: https://assist.dla.mil -- Downloaded: 202610-20T13:21Z
Check the source to verify that this is the currentversion before use.

5.2.3 Commercial. The equipment shall be prepared for shipment in a manner which will insure arrival at destination in a satisfactory condition. Preparation for delivery shall comply with applicable carrier rules and regulations.

5.3 Marking. Marking shall be in accordance with MIL-STD-129.

6. NOTES

6.1 Intended use. Dehumidifiers covered by this specification are intended for dehumidification of warehouses or other storage spaces.

6.2 Ordering data.

6.2.1 Acquisition requirements. Acquisition documents should specify the following.

a. Title, number, and date of this specification.
b. Type of reactivation heater required (see 1.2).
c. If a first article is required for inspection and approval (see 3.1, 4.2.1, and 6.3).
d. Power requirement for electric heaters if other than specified (see 3.6.6.1).
e. Control requirements for gas heater if other than specified (see 3.6.6.2).
f. Power requirements for motors, motor starters, and motor overload protective devices if other than specified (see 3.6.8.1).
g. Power requirements for electrical components if other than specified (see 3.6.8.3).
h. If hour meter is required (see 3.6.8.5).
i. If fungus resistance is required (see 3.6.8.6).
j. If electromagnetic interference control is required (see 3.6.8.7 and 4.5).
k. If means for lubrication is to be other than manufacturer's standard practice (see 3.7.2).
l. If treatment and painting are to be other than manufacturer's standard practice (see 3.8).
m. If the technical publication is to contain any additional supplemental data (see 3.11).
n. If spare parts are required (see 3.12).
o. Level of preservation and level of packing required (see 5.1 and 5.2).

6.2.2 Contract data requirements. When this specification is used in an acquisition which incorporates a DD Form 1423, Contract Data Requirements List (CDRL), the data requirements identified below shall be developed as specified by an approved Data Item Description (DID) (DD Form 1664) and delivered in accordance with the approved CDRL incorporated into the contract. When the provisions of Defense Acquisition Regulations (DAR) 7-104.9(n) are invoked and the DD Form 1423 is not used, the data specified below shall be delivered by the contractor in accordance with the contract or purchase order requirements. Deliverable data required by this specification is cited in the following paragraphs:

Source: https://assist.dla.mil -- Downloaded: 2026-10-20T13:21Z
Check the source to verify that this is the current version before use.

Equipment)

Paragraph No.	Data requirements title	Applicable DID No.
3.11	Publications, Commercial	DI-M-24010A
4.5	Electromagnetic Interference Control Plan	DI-R-7061

(Data item descriptions related to this specification, and identified in section 6 will be approved and listed as such in DOD 5000.19L, Vol. 11, AMSDL. Copies of data item descriptions required by the contractors in connection with specific acquistion functions should be obtained from the Naval Publications and Forms Center or as directed by the contracting officer.)

6.3 First article. When a first article inspection is required, the item will be tested and should be a first production item of one complete assembly, or it may be a standard production item from the contractor's current inventory as specified in 4.2.1. The contracting officer should include specific instructions in acquisition documents regarding arrangements for examination, test, and approval of the first article.

6.4 Lubricants. If deemed necessary, procurement documents should specify that the contractor furnish a list of lubricants recommended for the dehumidifier. This list should include the type, grade, manufacturer's name, and when applicable and available, the appropriate military specification number. To assist manufacturers in identifying suitable military lubricants, the contracting officer should be prepared to supply to the contractor, when requested, a list of applicable lubricants as contained in the Federal Supply Catalog, Department of Defense Section, Identification List C9100-IL for Federal Supply Group 91 and pertinent specifications. The finalized and approved list of lubricants should then be included in the technical publications furnished with the units.

6.5 Definitive military specification part number. The definitive military specification part number corresponds to the type, class, and other specific classification date applicable to dehumidifiers covered by this specification, and defines the requirements of the options presented under this specification. The military specification number, the type and class code number, and the dehumidifiers other applicable code numbers are combined to form the definitive military specification part number.

6.5.1 Cataloging data. For cataloging purposes, the definitive military specification part numbers for the dehumidifier are assigned as follows:

	M28594 -	1, 2, or 3
Military specification number		
Type of reactivation heater		

1 = Electric
2 = Gas
3 = Steam

Source: https://assist.dla.mil -- Downloaded: 2026-10-20T13:21Z
Check the source to verify that this is the current version before use.

6.6 Changes from previous issue. Asterisks are not used in this revision to identify changes with respect to the previous issue due to the extensiveness of the changes.

Custodians:

Army - ME
Navy - YD
Air Force - 99

User activities:

Army - GL, MI, CE
Navy - MC

Preparing activity:

Navy - YD

Project No. 4440-0033

Source: https://assist.dla.mil -- Downloaded: 2026-10-20T13:21Z
Check the source to verify that this is the current version before use.

Source: https://assist.dla.mil -- Downloaded: 2026-10-20T13:21Z
Check the source to verify that this is the current version before use.

STANDARDIZATION DOCUMENT IMPROVEMENT PROPOSAL

INSTRUCTIONS: This form is provided to solicit beneficial comments which may improve this document and enhance its use. DoD contractors, government activities, manufacturers, vendors, or other prospective users of the document are invited to submit comments to the government. Fold on lines on reverse side, staple in corner, and send to preparing activity. Attach any pertinent data which may be of use in improving this document. If there are additional papers, attach to form and place both in an envelope addressed to preparing activity. A response will be provided to the submitter, when name and address is provided, within 30 days indicating that the 1426 was received and when any appropriate action on it will be completed.

NOTE: This form shall not be used to submit requests for waivers, deviations or clarification of specification requirements on current contracts. Comments submitted on this form do not constitute or imply authorization to waive any portion of the referenced document(s) or to amend contractual requirements. 4440-0033

DOCUMENT IDENTIFIER *(Number)* AND TITLE: MIL-D-28594A - DEHUMIDIFIER, ROTARY, DRY-DESICCANT TYPE, AUTOMATIC, CONTINUOUS DUTY

NAME OF ORGANIZATION AND ADDRESS OF SUBMITTER

☐ VENDOR ☐ USER ☐ MANUFACTURER

1. ☐ HAS ANY PART OF THE DOCUMENT CREATED PROBLEMS OR REQUIRED INTERPRETATION IN PROCUREMENT USE? ☐ IS ANY PART OF IT TOO RIGID, RESTRICTIVE, LOOSE OR AMBIGUOUS? PLEASE EXPLAIN BELOW.

A. GIVE PARAGRAPH NUMBER AND WORDING

B. RECOMMENDED WORDING CHANGE

C. REASON FOR RECOMMENDED CHANGE(S)

2. REMARKS

SUBMITTED BY *(Printed or typed name and address — Optional)*

TELEPHONE NO.

DATE

DD FORM 1426 1 OCT 76 — Replaces edition of 1 Jan 72 which may be used. — S/N 0102-LF-001-4260

Source: https://assist.dla.mil -- Downloaded: 2026-10-20T13:21Z
Check the source to verify that this is the current version before use.

FOLD

DEPARTMENT OF THE NAVY

OFFICIAL BUSINESS
PENALTY FOR PRIVATE USE $300

NO POSTAGE NECESSARY IF MAILED IN THE UNITED STATES

BUSINESS REPLY MAIL

FIRST CLASS PERMIT NO. 12503 WASHINGTON D. C.

POSTAGE WILL BE PAID BY THE DEPARTMENT OF THE NAVY

Commanding Officer (156)
Naval Construction Battalion Center
Port Hueneme, CA 93043

FOLD

Source: https://assist.dla.mil -- Downloaded: 2026-10-20T13:21Z
Check the source to verify that this is the current version before use.