MIL-D-19947A(SHIPS)
3 December 1962
SUPERSEDING
MIL-D-19947(SHIPS)
26 July 1957

MILITARY SPECIFICATION

DEHUMIDIFIER, SPACE, MECHANICALLY REFRIGERATED, SELF-CONTAINED, NAVAL SHIPBOARD

1. SCOPE

1.1 This specification covers mechanically refrigerated dehumidifiers for Naval shipboard use.

2. APPLICABLE DOCUMENTS

2.1 The following documents of the issue in effect on date of invitation for bids or request for proposal, form a part of the specification to the extent specified herein.

SPECIFICATIONS

MIL-S-901 - Shockproof Equipment, Class HI (High-Impact), Shipboard Application, Tests For.
MIL-D-963 - Drawings, Electrical, Hull and Mechanical Equipment For Naval Shipboard Use.
MIL-Q-9858 - Quality Control System Requirements.
MIL-M-15071 - Manuals, Equipment and Systems.
MIL-P-15137 - Provisioning Technical Documentation For Repair Parts For Electrical and Mechanical Equipment (Naval Shipboard Use).
MIL-E-17555 - Electronic and Electrical Equipment and Associated Repair Parts, Preparation For Delivery Of.

(Copies of specifications, standards, drawings, and publications required by suppliers in connection with specific procurement functions should be obtained from the procuring activity or as directed by the contracting officer.)

2.2 Other publications. - The following documents form a part of this specification to the extent specified herein. Unless otherwise indicated, the issue in effect on date of invitation for bids or request for proposal shall apply.

AMERICAN STANDARDS ASSOCIATION (ASA)
B9.1-1958 - Mechanical Refrigeration, Safety Code for (ASRE 15-58).

(Application for copies should be addressed to the American Standards Association, 10 East 40th Street, New York 16, N.Y.)

NATIONAL ELECTRICAL MANUFACTURERS ASSOCIATION (NEMA)
DH 1-1961 - Dehumidifiers, Self-contained Electrically-operated Mechanically-refrigerated
MG 1-1959 - Motors and Generators - Part 7 - Motors for Hermetic Refrigeration Condensing Unit.

(Application for copies should be addressed to the National Electrical Manufacturers Association, 155 East 44th Street, New York 17, N.Y.)

UNDERWRITERS' LABORATORIES INCORPORATED (UL)
UL474 - Dehumidifiers

(Application for copies should be addressed to Underwriters' Laboratories, Incorporated, 207 East Ohio Street, Chicago 11, Illinois; 2550 Dundee Road, Box 247, Northbrook, Illinois; 161 Sixth Avenue, New York 13, N.Y.; or 1655 Scott Boulevard, Santa Clara, California)

OFFICIAL CLASSIFICATION COMMITTEE
Uniform Freight Classification Rules.

(Application for copies should be addressed to the Official Classification Committee, 1 Park Avenue at 33rd Street, New York 16, N.Y.)

(Technical society and technical association specifications and standards are generally available for reference from libraries. They are also distributed among technical groups and using Federal agencies.)

3. REQUIREMENTS

3.1 Materials. - Materials, parts and components shall be in conformance with the requirements specified herein. All materials forming a part of the finished product shall be new and suitable for the purpose intended. The materials shall be free from any defects that might affect the serviceability or appearance of the finished product.

Source: https://assist.dla.mil -- Downloaded: 2026-10-19T06:56Z
Check the source to verify that this is the current version before use.

3.1.1 Corrosion protection.- Corrosion-resisting steel, copper, brass, bronze, chromium, copper-nickel and copper-nickel alloys referenced herein are considered satisfactory corrosion-resisting materials. Corrosion-resisting steel, when fabricated by any method that tends to reduce corrosion-resisting properties, shall be normalized to restore those properties before assembled in any unit.

3.1.1.1 Parts other than corrosion-resisting materials shall be protected against corrosion with chemicals, electrolytic processes, plating, or suitable paints and enamels. The following methods, while not restrictive are acceptable corrosion-protection methods when properly applied:

(a) Hot dipped galvanized.
(b) Hot phosphate process with rust-inhibiting paint.
(c) Electroplated cadmium followed by dichromate, or hot-phosphate treatment or water-dip lacquer.

3.1.1.2 All bolts, nuts, studs, pins, screws and such other fastenings or fittings as may be used shall be of a corrosion-resisting material, or of a material treated in a manner to render it adequately resistant to corrosion. All screws exposed in final assembly shall be corrosion-resisting material.

3.1.2 Interchangeability. Similar parts, including repair parts, or corresponding apparatus furnished on the same contract or order, or built to the same drawings, shall be strictly interchangeable without the necessity of further machining or hand fitting of any kind.

3.2 General requirements.- The dehumidifiers covered by this specification shall conform to the standards of the Underwriters' Laboratories, Incorporated, regarding fire and casualty hazards. However, compliance with these requirements does not absolve the contractor from complete compliance with all requirements of this specification.

3.2.1 In the event of differences between any of the requirements of this specification and those of Underwriters' Laboratories, Incorporated, National Electrical Manufacturers Association and American Standards Association, the requirements of this specification shall govern.

3.3 General assembly.- The dehumidifier shall consist of a condensing unit, dehumidifying coil, fan and accessories, all enclosed within a metal cabinet. The dehumidifier shall be factory-assembled, complete, self-contained with the refrigeration equipment dehydrated and charged with the necessary operating quantity of refrigerant and oil. Each unit shall be ready for operation after removal of shipping protection, opening of valves, where provided, and connection to electric power.

3.3.1 Equipment subject to service and repair shall be readily accessible for servicing.

3.4 General design.- Unless otherwise specified herein, or in the contract or order, the dehumidifier shall be suitable for operation under shipboard conditions of vibration, roll, and shock. The dehumidifier shall be designed, constructed and assembled to comply with NEMA Publication DH 1-1961, UL Publication UL474, and ASA Publication B9.1-1958, as applicable.

3.4.1 The unit shall be tested for structural strength and shall be in conformance with MIL-S-901 (see 4.3.1).

3.4.2 The unit shall be compact and of a size that will permit passing through a circular opening 21 inches in diameter and a rectangular opening 18 inches by 30 inches.

3.4.3 The equipment shall operate satisfactorily when inclined at an angle 15 degrees each side of the vertical in each of two vertical planes at right angles to each other.

3.5 Refrigerating system.- The refrigerating system shall be designed for operation with dichlorodifluoromethane (refrigerant-12).

3.5.1 Compressor.- The compressor shall be of the hermetic type and shall consist of a compressor and a motor enclosed in a gas-tight shell. Provision shall be made for adequate lubrication of all rubbing and wearing surfaces under shipboard conditions of inclination and rolling.

3.6 Piping.- All piping necessary for the satisfactory operation of the equipment shall be provided. Piping connections shall be arranged in such a manner as not to impair the vibration-isolation properties of absorption-type mounts where such mounts are provided. All piping shall be securely supported to minimize strain and vibration. Piping connections made with soft solder will not be approved.

3.6.1 The piping system shall withstand the pressure tests specified in 4.5.1.1.

3.7 Electrical equipment.- The frames or enclosures of all electrical components shall be grounded to the frame of the dehumidifier unit to eliminate hazard from shorts or grounds within the equipment. No portion of the electrical circuit shall be grounded. Equipment shall be furnished for 115-volt (v.) single phase, 60-cycle alternating current (a.c.).

3.7.1 The hermetic compressor unit shall conform to NEMA Publication MG 1-1959, part 7,

Source: https://assist.dla.mil -- Downloaded: 20260-19T06:56Z
Check the source to verify that this is the current version before use.

and shall be at least 1/6 horsepower. The unit shall be protected against overload by a thermal protector built into the motor. The thermal protector shall be either the manual or automatic reset type.

3.7.1.1 Under conditions of maximum load specified in 3.9.1, the temperature rise of the hermetic motor shall not exceed 70° Centigrade (C.).

3.7.2 Wiring. - The wiring between the electric devices shall conform to the requirements of UL Publication UL474. The wiring shall be complete and the equipment shall be ready for connection of the incoming power cable at installation.

3.7.3 Insulation resistance. - The insulation resistance of the electrical circuit shall be not less than 1 megohm (see 4.5.1.2).

3.7.4 Dielectric strength. - The equipment shall be capable of withstanding for a period of 1 minute a dielectric a.c., root mean square (r.m.s.) test voltage of 900 v. (see 4.5.1.3).

3.8 A container shall be provided for collecting the condensate. The container shall be of a size and configuration that will fit within the cabinet enclosure. The container shall be fabricated from material adequately protected against corrosion; corrosion-resistant material or of a plastic material. The container shall be provided with baffles to prevent the overflow or spilling of water during pitch and roll of the ship and shall be readily removable from the dehumidifier cabinet.

3.8.1 Provision shall also be made to permit an alternate method of drainage. A male fitting shall be provided from the drain pan for connection of 0.375 inch inside diameter (i.d.) flexible rubber tubing (wall thickness 0.125 inch). The rubber tubing will not be required to be furnished by the contractor.

3.8.2 Provision shall be made in the frame to permit securing the cabinet to a deck.

3.9 Operating requirements. - The unit shall be capable of condensing at least 1.8 gallons of water per day at an ambient temperature of 90° Fahrenheit (F.) dry bulb and 60 percent relative humidity when tested as specified in 4.3.2.1.

3.9.1 Overload conditions. - The unit shall operate satisfactory in an ambient temperature of 110°F. and relative humidity not less than 30 percent (see 4.3.2.2).

3.10 Identification plates. - Identification plates shall be of nonferrous or corrosion-resisting steel.

3.11 Repair parts. - Repair parts shall be furnished in accordance with MIL-P-15137. The number of sets shall be as specified (see 6.1). The repair parts shall consist of those specified in table I as applicable, and shall constitute one set.

Table I - Repair parts.

Item	Quantity to be furnished, based on quantity of similar units required for one ship		
	1 to 3	4 to 9	10 and above
Electric repair parts:			
Hermetic compressor motor:			
Relay	1	2	3
Overload	1	2	3
Capacitor of each size	1	2	3
Fan motor:			
Motor with fan complete	1	2	3

3.12 Drawings. - Drawings delineating the equipment shall be furnished in accordance with MIL-D-963. The types of drawings shall include master drawings class A, or class C and certification data and diagram drawings class B. Drawings shall not be required for those parts which are in common commercial use and can be referenced to commercial standards.

3.12.1 A master drawing shall be provided for each of the following, as applicable:

(a) Complete dehumidifier.
(b) Compressor.
(c) Condenser.
(d) Fan and cooling coil.

3.12.1.1 Each master drawing shall show outline, mounting, attachment and connection dimensions, including methods and sizes of fastenings and clearances for installation and servicing plus supplementary data as necessary to permit shipyard installation without suppliers assistance. The drawing shall illustrate design, construction, operation (or function) and identity of parts. Where acceptance tests are required, the tests should be identified, and approval authority and date should be noted on the drawing. The drawing shall be sufficiently complete to reflect compliance with specification requirements for the equipment, and details may be added where necessary to illustrate compliance. Subassembly drawings may be provided to supplement master drawings where desirable.

Source: https://assist.dla.mil -- Downloaded: 20261O-19T06:56Z
Check the source to verify that this is the current version before use.

3.12.2 Certification data and diagram drawings. - The certification data and diagram drawings shall include piping schematic, electrical schematic, electrical and piping connections and certification data. The diagram shall show by symbolic representation all fluid piping, pipe sizes, electrical interconnections, components, accessories and controls plus connection required by others for operation. For example, the refrigerant diagram shall include associated condensing unit, controls, valves, piping accessories, and evaporator cooling coils, as applicable; the electrical wiring diagram will include and show circuits between motors, controllers, switches and accessories as applicable for an understanding of operating sequence. The diagram drawing shall also include a mechanical schematic illustrating the arrangement of components and accessories including method of assembly, fastening and access.

3.12.2.1 All symbols used for equipment components or parts shall be given a piece number and identified in the list of material with the following information:

(a) Piece number.
(b) Quantity required.
(c) Descriptive name.
(d) Manufacturer.
(e) Manufacturer's model or identifying number.
(f) Manufacturer's drawing number.
(g) Contractor's number.
(h) Weight.
(i) Characteristics.

3.12.2.2. The characteristics shall include ordering information necessary to specifically qualify or supplement data described in referenced drawings or manufacturer's model or part number. Complete characteristics for the dehumidifier as well as for all major parts or components including the compressor, condenser, cooling coils, fan and fan motor shall be furnished.

3.13 Manuals. - Manuals shall be type I in accordance with MIL-M-15071. Photo views of the equipment shall be included as part of the general description. A section shall be provided containing reduced copies of all drawings required to amplify or illustrate the text including diagram and assembly drawings.

3.14 Workmanship. - Workmanship shall be first class in every respect.

4. QUALITY ASSURANCE PROVISIONS

4.1 Responsibility for inspection. - Unless otherwise specified in the contract or purchase order, the supplier is responsible for the performance of all inspection requirements as specified herein. Except as otherwise specified, the supplier may utilize his own facilities or any commercial laboratory acceptable to the Government. The Government reserves the right to perform any of the inspections set forth in the specification; where such inspections are deemed necessary to assure supplies and services conform to prescribed requirements.

4.2 Quality control system. - The contractor shall provide and maintain a quality control system acceptable to the Government for the supplies covered by this specification. The system of quality control shall be in accordance with MIL-Q-9858.

4.2.1 Procedures shall be assembled in manual form and shall indicate organization and responsibility for the control of quality.

4.2.2 The contractor shall establish and maintain inspection at appropriately located points in the manufacturing process, beginning with the raw materials and subcontracted parts through final testing and preparation for shipment of completed units, to assure continuous control of quality of parts, components and assemblies.

4.3 First unit tests. - The first unit shall be subjected to the tests specified in 4.3.1 through 4.3.3. If the unit fails any test the unit shall not be offered for delivery. The unit that has satisfactorily passed the tests may be used as one of the production units. The contractor may acquire all materials required for use on the contract or order prior to the approval of the units. However, any final assembly work performed by the contractor on the production units prior to approval of the first unit shall be at the contractor's risk.

4.3.1 Structural strength test. - The unit shall be tested as required by MIL-S-901. Failure to operate satisfactorily and perform its principal function or evidence of breakage or disassembly shall be cause for rejection.

4.3.2 Performance. - The unit shall be subjected to the tests specified in 4.3.2.1 and 4.3.2.2. Observations shall be taken at least 20-minute intervals. Ambient temperature, relative humidity, voltage at service connection and quantity of condensate shall be recorded.

4.3.2.1 Design capacity test. - The unit shall be installed in an ambient temperature of 90°F. and 60 percent relative humidity. The unit shall be operated for a period of 4 hours. Under these conditions, the unit shall condense moisture at the rate of 1.8 gallons of water per day.

4.3.2.2 Overload test. - The unit shall be installed in an ambient temperature of 110°F. and not less than 30 percent relative humidity. The unit shall operate without tripping the compressor-

Source: https://assist.dla.mil -- Downloaded: 20261O-19T06:56Z
Check the source to verify that this is the current version before use.

motor overload device or without breakdown. The test shall be continued until steady conditions have been observed for at least 4 hours. The temperature rise of the compressor-motor winding shall be determined at the end of the 4-hour test period. The temperature rise shall not be greater than that specified in 3.7.1.1. The temperature rise of the running winding in the compressor-motor shall be measured and computed by the resistance method.

4.3.3 Inclination test. - The unit shall be inclined at an angle of 15 degrees each side of the vertical in each of two vertical planes at right angles to each other and operated at least 1 hour in each plane with no abnormal variations in temperature. Condensate from the evaporator shall collect and drain into the container without any spillage in any of the inclined positions.

4.4 Sampling. -

4.4.1 Lot. - The refrigerating equipment offered for delivery at one time shall be considered a lot for purposes of inspection and tests.

4.4.2 Sampling for quality conformance inspection. - Sample units shall be selected from each lot in accordance with table II and inspected for adjustment, fits, leaks, material, finish, and general conformance with this specification. Each sample unit shall be subjected to the tests specified in 4.5.2. If any unit fails in any test or is found nonconforming in any requirement, it shall be counted a defective unit, and if the number of such defective units in any sample exceeds the acceptance number shown in table II for the sample, the lot represented by the sample shall be rejected.

Table II - Sampling for quality conformance inspection.

Lot size number of units	Sample size number of units	Defective units	
		Acceptance number	Rejection number
1 to 6	All	-	-
7 to 15	7	0	1
16 to 25	10	0	1
26 to 40	13	0	1
41 to 65	17	1	2
66 to 110	22	1	2
111 to 180	28	2	3
181 to 300	35	2	3
301 to 500	45	3	4

4.5 Quality conformance inspection. -

4.5.1 Each unit shall be subjected to the tests specified in 4.5.1.1 through 4.5.1.4.1.

4.5.1.1 Pressure and leakage test. - All refrigerant containing parts on the high pressure side of the refrigeration system shall withstand, without damage, an air and gas test of 235 pounds per square inch gauge (p.s.i.g.). The refrigerant containing parts on the low-pressure side of the refrigeration system shall withstand, without damage, an air and gas test of 140 p.s.i.g. While subjected to the pressures indicated above the refrigerating system shall be leak tested by means of a halide leak detector and shall be free of evidence of leaks. The hologen leak detector shall have a leak index sensitivity of 1/2 ounce per year.

4.5.1.2 Insulation resistance test. - With the motor at ambient temperature, the insulation resistance shall be as specified in 3.7.3. The measuring of insulation shall be made by connecting the line terminals together, manually closing the line and fan contactors and measuring the resistance between terminals and ground. The insulation resistance shall be measured with a 500-volt insulation-resistance-meter. The time of test voltage application shall be not less than 60 seconds.

4.5.1.3 Dielectric strength test. - With the motor at ambient temperature, the dielectric strength shall be as specified in 3.7.4. The dielectric strength test shall be conducted with the line terminals together and manually closing the line contactors.

4.5.1.4 Operating test. - The units shall be operated for a period of at least one hour with controls set for specified operating conditions. At the conclusion of this operational test, the entire refrigerant circuit connections under refrigerant pressure, shall be given a Halide test to determine leakage. In the event of leakage, all leaks shall be repaired and the performance test shall be repeated.

4.5.1.4.1 Under equivalent ambient temperature, the electrical power input shall be measured and compared with the input of all other units which have been tested. If any unit requires 7 percent more power than the average of all the acceptable units, it shall not be offered for delivery until the cause has been found and corrected.

4.5.2 Each sample unit selected as specified in 4.4.2, shall be inspected for adjustment, fits, leaks, material, finish, and general conformance with this specification and as follows:

(a) All seal caps in the refrigerant system shall be provided with a gasket and shall be tight against freon leaks.
(b) Bolts, nuts, and screws shall be tight: equipment and parts shall be properly fastened and secured.

Source: https://assist.dla.mil -- Downloaded: 20261O-19T06:56Z
Check the source to verify that this is the current version before use.

(c) No parts shall be fractured, split, torn, dented or otherwise affecting serviceability.
(d) The limiting and mounting mensions shall be in accordance with drawings (see 3.12).
(e) There shall be no sharp or ragged edges on the sheeting that may be injurious to personnel.
(f) The manual shall be packed with the unit.
(g) The insulation resistance to ground shall be satisfactory (see 4.5.1.2).
(h) The dielectric strength shall be satisfactory (see 4.5.1.3).
(i) The refrigerant system shall be free of refrigerant leaks (see 4.5.1.4).
(j) The power consumption for any unit shall not be excessive (see 4.5.1.4.1).

5. PREPARATION FOR DELIVERY

5.1 Domestic shipment and early equipment installation and for storage of onboard repair parts. -

5.1.1 Basic equipment or item. -

5.1.1.1 Preservation and packaging. - Preservation and packaging shall be sufficient to afford adequate protection against corrosion, deterioration and physical damage during shipment from the supply source to the using activity and until early installation and may conform to the suppliers commercial practice when such meets these requirements. Manuals furnished with basic equipment shall be packaged in sealed, waterproof containers.

5.1.1.2 Packing. - Packing shall be accomplished in a manner which will insure acceptance by common carrier at the lowest rate and will afford protection against physical or mechanical damage during direct shipment from the supply source to the using activity for early installation. The shipping containers or method of packing shall conform to the Uniform Freight Classification Rules and Regulations or other carrier regulations as applicable to the mode of transportation and may conform to the suppliers commercial practice when such meets these requirements.

5.1.1.3 Marking. - Shipment marking information shall be provided on interior packages and exterior shipping containers in accordance with the contractor's commercial practice. The information shall include nomenclature, Federal stock number, contract or order number, contractor's name and destination.

5.1.2 Onboard repair parts. - Repair parts shall be preserved and packaged level A, packed level C and marked levels A and C respectively in accordance with MIL-E-17555.

5.2 Domestic shipment and storage or overseas shipment. - The requirements and levels of preservation, packaging, packing and marking for shipment shall be specified by the procuring activity (see 6.1).

(5.2.1 The following provides various levels of protection during domestic shipment and storage or overseas shipment, which may be required when procurement is made by a Government activity.

5.2.1.1 Preservation and packaging. -

5.2.1.1.1 Level A. - Each complete unit (see 3.3) shall be unit protected and packaged in accordance with method I of MIL-P-116. Exterior unpainted ferrous metal surfaces shall be coated with preservative compound conforming to grade 4 of MIL-C-16173.

5.2.1.1.2 Level C. - Preservation and packaging of each unit (see 3.3) shall be sufficient to afford adequate protection against corrosion, deterioration and physical damage during shipment from the supply source to the using activity for early installation. This level may conform to the supplier's commercial practice when such meets the requirements of this level.

5.2.1.2 Packing. -

5.2.1.2.1 Level A. - Each complete unit, packaged as specified in the contract or order, shall be packed in a container conforming to any one of the following specifications at the option of the contractor:

Specification	Classification
PPP-B-591	Overseas type
PPP-B-640	Class 2

Shipping containers shall be closed in accordance with the applicable box specification or appendix thereto. The gross weight of woodcleated boxes shall not exceed 200-pounds; fiberboard boxes shall not exceed the weight limitations of the applicable fiberboard box specifications.

5.2.1.3 Marking. - In addition to any special marking, shipping containers shall be marked in accordance with MIL-STD-129.

5.3 Repair parts. - Repair parts shall be preserved and packaged level A or C; packed level A, B or C and marked in accordance with specification MIL-E-17555.

5.4 Drawings. - Preparation for delivery shall be in accordance with MIL-D-963. Unless otherwise specified packages and shipping containers shall be marked in accordance with level C requirements of MIL-STD-129.

Source: https://assist.dla.mil -- Downloaded: 2026-10-19T06:56Z
Check the source to verify that this is the current version before use.

5.5 Manuals.- Manuals shall be packaged, packed and marked for shipment in accordance with MIL-M-15071.)

6. NOTES

6.1 Ordering data.- Procurement documents should specify the following:

(a) Title, number, and date of this specification.
(b) The number of sets of repair parts to be furnished (see 3.11).
(c) Preservation, packaging, packing and marking requirements other than those required by 5.1 (see 5.2).

6.1.1 Bid data.- Bidders shall submit with their bids a statement, in duplicate, showing an itemized list, identification of components and total weight of the equipment, including repair parts.

Notice.- When Government drawings, specifications, or other data are used for any purpose other than in connection with a definitely related Government procurement operation, the United States Government thereby incurs no responsibility nor any obligation whatsoever; and the fact that the Government may have formulated, furnished, or in any way supplied the said drawings, specifications, or other data is not to be regarded by implication or otherwise as in any manner licensing the holder or any other person or corporation, or conveying any rights or permission to manufacture, use, or sell any patented invention that may in any way be related thereto.

Preparing activity:
Navy - Ships
(Project 4440-N004Sh)

Source: https://assist.dla.mil -- Downloaded: 20261O-19T06:56Z
Check the source to verify that this is the current version before use.

Source: https://assist.dla.mil -- Downloaded: 2026-10-19T06:56Z
Check the source to verify that this is the current version before use.

SPECIFICATION ANALYSIS SHEET
NAVSHIPS-4863 (8-61)

BUDGET BU. NO. 45-R309

INSTRUCTIONS

This sheet is to be filled out by personnel either Government or contractor, involved in the use of the specification in procurement of products for ultimate use by the Bureau of Ships

This sheet is provided for obtaining information on the use of this specification which will insure that suitable products can be procured with a minimum amount of delay and at the least cost.

Comments and the return of this form will be appreciated.

Fold on dotted lines on reverse side, staple in corner, and send to Bureau of Ships, Specifications and Standardization Branch, Washington 25, D.C.

SPECIFICATION

ORGANIZATION	CITY	STATE

CONTRACT NO.	QUANTITY OF ITEMS PROCURED	DOLLAR AMOUNT
		$

MATERIAL PROCURED UNDER A DIRECT GOVERNMENT CONTRACT ☐ OR A SUBCONTRACT ☐

1. HAS ANY PART OF THE SPECIFICATION CREATED PROBLEMS OR REQUIRED INTERPRETATION IN PROCUREMENT USE?
   a. GIVE PARAGRAPH NUMBER AND WORDING

   b. RECOMMENDATIONS FOR CORRECTING THE DEFICIENCIES.

2. COMMENTS ON ANY SPECIFICATION REQUIREMENT CONSIDERED TOO RIGID.

3. IS THE SPECIFICATION RESTRICTIVE? ☐ YES ☐ NO IF THE ANSWER IS "YES", IN WHAT WAY?

4. REMARKS (*Attach any pertinent data which may be of use in improving this specification.*) PLACE THIS FORM AND PAPERS IN AN ENVELOPE AND SEND TO THE BUREAU.

SUBMITTED BY (*Print name and activity*)	DATE

Source: https://assist.dla.mil -- Downloaded: 2026-10-19T06:56Z
Check the source to verify that this is the current version before use.

Fold

DEPARTMENT OF THE NAVY
BUREAU OF SHIPS
WASHINGTON 25, D.C.
OFFICIAL BUSINESS

POSTAGE AND FEES PAID
NAVY DEPARTMENT

CHIEF, BUREAU OF SHIPS
SPECIFICATIONS AND STANDARDIZATION BRANCH
DEPARTMENT OF THE NAVY
WASHINGTON 25, D. C.

Fold

Source: https://assist.dla.mil -- Downloaded: 2026-10-19T06:56Z
Check the source to verify that this is the current version before use.